

## ADDENDUM 01 – DEPARTMENT of STATE POLICE NORTHVILLE FORENSIC LABORATORY – ELEVATOR REPLACEMENT DTMB

**DATE:** September 11, 2023

**PROJECT:** DTMB – DSP – Elevator Replacement – Northville Lab File No. 551/21167.TYC

**PROJECT #:** 22-300-00

---

This Addendum is issued for the purpose of modifying and/or clarifying the original drawings and specifications and shall take precedence over them.

All work included herein shall be in accordance with the original drawings and specifications except as specifically noted herein. All incidental items required to provide the following modifications shall be included even though not specifically described.

This Addendum is being sent to all bidders receiving plans and specifications. Receipt of this Addendum shall be noted on Proposal Form in appropriate locations.

### SPECIFICATIONS:

1. Section 01020 – Allowances
  - A. Note the contingency allowance of \$30,000.00 to be included in the bidders base bid.
2. Section 01500 – Construction Facilities and Temporary Controls
  - A. This section controls the temporary facilities allowed/not allowed.
3. Section 01100 Project Procedures
  - A. Paragraph 3 controls the temporary barriers and enclosures. Actual barrier locations and construction of to be determined. Provide for one 7' long x 9' tall dust control partition and one 3' x 7' solid hinged door and hardware for security purposes.
4. Section 015000 – This section is to be removed, and no longer valid.

DRAWINGS – No drawings are issued with this addendum.

END OF ADDENDUM 01

P:\2022\22300\DOCS\Addenda\Re-Bid\Add 01 - Narrative.docx