

### ADDENDUM No. 5

Project: **Washtenaw - Addition**  
Location: 7400 South Huron River Dr., Ypsilanti, MI, 48197  
Contract No: Y21456      File No: 511/21326.CAK      DMVA No: 26C8022016  
A/E File #: 2105-01  
Date: August 24<sup>th</sup>, 2022

---

#### I. Questions and Answers from the Bidding Period:

Question 1: The specs state that this project will extend the buildings existing Fire Alarm System - Notifier by Honeywell. Verify. If the extension is of the Notifier panel, then that should be the only equipment listed. Is this a new fire system that is open to the other manufacture equipment?

Answer 1: Modify Specification section 28 31 00-2.1 to remove listed alternate manufacturers. New notifier panel and associated components shall match the existing panel. See Below for photos of existing panel.





END OF ADDENDUM