DTMB-0414 (Rev 6/25)

DEPARTMENT OF TECHNOLOGY, MANAGEMENT AND BUDGET
State Facilities Administration
Design & Construction Division

CONSTRUCTION BID ADDENDUM NO. 3

This form identifies an Addendum to Bidding Documents, and incorporates interpretations or clarifications, modifications, acceptance of proposed "or equal" materials, and other information into the Bidding Documents. Addenda will be numbered by the Professional and distributed through www.michigan.gov/SIGMAVSS as an attachment.

TO: **ALL BIDDERS**		DATE ISSUED 11/6/2026
PROJECT NAME MDOT Aeronautics Building - HVAC Equipment Upgrades		FILE NUMBER 591/26063.KMM
PROFESSIONAL Matrix Consulting Engineers	PROJECT DIRECTOR Kurt Maiberger	BID OPENING DATE: 11/11/2026

ADDENDUM ITEMS:

1. Clarification: New rooftop units are to be the same weight or less than the basis of design rooftop units.
2. Clarification: There are no fees filing with the FAA for utilizing a crane for the project.
3. Clarification: The new RTU-5 and RTU-9 are to be equipped with manufacturer provided single zone VAV sequence/controls.
4. Clarification: Contractor is responsible for coordinating with MDOT and the Lansing Airport for additional required training if the crane is going to be parked on the tarmac. Contractor to ensure that all FAA, Lansing Airport, and MDOT procedures and protocols when using a crane onsite.
5. Clarification: The building will be occupied during construction.

ACKNOWLEDGEMENT: This Addendum must be acknowledged by the Bidder in the space provided in the Bid Summary and Bid Form. Failing to acknowledge Addenda may be cause for the Bid to be rejected. Addenda will become part of the Contract Documents.

PROFESSIONAL: Devon Pung, Matrix	DATE: 11/5/2026
APPROVED BY: Kurt Maiberger PROJECT DIRECTOR: Kurt Maiberger	DATE: 11/5/2026