



State of Michigan

**Department of Technology, Management and Budget
State Facilities Administration
Design and Construction Division**

**DCSPEC
Bidding and Contract Document
Minor Projects**

**File No. 171/26076.GSA
Department/Agency: 171
Flint Parking Ramp – Upgrade Fire
Suppression System
300 Harrison Street
Flint, MI 48502**

June 12, 2026

BID SUMMARY

**DEPARTMENT OF TECHNOLOGY, MANAGEMENT AND BUDGET
STATE FACILITIES ADMINISTRATION
DESIGN AND CONSTRUCTION DIVISION
3111 W. St. Joseph Street
Lansing, Michigan 48917**

Bids must be submitted electronically at: <https://sigma.michigan.gov/webapp/PRDVSS2X1/AltSelfService>

| | | |
|--|---|--|
| FILE NUMBER 171/26076.GSA | DEPARTMENT/AGENCY Department of Technology, Management & Budget | |
| CONTRACT TIME(S) Substantial Completion: 22 weeks (154 Days) from Notice to Proceed | PROJECT NAME Flint Parking Ramp - Upgrade Fire Suppression System | LOCATION Flint Parking Ramp 300 Harrison Street Flint, MI 48502 |
| BID OPENING DATE July 8, 2026 at 2:00 pm ET | FOR AN EXAMINATION OF THE SITE CONTACT: Brian Walts: Phone 517-202-1960, email: WaltsB@michigan.gov | |
| SEE SECTION 00100 INSTRUCTIONS TO BIDDERS AND SECTION 00700 GENERAL CONDITIONS PROVIDED WITH THE BIDDING DOCUMENTS. BID: WE PROPOSE TO FURNISH, PERFORM AND COMPLETE THE ENTIRE WORK IN ACCORDANCE WITH THE CONTRACT DOCUMENTS IN CONSIDERATION OF THE BID PRICE (S) STATED BELOW. | | |
| FIRM NAME AND COMPLETE ADDRESS | TELEPHONE NUMBER and E-MAIL ADDRESS | |
| <input type="checkbox"/> Qualified Disabled Veteran | SIGMA VENDOR NUMBER <small>(protected information required for processing payments)</small> | |
| BIDDER'S SIGNATURE AND TITLE | DATE | WITNESS' SIGNATURE DATE |

By signing this bid above, bidder certifies their enclosed Qualified Disabled Veteran and Michigan-Based Business Certifications.

BASE BID FROM BID SCHEDULE (Include specified Allowances):

_____ Dollars \$ _____
(use words) (in figures)

Alternate 1: (Add/Subtract) _____ Dollars \$ _____
(use words) (in figures)

Alternate 2: (Add/Subtract) _____ Dollars \$ _____
(use words) (in figures)

Alternate 3: (Add/Subtract) _____ Dollars \$ _____
(use words) (in figures)

A PERFORMANCE BOND AND A PAYMENT BOND ARE REQUIRED FOR ALL BIDS OVER \$50,000.00. EACH BID MUST BE ACCOMPANIED BY A FIVE (5) PERCENT BID GUARANTEE. BUILDERS RISK INSURANCE IS REQUIRED TO BE PROVIDED BY THE CONTRACTOR UNLESS OTHERWISE INDICATED IN THE BID DOCUMENTS.

BIDDERS ARE ALSO CAUTIONED TO FAMILIARIZE THEMSELVES WITH ALL OF THE OTHER CONDITIONS OF THE CONTRACT.

Project Scope of Work: Full replacement of the existing dry fire suppression system including new fire department connection, dry valve, air compressor, and all fire suppression piping.

The Bidder must figure its Base Bid on the specified, or Addendum-approved, materials and equipment **only**. No "or equal" or substitution proposals will be permitted after Bid opening, except as provided in the General Conditions.

Addenda: Bidder acknowledges receipt of Addenda: No. ___ dated: _____, No. ___ dated: _____ No. ___ dated: _____

BID SCHEDULE

Base Bid Schedule - The Bidder will complete the Work and accept as full payment, for the Work items listed, the following Unit Prices and/or Item Bid Prices, as applicable:

| Base Bid Item No. | Bid Quantity | Description | Unit Price | Item Bid Price |
|---|--------------|-------------------------|-----------------|-----------------|
| General Trades | | | | |
| Fire Suppression | | | | |
| Electrical | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | ALLOWANCE AMOUNT | \$20,000 | \$20,000 |
| TOTAL (This amount should equal the Base Bid amount on the Bid Summary Form) | | | | \$ |

Base Bid (Sum of Item Bid Prices for all Base Bid Items):

_____ Dollars \$ _____
 (use words) (in figures)

DEPARTMENT OF TECHNOLOGY, MANAGEMENT AND BUDGET
State Facilities Administration
Design & Construction Division

Qualified Disabled Veteran (QDV)
Business Representation

'Qualified Disabled Veteran,' means a business entity that is 51% or more owned by one or more veterans with a service-connected disability.

'Qualified Disabled,' means a business entity that is 51% or more owned by one or more with a service-connected disability.

The vendor represents that it IS _____, a qualified disabled veteran.

The contractor represents and warrants that the company meets the above (when checked) and has attached supporting documentation per the following:

Each bid requesting the Qualified Disabled Veterans (QDV) preference, in accordance with Public Act 22 of 2010, MCL 18.1241.3 shall include a DD214 Proof of Service and Discharge, a Veterans Administration rating decision letter, proof of disability (if the disability is not indicated on the DD214), and appropriate legal documents setting forth the 51% natural persons QDV ownership.

Fraudulent Certification as a Qualified Disabled Veteran may result in debarment under MCL 18.264.

Certification of a Michigan Based Business

(Information Required Prior to Contract Award for Application of State Reciprocity Provisions)

To qualify as a Michigan Based Business:

Vendor must have, during the 12 months immediately preceding this bid deadline:

or

If the business is newly established, for the period the business has been in existence, it has:

(Check all that apply):

- Filed a Michigan single business tax return showing a portion, or all the income tax base allocated or apportioned to the State of Michigan pursuant to the Michigan Single Business Tax Act, 1975 PA 228, MCL 208.1 – 208.145: or
- Filed a Michigan income tax return showing income generated in or attributed to the State of Michigan; or
- Withheld Michigan income tax from compensation paid to the bidder's owners and remitted the tax to the Department of Treasury; or

I certify that **I have personal knowledge** of such filing or withholding, that it was more than a nominal filing for the purpose of gaining the status of a Michigan business, and that it indicates a significant business presence in the state, considering the size of the business and the nature of its activities.

I authorize the Michigan Department of Treasury to verify that the business has or has not met the criteria for a Michigan business indicated above and to disclose the verifying information to the procuring agency.

Bidder shall also indicate one of the following:

- Bidder qualifies as a Michigan business (provide zip code: _____)
- Bidder does not qualify as a Michigan business (provide name of State: _____).
- Principal place of business is outside the State of Michigan, however service/commodity provided by a location within the State of Michigan (provide zip code: (_____)).

Fraudulent Certification as a Michigan business is prohibited by MCL 18.1268 § 268. A BUSINESS THAT PURPOSELY OR WILLFULLY SUBMITS A FALSE CERTIFICATION THAT IT IS A MICHIGAN BUSINESS OR FALSELY INDICATES THE STATE IN WHICH IT HAS ITS PRINCIPAL PLACE OF BUSINESS IS GUILTY OF A FELONY, PUNISHABLE BY A FINE OF NOT LESS THAN \$25,000 and subject to debarment under MCL 18.264.

ASBESTOS ABATEMENT ATTESTATION

SUBMISSION REQUIRED WITH ALL BIDS

Pursuant to the Public Entity Asbestos Removal Verification Act, PA 59 of 2024, MCL 338.3371 et seq. (“the Act”), the Owner will conduct the background investigation as required of any asbestos abatement contractor, or a general contractor that contracts with an asbestos abatement contractor, for the abatement of asbestos. Under the Act, an “Asbestos abatement contractor” means a business entity that is licensed under the asbestos abatement contractors licensing act, 1986 PA 135, MCL 338.3101 to 338.3319, and that carries on the business of asbestos abatement on the premises of another business entity and not on the asbestos abatement contractor’s premises. Asbestos abatement contractor includes an individual or person with an ownership interest in a business entity described in MCL 338.3373(b).

(INSTRUCTIONS: Professional to select one of these two statements, then *delete* the not selected statement and instructions.)

THE SCOPE OF WORK TO BE COVERED UNDER THIS CONTRACT CONTAINS ASBESTOS ABATEMENT AND THIS ATTESTATION MUST BE COMPLETED.

THE SCOPE OF WORK TO BE COVERED UNDER THIS CONTRACT DOES NOT CONTAINS ASBESTOS ABATEMENT AND THIS ATTESTATION IS TO BE LEFT BANK.

Contractor attests that: *(check one:)*

1. The Contractor will self-perform all asbestos abatement project work and attests that Contractor has not been issued 5 or more notices of violation of environmental regulations (State and/or Federal), nor has been subject to an administrative consent order or a consent judgment involving environmental regulations.
2. The Contractor will self-perform all asbestos abatement project work; however, Contractor has been issued 5 or more notices of violation of environmental regulations (State and/or Federal), or has been subject to an administrative consent order or a consent judgment involving environmental regulations, requiring Owner to conduct a background investigation and a public hearing pursuant to PA 59 of 2024, MCL 338.3371 et seq.
3. The Contractor nominates the following Sub-contractor for all asbestos abatement project work and attests that the nominated Sub-contractor has not been issued 5 or more notices of violation of environmental regulations (State and/or Federal), nor has been subject to an administrative consent order or a consent judgment involving environmental regulations:

Nominated Sub-contractor: _____

4. The Contractor nominates the following Sub-contractor for all asbestos abatement project work; however, the nominated Sub-contractor has been issued 5 or more notices of violation of environmental regulations (State and/or Federal), or has been subject to an administrative consent order or a consent judgment involving environmental regulations, requiring Owner to conduct a background investigation and a public hearing pursuant to PA 59 of 2024, MCL 338.3371 et seq.

Nominated Sub-contractor: _____

BID BOND

BID SUBMITTED ON the _____ day of _____, 20____.

Bid Security is in the form of a Bid Bond _____ Bid Bond form has been duly executed _____; or

A Bank Certified or Cashier's check ___ or Money Order ___ is attached to this page ____ *(If Bid Security is by Check or Money Order, the original check or money order must be delivered to the issuing office before Bid Due Time. ALL other SIGMA bid submittals are also still to be made).*

If the Bidder is an Individual:

Name of Individual: _____

Name & Title of Person Authorized to sign: _____

Signature: _____
 (If not the Individual, Attach Power of Attorney) Date

Doing Business as: _____

Business Address: _____

County of registration _____

Telephone: _____ FAX: _____

If the Bidder is a Partnership:

By: _____
 (True Name of the Partnership)

Partner Authorized to Sign Date

Signature: _____
 (Attach evidence of Authority to sign) Date

Business Address: _____

County of registration _____

Telephone: _____ FAX _____

If the Bidder is a Corporation:

By: _____
 (Legal Corporation Name)

Name & Title of Authorized Officer: _____

Signature: _____
 (Attach evidence of Authority to sign) Date

Name & Title of Officer Attesting: _____

Signature: _____
 Date

Business Address: _____

Telephone: _____ FAX _____

(State of Incorporation): _____

If The Bidder is A Joint Venture: JOINT VENTURE SIGNATURES MUST BE AS PROVIDED IN INSTRUCTIONS TO BIDDERS. EACH JOINT VENTURER SIGNING THE BID MUST SIGN IN THE MANNER INDICATED FOR AN INDIVIDUAL, A PARTNERSHIP OR A CORPORATION. IF MORE THAN TWO JOINT VENTURERS OF THE SAME TYPE ARE INCLUDED, USE ADDITIONAL PAGES. JOINT VENTURE STATE OF INCORPORATION _____ OR COUNTY OF REGISTRATION _____

POST-BID SUBMITTALS

The PSC will request this submittal after bid opening. Complete and submit these items within two business days after the request.

BIDDER'S EXPERIENCE MODIFICATION RATING (EMR) _____

Attach letter of explanation if the Bidder does not have an EMR.

PROPOSED PROJECT SUPERINTENDENT _____

Attach brief resume or list of similar successful projects.

LIST OF SIMILAR PROJECTS COMPLETED BY THE BIDDER

Please list at least three completed projects of similar size and complexity to the project being bid, with reference contact information

REFERENCE # _____

Owner: _____

Project/Contract Name: _____

Location of Project/Contract: _____

Contract Price: _____ Project/Contract Started: _____ Completed: _____

Owner's Representative (Name and Telephone): _____

Scope of Project/Contract: _____

REFERENCE # _____

Owner: _____

Project/Contract Name: _____

Location of Project/Contract: _____

Contract Price: _____ Project/Contract Started: _____ Completed: _____

Owner's Representative (Name and Telephone): _____

Scope of Project/Contract: _____

REFERENCE # _____

Owner: _____

Project/Contract Name: _____

Location of Project/Contract: _____

Contract Price: _____ Project/Contract Started: _____ Completed: _____

Owner's Representative (Name and Telephone): _____

Scope of Project/Contract: _____

POST BID SUBMITTALS: LIST OF SUBCONTRACTORS

The Apparent Low Bidder shall nominate for each Division of Specification and/or trade category, the Subcontractor to be awarded Sub-agreements, including the apparent Low Bidder if work is to be self-performed. The Apparent Low Bidder will ensure that all Subcontractors have a current State Project Registration in compliance with PA10 of 2023, as amended in PA110 of 2024. Nominated subcontractors shall not be removed, replaced, or added to except by written request for good reason, subject to Owner acceptance. Notwithstanding anything to the contrary, the Owner has the right to object, regardless of cause, to any asbestos abatement Subcontractor nominated by the Contractor to be awarded a Sub-agreement that has 5 or more notices of violation of environmental regulations, or has been subject to an administrative consent order or a consent judgment involving environmental regulations, within the immediately preceding 5 years.

| Division, Specification Section and/or Trade | Nominated Subcontractor(s) | Amount of Subcontract |
|--|----------------------------|-----------------------|
| 1. _____ | _____ | _____ |
| 2. _____ | _____ | _____ |
| 3. _____ | _____ | _____ |
| 4. _____ | _____ | _____ |
| 5. _____ | _____ | _____ |
| 6. _____ | _____ | _____ |
| 7. _____ | _____ | _____ |
| 8. _____ | _____ | _____ |
| 9. _____ | _____ | _____ |
| 10. _____ | _____ | _____ |
| 11. _____ | _____ | _____ |
| 12. _____ | _____ | _____ |
| 13. _____ | _____ | _____ |
| 14. _____ | _____ | _____ |

The undersigned Apparent Low Bidder _____ certifies that all the information and data furnished in this List of Subcontractors are current, accurate and complete as of the date stated below.

Signed by: _____ Name _____ Title _____

on this _____ day of _____, 20_____.

PERFORMANCE BOND

SURETY COMPANY REFERENCE No. _____

That "the **Contractor**," _____, a corporation ____, individual ____, partnership ____, joint venture __ of the State of _____, qualified to do business in the State of Michigan, as Principal, and "the Surety," _____, of the State of _____, as surety, are held and bound unto the State of Michigan, "the **Owner**," as Obligee, in the amount of _____ Dollars (\$ _____), for the payment of which the **Contractor** and Surety bind themselves, their respective heirs, successors, legal representatives and assigns, jointly and severally, in compliance with 1963 PA 213, as amended, MCL 129.201 et seq.

The **Contractor** has entered into "the Contract" with the **Owner** for _____, "the Work," covered by the Contract Documents, which are incorporated into this Performance Bond by this reference.

If the **Contractor** faithfully performs and fulfills all the undertakings, covenants, terms, conditions, warranties, indemnifications and agreements of the Contract Documents within the Contract Time (including any authorized changes, with or without notice to the Surety) and during the Correction Period, and if the **Contractor** also performs and fulfills all the undertakings, covenants, terms, conditions, warranties, indemnifications and agreements of any and all duly authorized modifications of the Contract Documents, then THIS OBLIGATION IS VOID, OTHERWISE TO REMAIN IN FULL FORCE AND EFFECT.

A. No change in Contract Price or Contract Time, "or equal" or substitution or modification of the Contract Documents (including addition, deletion, or other revision) releases the Surety of its obligations under this Section 00610 Performance Bond. The Surety expressly waives notice of any such change in Contract Price or Contract Time, "or equal" or substitution or

modification of the Contract Documents (including addition, deletion, or other revision).

B. This Performance Bond must be solely for the protection of the **Owner** and its successors, legal representatives or assigns.

C. It is the intention of the **Contractor** and Surety that they must be bound by all terms and conditions of the Contract Documents (including, but not limited to General Conditions and this Performance Bond). However, this Performance Bond is executed pursuant to 1963 PA 213, as amended, MCL 129.201 et seq., and if any provision(s) of this Performance Bond is/are illegal, invalid, or unenforceable, all other provisions of this Performance Bond must nevertheless remain in full force and effect, and the **Owner** must be protected to the full extent provided by 1963 PA 213, as amended, MCL 129.201 et seq.

IMPORTANT: The Surety must be authorized to do business in the State of Michigan by the Department of Licensing and Regulatory Affairs, must be listed on the current U.S. Department of the Treasury Circular 570, and, unless otherwise authorized by the **Owner** in writing, must have at least an A– Best’s rating and a Class VII or better financial size category per current A. M. Best Company ratings.

Name, Address and Telephone of the Surety:

Address and Telephone of Agent, who is either a resident of, or whose principal office is maintained in, the State of Michigan

Signed and sealed this _____ day of _____, 20_____.

THE **CONTRACTOR**: (Print Full Name and Sign) By: _____

WITNESS _____ Name & Title: _____
Telephone No. _____

THE SURETY: (Print Full Name and Sign) Agent: _____

WITNESS _____ Attorney-in-Fact: _____
Telephone No. _____

Email: _____

PAYMENT BOND
SURETY COMPANY REFERENCE No. _____

“the **Contractor**,” _____, a corporation _____, individual _____, partnership _____, joint venture _____ of the State of _____, qualified to do business in the State of Michigan, as Principal, and “the **Surety**,” _____, of the State of _____, as surety, are held and bound unto the State of Michigan, “the **Owner**,” as Obligee, in the amount of _____ Dollars (\$ _____), for the payment of which the **Contractor** and Surety bind themselves, their respective heirs, successors, legal representatives and assigns, jointly and severally, in compliance with 1963 PA 213, as amended, MCL 129.201 et seq.

The **Contractor** has entered into “the Contract” with the **Owner** for _____, “the Work,” covered by the Contract Documents, which are incorporated into this Payment Bond by this reference.

If the **Contractor** promptly pays all claimants supplying labor or materials to the **Contractor** or to the **Contractor’s** Subcontractors in the prosecution of the Work, then THIS OBLIGATION IS VOID, OTHERWISE TO REMAIN IN FULL FORCE AND EFFECT.

A. All rights and remedies on this Payment Bond are solely for the protection of all claimants supplying labor and materials to the **Contractor** or the **Contractor’s** Subcontractors in the prosecution of the Work and must be determined in accordance with Michigan Law.

B. No change in Contract Price or Contract Time, “or equal” or substitution or modification of the Contract Documents (including addition, deletion, or other revision) must release the Surety of its obligations under this Payment Bond. The Surety

hereby expressly waives notice of any such change in Contract Price or Contract Time, “or equal” or substitution or modification of the Contract Documents (including addition, deletion, or other revision).

C. It is the intention of the **Contractor** and Surety that they must be bound by all terms and conditions of the Contract Documents (including, but not limited to this Payment Bond). However, this Payment Bond is executed pursuant to 1963 PA 213, as amended, MCL 129.201 et seq., and if any provision(s) of this Payment Bond is/are illegal, invalid, or unenforceable, all other provisions of this Payment Bond must nevertheless remain in full force and effect, and the **Owner** must be protected to the full extent provided by 1963 PA 213, as amended, MCL 129.201 et seq.

IMPORTANT: The Surety must be authorized to do business in the State of Michigan by the Department of Licensing and Regulatory Affairs, must be listed on the current U.S. Department of the Treasury Circular 570, and, unless otherwise authorized by the **Owner** in writing, must have at least an A– Best’s rating and a Class VII or better financial size category per current A. M. Best Company ratings.

Name, Address and Telephone of the Surety:

Address and Telephone of Agent, who is either a resident of, or whose principal office is maintained in, the State of Michigan

Signed and sealed this _____ day of _____, 20_____.

THE **CONTRACTOR**: (Print Full Name and Sign) By: _____

WITNESS _____ Name & Title: _____
Telephone No. _____

THE **SURETY**: (Print Full Name and Sign) Agent: _____

WITNESS _____ Attorney-in-Fact: _____
Telephone No. _____

Email: _____

TABLE OF CONTENTS

CONTRACT FORMS

BID SUMMARY FORM
 BID SCHEDULE
 QUALIFIED DISABLED VETERAN (QDV) BUSINESS REPRESENTATION
 CERTIFICATION OF A MICHIGAN BASED BUSINESS
 ASBESTOS ABATEMENT ATTESTATION
 BID BOND
 POST-BID SUBMITTALS
 PERFORMANCE BOND
 PAYMENT BOND

TABLE OF CONTENTS

DIVISION 00 BIDDING REQUIREMENTS AND CONTRACT CONDITIONS

| SECTION | TITLE | PAGE |
|---------|----------------------------|-------|
| 00010 | PRE-BID INFORMATION | 00-1 |
| 00100 | INSTRUCTIONS TO BIDDERS | 00-2 |
| 00120 | SUPPLEMENTARY INSTRUCTIONS | 00-7 |
| 00200 | INFORMATION TO BIDDERS | 00-7 |
| 00700 | GENERAL CONDITIONS | 00-8 |
| 00750 | SPECIAL WORKING CONDITIONS | 00-21 |
| 00800 | SUPPLEMENTARY CONDITIONS | 00-22 |
| 00900 | ADDENDA | 00-22 |

DIVISION 01 - GENERAL REQUIREMENTS

| | | |
|-------|--|-------|
| 01010 | SUMMARY OF WORK | 01-1 |
| 01020 | ALLOWANCES | 01-1 |
| 01025 | MEASUREMENT AND PAYMENT | 01-1 |
| 01030 | ALTERNATES | 01-1 |
| 01040 | COORDINATION | 01-2 |
| 01050 | FIELD ENGINEERING | 01-2 |
| 01060 | REGULATORY REQUIREMENTS | 01-2 |
| 01090 | REFERENCES | 01-4 |
| 01100 | PROJECT PROCEDURES | 01-5 |
| 01200 | PROJECT MEETINGS | 01-5 |
| 01300 | SUBMITTALS | 01-6 |
| 01400 | QUALITY CONTROL | 01-9 |
| 01500 | CONSTRUCTION FACILITIES AND TEMPORARY CONTROLS | 01-10 |
| 01600 | MATERIAL AND EQUIPMENT | 01-10 |
| 01650 | FACILITY START-UP | 01-11 |
| 01700 | CONTRACT CLOSE-OUT | 01-11 |
| 01800 | MAINTENANCE | 01-11 |

APPENDIX I – GLOSSARY

APPENDIX II – SPECIAL WORKING CONDITIONS

APPENDIX III – SPECIAL PROJECT PROCEDURES

APPENDIX IV – PREVAILING WAGE

DIVISION 01 – GENERAL REQUIREMENTS

| | |
|---------|----------------------------------|
| 01 3000 | SUBMITTALS |
| 01 7823 | OPERATION AND MAINTENANCE MANUAL |

DIVISION 09 – FINISHES

| | |
|---------|----------------------------|
| 09 9114 | INTERIOR EXTERIOR PAINTING |
|---------|----------------------------|

DIVISION 21 – FIRE SUPPRESSION

| | |
|---------|--|
| 21 0500 | COMMON WORK RESULTS FOR FIRE SUPPRESSION |
| 21 0517 | SLEEVES AND SLEEVE SEALS FOR FIRE SUPPRESSION PIPING |
| 21 0518 | ESCUTCHEONS FOR FIRE SUPPRESSION PIPING |
| 21 0523 | GENERAL DUTY VALVES FOR WATER BASED FIRE SUPPRESSION PIPING |
| 21 0529 | HANGERS AND SUPPORTS FOR FIRE SUPPRESSION PIPING AND EQUIPMENT |
| 21 0533 | HEAT TRACING FOR FIRE SUPPRESSION PIPING |
| 21 0553 | IDENTIFICATION FOR FIRE SUPPRESSION PIPING AND EQUIPMENT |
| 21 0700 | FIRE SUPPRESSION INSULATION |
| 21 1119 | FIRE DEPARTMENT CONNECTIONS |
| 21 1316 | DRY-PIPE SPRINKLER SYSTEMS |

DIVISION 26 – ELECTRICAL

| | |
|---------|---|
| 26 0010 | BASIC ELECTRICAL REQUIREMENTS |
| 26 0500 | COMMON WORK RESULTS FOR ELECTRICAL |
| 26 0519 | LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES |
| 26 0526 | GROUND AND BONDING FOR ELECTRICAL SYSTEMS |
| 26 0529 | HANGERS AND SUPPORTS FOR ELECTRICAL SYSTEMS |
| 26 0533 | RACEWAYS AND BOXES FOR ELECTRICAL SYSTEMS |
| 26 0544 | SLEEVES AND SLEEVE SEALS FOR ELECTRICAL RACEWAY AND CABLING |
| 26 0553 | IDENTIFICATION FOR ELECTRICAL SYSTEMS |
| 26 2726 | WIRING DEVICES |
| 26 2816 | ENCLOSED SWITCHES AND CIRCUIT BREAKERS |

SHEETS THRU (BOUND SEPERATLY)

| | |
|---|--------|
| Title Sheet | FP-000 |
| Fire Protection Symbols, Notes, Abbreviations, and Schedules | FP-100 |
| Parking Garage – Basement Floor Plan – Fire Protection Demolition | FP-300 |
| Parking Garage – Basement Floor Plan – Fire Protection New | FP-400 |
| Electrical Symbols, Notes, and Abbreviations | E-100 |
| Parking Garage – Basement Floor Plan - Electrical Demolition | E-300 |
| Parking Garage – Basement Floor Plan - Electrical New | E-400 |

DIVISION 00

BIDDING REQUIREMENTS AND CONTRACT CONDITIONS

SECTION 00010 PRE-BID INFORMATION

- 1. Invitation to Bid (ITB)** – Your firm is invited to submit a Bid. The State of Michigan as the Owner will receive **bids electronically through the SIGMA VSS website** at <https://sigma.michigan.gov/webapp/PRDVSS2X1/AltSelfService>, for Flint Parking Ramp – Upgrade Fire Suppression System until 2:00 p.m., ET, on July 8, 2026. The State reserves the right to cancel this Invitation to Bid (ITB) or change the date and time for submitting Bids by announcing same at any time before the established date and time for Bid opening. Bids must remain open for acceptance by the Owner for no less than the Bid hold period. Contractor may agree to extend the Bid hold period. However, any such extension must be based upon no increase in the Bid Price and/or Contract Time.
- 2. Work Description** – The Work, Full replacement of the existing dry fire suppression system including new fire department connection, dry valve, air compressor, and all fire suppression piping, DTMB File No. 171/26076.GSA includes, but is not necessarily limited to: Full replacement of the existing dry fire suppression system including new fire department connection, dry valve, air compressor, and all fire suppression piping.

The site is located Flint Parking Garage, 300 Harrison Street, Flint, MI 48502, as shown on the Drawings.

- 3. Bidding Documents** – Sets of Bidding Documents may be obtained at <https://sigma.michigan.gov/webapp/PRDVSS2X1/AltSelfService>.
- 4. Bid Security** – Each Bid must enclose a duly executed Bid Security, in the amount of five percent (5%) of the Bidder's Base Bid, paid to the "State of Michigan" in the form of a certified or cashier's check or money order drawn upon a bank insured by an agency of the Federal Government, or a bid bond signed by both the Contractor and authorized surety company. *If Bid Security is by check or money order, such certified or cashier's check or money order must be delivered in original copy before the Bid Due Time to:*

State Facilities Administration
Design & Construction Division
3111 W. St. Joseph Street
Lansing, Michigan 48917

All other Bid information must be submitted via SIGMA as per standard bidding procedure

- 5. Pre-Bid Conference** – A mandatory pre-bid conference will be held at Flint Parking Garage, 300 Harrison Street, Flint, MI 48502 on June 22, 2026 at 1:00 pm ET. A tour will be held on the same day, starting at right after the pre-bid conference. All prospective Bidders are required to attend the tour, if held. Other parties interested in the Work are encouraged to attend the tour. Addenda may be issued, in response to issues raised at the pre-bid conference and tour, or as the Owner and/or Professional may otherwise consider necessary. An individual is only permitted to represent one bidder at a mandatory Pre-Bid Conference.

The purpose of the pre-bid conference and inspection is to answer questions and provide an inspection tour of the Project site at the scheduled time on the day of the meeting. A representative will be available to assist the Contractors. Other inspection visits may be allowed if needed. Individuals needing special services to fully participate in the meeting due to a disability may contact Brian Walts at 517-202-1960.

FOR CORRECTIONAL FACILITIES ONLY: All contractor/vendor representatives attending a Pre-Bid Walk Through Meeting must submit a Vender/Contractor LEIN Request five business days prior to the meeting date, (LEIN Request For CAJ-1037 attached to Bid posting). Send the LEIN Request form, filled out and signed, by email to SmithD76@michigan.gov & FrostS1@michigan.gov. The email "Subject" must include (Facility Name, Project Name, Date & Time of Pre-Bid Walk Through Meeting).

- 6. SIGMA VENDOR NUMBER:** If you are bidding a State job for the first time, visit the State of Michigan SIGMA website, <https://sigma.michigan.gov/webapp/PRDVSS2X1/AltSelfService>, and follow the "SOM VSS User Guide for New Vendors" instructions, located under Forms and Reference Documents. Registration is required for bid submission. **Do not wait until the last minute to submit a proposal**, as the SIGMA system requires the creation of an account and entry of certain information, in addition to uploading and submitting the materials. The SIGMA system **will not** allow a proposal to be submitted after the proposal deadline, even if a portion of the proposal has been updated.

Questions on how to submit information or how to navigate in the SIGMA VSS system can be answered by calling **(517) 373-4111 or (888) 734-9749**.

- 7. Equal Employment Opportunity** – Covenants to not discriminate in employment by Contractors, Subcontractors and Suppliers required by Law are contained in Instructions to Bidders and General Conditions and are applicable to the Work and any Sub-agreement under the Contract.

- 8. **Contract Times** – The Contract Times and the associated liquidated damages are specified in the Contract.
- 9. **Contact Person** – All requests or inquiries concerning the Bidding Documents, or the Work must be addressed to: Matrix Consulting Engineers, Inc. #517-487-2511 att. Devon Pung, email dpung@matrixceinc.com. Questions will be accepted until June 29, 2026 at 5:00 pm ET.
- 10. **Award** – Subject to any agreed extension of the period for holding Bids, Bids must remain valid for acceptance by the Owner for 60 Calendar Days after the date of Bid opening. In addition, the Owner expressly reserves the right, within the Owner's sole discretion, to reject any or all Bids, to waive any irregularities, to issue post-Bid Addenda and re-bid the Work without re-advertising, to re-advertise for Bids, to withhold the award for any reason the Owner determines and/or to take any other appropriate action.
- 11. **Performance and Payment Bonds** – A performance bond and a payment bond are required for all contracts over \$50,000.00 for the contract award amount.

END OF SECTION 00010

SECTION 00100 INSTRUCTIONS TO BIDDERS

- 1. **PREPARATION OF BID:** Execute Bid fully and properly. Bid Summary Form (DTMB -0401D) and Bid Form Attachments must be used and completely filled out for the Bid to be considered responsive and meeting the requirements of the contract solicitation. All Bid prices must be printed or typed in both words and figures.
- 2. **BID CHECKLIST:** Submit Bid Summary Form with original signatures plus Bid Form Attachments in accordance with the electronic bidding procedures on the SIGMA VSS website.

A complete Bid will consist of the following forms, which are included immediately following the Bid Summary Form:

Bids **SUBMIT THESE Bid Forms and Bid Form Attachments**

- All Bids **Signed** and completed Bid Summary Form (DTMB-0401D).
- Bid Schedule.
- Qualified Disabled Veteran (QDV) Business Representation.
- Bid Security in the amount of 5% of Base Bid Price.
- If Bid Security is by check or money order, such certified or cashier's check or money order must be delivered in original copy before the Bid Due Time to:*
 - State Facilities Administration
 - Design & Construction Division
 - 3111 W. St. Joseph Street
 - Lansing, Michigan 48917
- All other Bid information must be submitted via SIGMA as per standard bidding procedure*
- Signature Authorization or copy of the partnership agreement if signed by all partners.
- Byrd Anti-Lobbying Certification (Only when Federal Provisions Addendum is included)
- Asbestos Abatement Attestation
- State Project Registration (SPR) for the Contractor and subcontractors (if applicable pursuant to 2023 PA 10, as amended, MCL 408.1101 et seq.)
- Other Forms;
- Over \$50K Forms listed under All Bids.
- Payment and Performance Bond (upon issuing the Notice of Award).
- Over \$100K Forms listed under All Bids.
- Certification of a Michigan Based Business.
- Payment and Performance Bond (upon issuing the Notice of Award).
- Over \$250K Forms listed under All Bids.

- Certification of a Michigan Based Business.
- Payment and Performance Bond (upon issuing the Notice of Award).

Apparent Low Bidders ONLY (upon request from the Professional)

- Experience Modification Rating (EMR), or a letter stating why the Bidder does not have one.
- Identification of the proposed project superintendent, with a resume or list of similar projects handled by that individual.
- A list of at least three (3) projects completed by the Bidder, within the last three (3) years of similar size and complexity, with contact information for references for each.
- A list of nominated sub-contractors, including proposed self-performed categories, for each Division/Trade/etc.

3. **BID SUBMISSION:** Bids must be submitted electronically through the SIGMA VSS website at <https://sigma.michigan.gov/webapp/PRDVSS2X1/AltSelfService>.

4. **BID GUARANTEE:** Each proposal must be accompanied by either a bank certified or cashier's check on an open, solvent bank or a bid bond with an authorized surety company (the surety must be listed on the current U.S. Department of the Treasury Circular 570) in the amount of five percent of the base bid payable to the State of Michigan, as a guarantee of good faith. If the successful Bidder fails to furnish satisfactory bonds and insurance within fifteen Calendar Days after Notice of Award, such guarantee must be forfeited to the State as liquidated damages. *If Bid Security is by check or money order, such certified or cashier's check or money order must be delivered in original copy before the Bid Due Time to the Issuing Office.* The bid security, exclusive of bid bonds, of all unsuccessful Bidders will be returned when an award is made or upon substitution of a bid bond. The bid security of the successful Bidder will be returned when the performance bond and labor and material bond are approved.

5. **Left Blank Intentionally.**

6. **MICHIGAN BASED BUSINESS CERTIFICATION:** All Bidders submitting Bids in excess of \$100,000.00 must complete the Certification of Michigan Based Business. This information will determine if a Bidder qualifies as a "Michigan" business for purposes of application of reciprocity where applicable.

7. **POST-BID SUBMITTAL:** For all projects, the Professional may request a Post-Bid Submittal from the Apparent Low Bidders. The Apparent Low Bidders must submit to the Professional, within **two** Business Days after receipt of the Professional's request,

- Experience Modification Rating (EMR), or a letter stating why the Bidder does not have one.
- Identification of the proposed project superintendent with a resume or list of similar projects managed by that individual.
- A list of at least three (3) projects completed by the Bidder, within the last three (3) years of similar size and complexity, with contact information for references for each.

Failure to provide the submittals may disqualify the Bid.

8. **SIGNATURES:** All Bids, notifications, claims, and statements must be signed as follows:

- (a) **Corporations:** Signature of official must be accompanied by a certified copy of the Resolution of the Board of Directors authorizing the individual signing to bind the corporation.
- (b) **Partnerships:** Signature of one partner must be accompanied by a signed copy of the legal document (e.g., Power of Attorney or partnering agreement) authorizing the individual signing to bind all partners. If Bid is signed by all partners, no authorization is required.
- (c) **Individual:** No authorization is needed. Each signature must be witnessed.

9. **BID PRICES:** The Bidder's Base Bid and Alternate Bid prices must include, and payment for completed Work will compensate in full for: all services, obligations, responsibilities, management, supervision, labor, materials, devices, equipment, construction equipment, general conditions, permits, patent fees and royalties, testing, inspection and approval responsibilities, warranties, temporary facilities, small tools, supplies, Bonds, insurance, taxes, mobilization, close-out, overhead and profit and all connections, appurtenances and any other incidental items of any kind or nature, as are necessary to complete the Work, in a neat, first quality, workmanlike and satisfactory manner in accordance with the Drawings and Specifications and as otherwise required to fulfill the requirements of the Bidding Documents. For each Cash Allowance item, the Bidder must include, within the Bid, all labor costs, construction equipment costs, insurance and Bond premiums and other general conditions costs and Fees (Bidder's and Subcontractors') to complete Work associated with the material, equipment, or other designated item to be

furnished under the Cash Allowance. For each Provisionary Allowance, the Bidder must include, within the Bid, insurance, premiums (not recoverable as labor burden) and Bond premiums required to complete Work that may be ordered under a Provisionary Allowance.

- 10. INSPECTION OF BIDDING DOCUMENTS AND SITE CONDITIONS:** The Bidder must carefully review and inspect all documents referenced and made part of this ITB, site conditions, all applicable statutes, regulations, ordinances, and resolutions addressing or relating to the goods and services under this contract. Failure to do so or failure to acquire clarifications and answers to any discovered conflicts, ambiguities, errors, or omissions in the Bidding Documents will be at the Bidder's sole risk.
- 11. SAFETY REQUIREMENTS AND LAWS:** The Bidder awarded the Contract must comply with all applicable federal, state, and local Laws including health and safety regulations, environmental protection, permits and licensing.
- 12. INTERPRETATIONS AND ALTERATIONS TO THE BID AND BIDDING DOCUMENTS:** All requests for clarification or interpretation of the Bidding Documents, all proposals for any modifications to the Bidding Documents, all requests for information and all other questions or inquiries about the Bidding Documents and/or the Work shall be submitted in writing to the Contact Person identified in the Bid Documents. Requests or inquiries received less than seven Calendar Days before the date of Bid opening will be answered only if (a) the response can be given through an Addendum made available at least seventy-two hours before Bid opening (counting Business Days only), (b) the Bid opening is postponed by Addendum, or (c) the Work is rebid without readvertising following the issuance of post-Bid Addenda.
- Bidders must not rely upon any oral statements or conversations regarding interpretations, clarifications, corrections, additions, deletions or other revisions or information to the Bidding Documents. Any addition, limitation or provision made with or attached to the Bid may render it non-responsive and/or irregular and be a cause for rejection. The Owner reserves the right to issue a post-Bid Addendum after opening the Bids and set a new date for the receipt and opening of sealed Bids. The Bidder acknowledges that any quantities of Unit Price Work given in this ITB are approximate only and payments will be made only for actual quantities of Unit Price Work completed in accordance with the Contract Documents.
- 13. MODIFICATION OF BID:** The entire bid must be resubmitted on the SIGMA VSS website.
- 14. BID WITHDRAWAL:** Except for timely filed claims of mathematical or clerical errors granted by the State, no Bid may be withdrawn within sixty Calendar Days after the Bid Opening time and date or before the Bid expiration date without forfeiting Bid security. The request to withdraw a Bid due to error must be submitted in writing along with the supporting documents within two Business Days after the date of Bid Opening. The claim must describe in detail the error(s), include a signed affidavit stating the facts of the alleged error(s) and request that the Bidder be released from its Bid. The review of the claim and its supporting documents by the State is only for the purpose of evaluating the Bidder's request and must not create duty or liability on the State to discover any other Bid error or mistake. The sole liability of any Bid error or mistake rests with Bidder.
- 15. OBJECTION TO THE AWARD:** A Bidder may file a written protest with the Director-DCD to object to the Apparent Low Bidder. This objection must be filed within seven Calendar Days after the date of Bid opening and must describe in detail the basis for the protest and request a determination. The Director-DCD will either dismiss or uphold the protest and notify the protestor within ten Calendar Days after receipt of the written protest.
- 16. BID IRREGULARITIES:** The following irregularities on any Bid Form or Bid Form Attachment must be resolved as follows:
- between SIGMA entry and signed Bid Summary attachment, the signed Bid Summary attachment will be used.
 - between words and figures, the words must be used.
 - between any sum, computed by the Bidder, and the correct sum, the sum computed by the Bidder must be used.
 - between the product, computed by the Bidder, of any quantity and Bid Unit Price and the correct product of the Unit Price and the quantity of Unit Price Work, the product extended by the Bidder must be used.
 - between a stipulated Allowance and the amount entered, the Allowance must be used.
 - any mobilization pay item exceeding the maximum specified must be ignored and the Bid must remain unchanged.
 - if any Bidder fails or neglects to bid a Unit Price for an item of Unit Price Work but shows a "Bid Price" for that item, the missing unit price must be computed from the respective quantity and the Item Bid Price shown.
 - if any Bidder fails or neglects to show a "Bid Price" for an item of Unit Price Work but bids a unit price, the missing Bid Price must remain as "zero"; and
 - if any Bidder fails or neglects to enter a Bid Price in both words and figures, the Bid Price printed or typed, whether in words or figures, must be used.
- 17. CERTIFICATION:** The bidder certifies to the best of its knowledge and belief that, within the past three (3) years, the bidder, an officer of the bidder, or an owner of a 25% or greater interest in the bidder:
- Has not been convicted of a criminal offense incident to the application for or performance of a contract or subcontract with the State of Michigan or any of its agencies, authorities, boards, commissions, or departments.
 - Has not had a felony conviction in any state (including the State of Michigan).

- (c) Has not been convicted of a criminal offense which negatively reflects on the bidder's business integrity, including but not limited to, embezzlement, theft, forgery, bribery, falsification, or destruction of records, receiving stolen property, negligent misrepresentation, price-fixing, bid rigging, or a violation of state or federal anti-trust statutes.
- (d) Has not had a loss or suspension of a license or the right to do business or practice a profession, the loss or suspension of which indicates dishonesty, a lack of integrity, or a failure or refusal to perform in accordance with the ethical standards of the business or profession in question.
- (e) Has not been terminated for cause by the Owner.
- (f) Has not failed to pay any federal, state, or local taxes.
- (g) Has not failed to comply with all requirements for foreign corporations.
- (h) Has not been debarred from participation in the bid process pursuant to Section 264 of 1984 PA 431, as amended, MCL 18.1264, or debarred or suspended from consideration for award of contracts by any other State or any federal Agency.
- (i) Has not been convicted of a criminal offense or other violation of other state or federal law, as determined by a court of competent jurisdiction or an administrative proceeding, that in the opinion of DTMB indicates that the bidder is unable to perform responsibly or which reflects a lack of integrity that could negatively impact or reflect upon the State of Michigan, including but not limited to, any of the following offenses under or violations of:
 - 1. The Natural Resources and Environmental Protection Act, 1994 PA 451, MCL 324.101 to 324.90106.
 - 2. A persistent and knowing violation of the Michigan Consumer Protection Act, 1976 PA 331, MCL 445.901 to 445.922.
 - 3. A finding that the bidder failed to pay the wages and/or fringe benefits as required by applicable law.
 - 4. Repeated or flagrant violations of 1978 PA 390 MCL 408.471 to 408.490 (law relating to payment of wages and fringe benefits).
 - 5. A willful or persistent violation of the Michigan Occupational Health and Safety Act, 1974, PA 154, MCL 408.10001 to 408.1094, including: a criminal conviction, repeated willful violations that are final orders, repeated violations that are final orders, and failure to abate notices that are final orders.
 - 6. A violation of federal or state civil rights, equal rights, or non-discrimination laws, rules, or regulations.
 - 7. Been found in contempt of court by a Federal Court of Appeals for failure to correct an unfair labor practice as prohibited by Section 8 of Chapter 372 of the National Labor Relations Act, 29 U. s. C. 158 (1980 PA 278, as amended, MCL 423.321 et seq).
- (j) Is not an Iran-Linked Business as defined in MCL 129.312.

A false statement, misrepresentation, or concealment of material facts on this certification may be grounds for rejection of this proposal or termination of the award and may be grounds for debarment.

18. REJECTION OF BID: The Bidder acknowledges the right of the Owner to reject any Bids and to waive any informality, defects or irregularity in any Bid received. In addition, the Bidder recognizes the right of the Owner to reject a Bid if:

- (a) the Bid is in any way incomplete or irregular.
- (b) the Bidder, Subcontractor or Supplier is not responsible as determined by the Owner.
- (c) the Bidder's performance as a Contractor was unsatisfactory under a prior Contract with the Owner for the construction, repair, modification, or demolition of a facility with the Owner, or under any other Contract, which was funded, directly or indirectly, by the Owner.
- (d) there are reasonable grounds for believing that collusion or unlawful agreements exists between any Bidders, that a Bidder is interested in more than one Bid, or that the Bid is not genuine.
- (e) the Bid exceeds the funds available.

19. MATERIALS AND EQUIPMENT SUBSTITUTION: Any Bidder wishing to use manufacturers or materials other than those specified must submit a written request to the Professional not later than seven days before due date for Bids. Request must be accompanied by product data to permit evaluation and comparison with specified products or materials. The Person submitting the request will be responsible for its prompt delivery. The Professional and the Owner will examine and evaluate the product data and if found acceptable, an Addendum will be issued and mailed or delivered to each Person who has received a set of Drawings and Specifications. All Addenda issued must be made a part of the Contract requirements. Contractor will be responsible for any extra work and expense incurred to satisfactorily and completely incorporating each substitute product into the Project.

20. MICHIGAN PRODUCTS AND RECYCLED PRODUCTS: All Contractors and Suppliers are encouraged to provide Michigan-made products and/or recycled products and/or green products and/or environmentally friendly products whenever possible where price, quality, and performance are equal to, or superior to, non-Michigan products and the requirements of the Contract Documents. The Contractor will be required to use alternatives to landfills for waste disposal such as reuse or recycle of asphalt, bricks, concrete, masonry, plastics, paint, glass, carpet, metals, wood, drywall, insulation, and any other waste materials to the extent practical.

21. PRE-AWARD PRODUCT SUBMITTALS: If requested, the Apparent Low Bidders must submit a summary of preliminary technical data on each product listed in n/a. The Apparent Low Bidders will furnish this summary data to the Professional within forty-eight hours of the Bid Opening. These submittals will be used to evaluate the Bid before the award. Failure to provide the submittals may disqualify the Bid.

22. CONTRACT AND CONTRACT AWARD: The Owner intends to award a Contract to the responsive and responsible best value bidder, except as provided below relative to veteran's preference.

- 22.1 Determination of the lowest three Bidders shall be based on the sum of the Base Bid and any additive and deductive Alternates the Owner accepts, in the order in which they are listed only. The Owner will accept an Alternate only if all other previously listed Alternates are also accepted unless acceptance by the Owner of Alternates in a different order does not affect determination of the lowest three bidders in any way.
- 22.2 The bids will be evaluated for best value based on price and qualitative components by comparing the qualitative components of the three lowest responsive and responsible Bidders. The comparison may also include other Bidders whose bids are within 10% of the lowest responsive and responsible Bidder.
- 22.3 If a Qualified Disabled Veteran meets the requirements of the contract solicitation, provides acceptable responses to both Part One and Part Two of the Best Value Construction Bidder Evaluation to achieve a Best Value recommendation and with the veteran's preference is the lowest responsive, responsible, best value Bidder, the Owner will award the contract to the Qualified Disabled Veteran bidder. A determination as to whether the requirements of the bid solicitation have been met will be based solely on the Owner's and Professional's evaluation of the Bid Summary, Bid Attachments, Bidder-provided documents, and interview.
- 22.4 For the purpose of evaluating and determining the low responsive bid, 10% of the lowest responsive bid (the bid that would otherwise receive the contract award if the preference were not being considered) will be deducted from all QDV bids. If the low responsive QDV bid, less the 10% preference, is less than the lowest responsive bid, then the QDV bid will be declared the official low responsive bid. The original QDV bid amount will be the basis of the contract award.

Example:

| | |
|---|----------------------------------|
| Lowest Responsive Bid | \$100,000 |
| Lowest Responsive QDV Bid | \$109,000 |
| Preference (10% of the Lowest Responsive Bid) | \$ 10,000 |
| Lowest Responsive QDV Bid Less Preference | \$ 99,000 (\$109,000 - \$10,000) |
| Official Low Responsive Bid | \$109,000 |

- 22.5 The Apparent Low Bidders will be evaluated for responsiveness and responsibility based on the following:

- Compliance with the bid specifications and requirements.
- The Bidder's financial resources.
- The Bidder's technical capabilities.
- The Bidder's technical experience.
- The Bidder's past performance.
- The Bidder's insurance and bonding capacity.
- The Bidder's business integrity.

Some qualitative components that may be evaluated are:

- Technical approach.
- Quality of proposed personnel.
- Management plans.
- Past performance of any nominated asbestos abatement subcontractor(s).

- 22.6 For contracts under \$250,000, best value will primarily be based on the lowest responsive and responsible bid.

23. CONTRACT TIME; LIQUIDATED DAMAGES: Work of all trades as specified in the Contract Documents must be completed by 22 Weeks (154 days) from the Notice-to-Proceed except for minor replacement, correction, or adjustment items which do not interfere with the complete operation and utilization of all parts of the Contract Work. This Contract Time is of the essence and liquidated damages for each Calendar Day that expires after this Substantial Completion of the entire Work must be in the amount of \$500.00. Liquidated damages are not a penalty, are cumulative and represent a reasonable estimate of the Owner's extra costs and damages, which are difficult to estimate with accuracy in advance.

24. MOBILIZATION: If used in the Specifications/Bid schedule, all the up-front costs incurred by the Contractor must be covered by the mobilization. The costs to establish temporary site offices, to obtain required permits for commencing the Work and for bonds and insurance premiums are examples of costs to the Contractor that are covered by mobilization pay item. This cost must not exceed four percent (4%) of the Base Bid, unless otherwise expressly provided in the Bidding Documents.

25. SOIL EROSION AND SEDIMENTATION CONTROL: All Work under this Contract must meet the storm water management requirements of the Project and comply with the applicable Soil Erosion and Sedimentation Control (SESC) rules and regulations and specific provisions for same within the Contract Documents. SESC measures will be monitored and enforced by the State Facilities Administration, or another authorized enforcing agency if so delegated, through the review of the Contractor's implementation plans and site inspections. State Facilities Administration or the Professional will notify the Contractor in writing of any violation(s) of the applicable SESC statutes and/or the corrective action(s) undertaken by the Owner and may issue stop work orders. State Facilities Administration has the right to assess a fine to the Contractor for noncompliance with the provisions of the Contract Documents and/or SESC regulations applicable to this Work and fines must be in addition to any other remediation costs or liquidated damages applicable to the Project and may exceed the value of the Contract.

26. PREVAILING WAGE: The Bidding Documents include either the attached Appendix V of prevailing rates of wages and fringe benefits for all classes of Construction Mechanics called for in the Bid and resulting Contract, if any, or the attached current prevailing wage determination issued by the U.S. Department of Labor, as applicable depending on the funding source(s).

To the extent 2023 PA 10, as amended, MCL 408.1101 et seq. is applicable, the bid response for a state project must include a copy of the state project registration for the Contractor and for each Subcontractor of the Contractor that has been selected at the time the Contractor submits the Bid.

END OF SECTION 00100

SECTION 00120 SUPPLEMENTARY INSTRUCTIONS

The provisions of this Section amend or supplement Section 00100 Instructions to Bidders and those other provisions of the Bidding Requirements that are indicated below. All other Bidding Requirements that are not so amended or supplemented remain in full force and effect.

END OF SECTION 00120

SECTION 00200 INFORMATION FOR BIDDERS

1. UNDERGROUND UTILITIES

Information or data about physical conditions of existing Underground Utilities, which have been used by the Professional in preparing the Bidding Documents, is shown, or indicated in the Drawings and technical Specifications and those Underground Utility drawings itemized immediately below.

2. PERMITS, APPROVALS, LICENSES AND FEES

- 2.1 If the Owner has secured or will secure any permits, approvals and licenses and has paid or will pay any associated charges and fees, any such permits, approvals and licenses are itemized in this paragraph:
- 2.2 If any permits, approvals, and licenses itemized above have been obtained by the Owner and the fees have been paid, copies of those permits, approvals, licenses, and corresponding fee receipts, are attached to this Section 00200 Information for Bidders.

Except for any permits, approvals, licenses, and fees identified above, the Contractor shall be responsible for all permits, approvals, licenses, and fees applicable to Work.

3. SEQUENCING REQUIREMENTS

Refer to the technical Specifications, including, but not limited to the General Requirements, for information, data, and criteria on sequences of Work restraints, construction, and maintenance of service to existing facilities, which, if provided, must govern the selection of Work sequences. Each Bidder must be responsible for any conclusions or interpretations the Bidder makes related to the selection of sequences and Means and Methods, based on the technical data made available, and/or those additional investigations or studies made or obtained by that Bidder.

4. SUBSURFACE CONDITIONS

In preparing the bidding documents, the PSC used the reports of explorations and tests of subsurface conditions itemized immediately below.

- 4.1 Information or data contained in those reports that may be properly considered Authorized Technical Data concerning subsurface conditions include (NOTE: All other information or data excluded from the list below represent Non-Technical Information or Data, interpretations, or opinions):
- 4.2 In preparing the bidding documents, the PSC has not used the following reports of explorations and tests of subsurface conditions itemized immediately below.

5. OTHER PHYSICAL CONDITIONS

- 5.1 The Drawings and technical Specifications and those drawings itemized immediately below contain information or data that have been used in the preparation of the Bidding Documents, and that may be properly considered Authorized Technical Data concerning physical conditions of existing surface and subsurface facilities.
- 5.2 The reference documents itemized immediately below have not been used in the preparation of the Bidding Documents and are available for review or purchase. Information and data contained in those reference documents, including, but not limited to dimensions, locations and conditions of existing surface and subsurface structures, roadways, piping, raceways, equipment, etc. may not accurately or reliably reflect actual conditions. Neither the Owner nor Professional warrants that this list identifies all existing relevant documents.

END OF SECTION 00200

SECTION 00700 GENERAL CONDITIONS

1. **Interpretations:** Any requests for clarifications or interpretations of the Contract Documents must be in writing to the Professional, who will issue written clarifications or interpretations as appropriate. If the Contractor believes that such clarification or interpretation justifies an adjustment to the Contract Price/Time, the Contractor must promptly notify the Professional in writing before proceeding with the Work Involved.
- 1.1 **Standards:** The Contract Documents describe the entire Work. The provisions of the Contract Documents must govern over any standard specifications, manual or code of any technical society, organization, or association but, if lower than the standards set by any Law applicable to the Work or the Project, the higher standards must govern. The Contractor's responsibilities extend to cover Subcontractors and Suppliers if liable as a result of their actions or obligations.
- 1.2 **Contract Time Computation:** The time to complete the Work must be made in Calendar Days and must include both the first and last day. The first day is established by the Notice-to-Proceed.
- 1.3 **Technical Specifications and Priority:** The following applies whenever priority is called for in Contract Documents: specifications must govern Drawings; figured dimensions must govern scaled dimensions; detail drawings must govern general drawings; Drawings must govern Submittals.
- 1.4 **Indemnification:** The Contractor is required to defend, indemnify and hold harmless the Owner and the Professional, their employees, agents, servants, and representatives from and against all claims, suits, demands, actions of whatever type and nature and all judgments, costs, losses and damages, whether direct, indirect or consequential including, but not limited to, charges of architects, engineers, attorneys and others and all court, hearing and any other dispute resolution costs arising from:
- any patent or copyright infringement by the Contractor.
 - any damage to the premises or adjacent lands, areas, properties, facilities, rights-of-way, and easements, including loss of use to the business and property of others as a result of Contractor's operations.
 - any bodily injury, sickness, disease or death, or injury to or destruction of property, including loss of use due to or related to the Work and caused in whole or in part by the Contractor or Subcontractor or Supplier's negligence, omissions, or failure to maintain the required insurance and coverage and,
 - a failure by the Contractor to appropriately handle Hazardous Materials for the Work or the Contractor's operations in compliance with the Owner requirements and/or applicable Laws and regulations.

The indemnification obligations are not affected by the limitation on the amount and types of damages, compensation or benefits payable by or for the Contractor or Subcontractor or Supplier under worker's or workman's compensation acts, disability benefit acts or other employee benefit acts.

- 1.5 **Contract Documents Ownership:** The State is the owner of the Contract Documents. The Contractor, Subcontractor or Supplier must not reuse any of the documents on any other Project without prior consent of the State and Professional. The Professional will furnish on behalf of the Owner at no cost to the Contractor, one (1) electronic copy of the Drawings and Project Manual. If the **Contractor**, or the Contractor's Subcontractors or Suppliers request hard copy sets, reproduction of these documents will be the responsibility of the **Contractor**.

2. GENERAL PROVISIONS

- 2.1 **Owner:** The Project Director and/or Owner Field Representative will represent the Owner. Neither the Project Director nor the Owner Field Representative has the authority to interpret the requirements of the Contract Documents or to authorize any changes in the Work or any adjustment in Contract Price/Time. The State will provide the necessary easements for permanent structure and permanent changes in existing lands, areas, properties, and facilities. However, the Contractor must obtain, at no increase in Contract Price/Time, permits for any other lands, areas, properties, facilities, rights-of-way, and easements required by the Contractor for temporary facilities, storage, disposal of soil or waste material or any other purpose. The Contractor must submit copies of the permits and written agreements to the Owner. The Contractor must engage a registered land surveyor to establish the necessary reference points and/or base lines for construction and must be responsible for protecting them including benchmarks and Project elevations.
- 2.2 **Professional:** Acting as the Owner's representative during the Contract Time period, the Professional will endeavor to guard the Owner from Defective work and to keep the Owner informed of the progress of the Work. Unless delegated by specific written notice from the Owner, the Professional and the Professional's representatives do not have the authority to authorize any changes in the Work or any adjustment in Contract Price/Time. The On-site Inspections by the Owner Field Representative and/or the Professional do not relieve the Contractor from its obligation to provide the Work in accordance with the Contract Documents or represent acceptance of Defective Work.
- 2.3 **Contractor:** The Contractor must manage, supervise, and direct the Work competently, applying the management, supervision, skills, expertise, scheduling, coordination, and attention necessary to provide the Work in accordance with the Contract Documents with a minimum disturbance to or interference to the business operations on site or adjacent properties. The Contractor must assign and maintain a competent full-time **superintendent** on the Work, as its representative, at all times while Work is being done on site and must not be replaced without the Owner's consent. The DTMB Superintendent Designation [form](#) must be completed by the Contractor and submitted before beginning any work. The Contractor shall enforce good order among its employees and shall not employ on the work any disorderly, intemperate, or unfit persons, or not skilled in the work assigned to them. The Contractor is solely responsible for his Means and Methods, safety precautions and programs related to safety, the Contractor's failure to execute the Work in accordance with the Contract Documents and any act of omissions by the Contractor, Subcontractor or Supplier. The Contractor must **compare Contract Documents for conflicts**, unworkable or unsafe specified Means and Methods and verify against manufacturer's recommendations for installations and handling and must notify the Professional in writing of the discovery of any such conflicts or errors. The Contractor is required to furnish certifications that lines and grades for all concrete work were checked before and after placing concrete, and that final grades are as required by the Contractor Documents. Wherever required, the Contractor must be responsible for all cutting, fitting, drilling, fixing-up, and patching of concrete, masonry, gypsum board, piping and other materials that may be necessary to make in-place Work and dependent Work fit together properly. The Contractor must restore to pre-existing conditions all walks, roadways, paved or landscaped areas and other real and personal property not designated for alteration by the Contract Documents. The Contractor must maintain at the site one copy of safety data sheets (SDS) and one copy of all **as built/Record Documents** in good order and annotated in a neat and legible manner to show:
- all revisions made,
 - dimensions noted during the furnishing and performance of the Work, and
 - all deviations between the as-built installation and the Contract Documents, all approved Submittals and all clarifications and interpretations.
- The Contractor must maintain and furnish promptly to the Owner and the Professional upon their request **daily field reports and photos** recording the on-site labor force and equipment (Contractor and Subcontractors); materials/equipment received; visits by Suppliers; significant in-progress and completed trade Work within major areas; and other pertinent information. The Contractor is obligated to act to prevent threatened damage, death, injury, or loss without any special instruction in **emergencies** and must give the Owner prompt written notice of any changes in Work resulting from the action taken for review and approval.
- 2.4 **Subcontractors and Suppliers:** The Owner assumes no contractual obligations to anyone other than the Contractor. All trade construction Drawings must be field coordinated before fabrication and/or installation. The Owner reserves the right to reject or revoke, for its convenience, any approved Subcontractor/Supplier. For any projects with asbestos abatement, Contractor must comply with MCL 338.3375(4) and complete the Asbestos Abatement Attestation. Work performed by any Subcontractor or Supplier must be through an appropriate written agreement that:
- expressly binds the Subcontractor/Supplier to the requirements of the Contract Documents,
 - requires such Subcontractor or Supplier to assume toward the Contractor all the obligations that the Contractor assumes toward the Owner and the Professional, and
 - contains the waiver of rights and dispute resolution provisions.

2.5 Prevailing Wages and Access to Payroll Records:

2.5.1 Prevailing Wages:

To the extent applicable, Contractor will comply with federal and state prevailing wage requirements. The wage and classification schedules applicable for this project/location are included in Appendix V.

Federal Prevailing Wages - If a project is funded in whole or in part by federal dollars, the Contractor and all Subcontractors must comply with the most recent version of Federal Provisions Addendum and all Laws pertaining to occupational classifications and wage requirements as follows:

1. FEDERAL PROVISIONS ADDENDUM

- a. The most current version of Federal Provisions Addendum shall apply to this contract and is included at the end of this section and/or Appendix V.

2. DAVIS BACON ACT WAGE AND CLASSIFICATIONS

- a. If applicable, the Contractor (and its Subcontractors) for prime construction contracts in excess of \$2,000 must comply with the Davis-Bacon Act ([40 USC 3141-3148](#)) as supplemented by Department of Labor regulations ([29 CFR Part 5](#), "Labor Standards Provisions Applicable to Contracts Covering Federally Financed and Assisted Construction").
- b. The Contractor (and its Subcontractors) shall pay all mechanics and laborers employed directly on the site of the work, unconditionally and at least once a week, and without subsequent deduction or rebate on any account, the full amounts accrued at time of payment, computed at wage rates not less than those stated in the advertised specifications, regardless of any contractual relationship which may be alleged to exist between the Contractor or subcontractor and the laborers and mechanics.
- c. The Contractor will post the scale of wages to be paid in a prominent and easily accessible place at the site of the work.
- d. There may be withheld from the Contractor so much of accrued payments as the contracting officer considers necessary to pay to laborers and mechanics employed by the Contractor or any Subcontractor on the work the difference between the rates of wages required by the Contract to be paid laborers and mechanics on the work and the rates of wages received by the laborers and mechanics and not refunded to the Contractor or Subcontractors or their agents.
- e. The Contractor shall maintain payrolls and basic records relating thereto for a period of three (3) years after the project; contractor shall submit Certified Payroll Reports using US Department of Labor Wage and Hour Division Form WH-347 for each weekly payroll to support and document compliance with the Davis Bacon Wage rates.
- f. Davis Bacon wage and classification schedules applicable for this project/location are included at the end of this section and/or Appendix V.

State Prevailing Wages -The following provisions apply when 2023 PA 10, as amended, MCL 408.1101 et seq. applies.

Prevailing Wage and Fringe Benefits--The rates of wages and fringe benefits to be paid to each class of Construction Mechanic by DB Entity and Subcontractors must not be less than the wage and fringe benefit rates prevailing in the locality in which the work is performed.

Nondiscrimination, Nonretaliation- Contractor or a Subcontractor shall not discharge, discipline, retaliate against, or otherwise discriminate against a Construction Mechanic, or threaten to do any of these things, because the Construction Mechanic reported or was about to report a violation or suspected violation of the act.

Construction Mechanics under this Contract are intended beneficiaries of the contractual prevailing wage, fringe benefit, and nondiscrimination nonretaliation requirements of the Contract. Any such Construction Mechanic aggrieved by failure of a contractor or subcontractor to pay prevailing wages or benefits as specified in the Contract, or by violation of section 7 of 2023 PA 10, in addition to any other remedies provided by law, may bring an action in a court of competent jurisdiction against such contractor or subcontractor for damages or injunctive relief and may be awarded reinstatement or other appropriate relief, and all damages sustained, together with actual costs and attorney fees at trial and on appeal.

Contractor and Subcontractors shall keep posted on the construction site, in a conspicuous place, a copy of all prevailing wage and fringe benefit rates prescribed in this Contract and shall keep an accurate record showing the name and occupation of and the actual wages and benefits paid to each Construction Mechanic employed by it in connection with the Contract. This record shall be available for reasonable inspection by the State.

Contractor must immediately notify the Owner if Contractor's state project registration or a Subcontractor's state project registration is no longer valid (i.e. suspended, revoked or not renewed) at any time during the term of the Contract.

Contractor is to submit certified payrolls, including contractor and subcontractor, not later than 10-days after the end of a pay period to the Department of Labor and Economic Opportunity database via the internet through the Online Certified Payroll Submission process the Contractor signed up for to receive their State Project Registration, 2023 PA 10 as amended, MCL 408.1122. State certified payroll is not to be submitted to DTMB at any time.

- 2.5.2 Access to Payroll Records:** The Contractor and its Subcontractors must maintain and keep, in accordance with generally accepted accounting principles, records pertaining to the bidding, award and performance of the Work, including, but not limited to certified payroll, employment records and all data used in estimating the Contractor's prices for the Bid, Change Order, proposal or claim. The Owner or its representative must have access to those records, must have the right to interview the Contractor's employees and must be provided with appropriate facilities for the purpose of inspection, audit/review and copying for five years after final payment, termination, or date of final resolution of any dispute, litigation, audit exception or appeal. The certified payroll and other employment records of workers assigned to the site must contain the name and address of each worker, correct wage classification, rate of pay, daily and weekly number of hours worked, deduction made, and actual wages paid. The Contractor must maintain records that show: (a) the anticipated costs or actual costs incurred in providing such benefits, (b) that commitment to provide such benefits is enforceable, and (c) that the plan or program is financially responsible and has been communicated in writing to the workers affected.
- 2.6 Asbestos Abatement Projects:** For projects with Asbestos Abatement, the Contractor must comply with PA 59 of 2024, MCL 338.3371 et seq. as applicable and with APPENDIX III – ASBESTOS ABATEMENT PROJECT PROCEDURES as part of and in conjunction with all other contract requirements.

3. Bonds and Insurance:

- 3.1** Both the Performance Bond and Payment Bond must remain in effect from the date of Contract Award until final completion of the Work or the end of Correction Period, whichever comes later. The surety bonds required for a Construction Contract will not be accepted by SFA unless the surety bonding company is listed in the current United States Government, Department of Treasury's, Listing of approved sureties (bonding/insurance companies), Department Circular 570. Copies of the current Circular listing may be obtained through the internet web site <https://www.fiscal.treasury.gov/fsreports/ref/suretyBnd/c570.htm>.

Insurers must have an "A-" A.M. Best Company Rating and a Class VII or better financial size category as shown in the most current A.M. Best Company ratings. Insurance must be provided by insurers authorized by the Department of Insurance and Financial Services (DIFS) to do business as an insurer in Michigan. The insurance company and must attach evidence of the authorization. These certificates must specify the Project File No., Project Title, and a description of the Project. The Contractor agrees that insurance coverage afforded under the policies as such coverage relate to the State under this Contract as determined by the Contractor will not be modified or canceled without at least thirty calendar days prior written notice to the State. The latest A.M. Best's Key Ratings Guide and the A.M. Best's Company Reports (which include the A.M. Best's Ratings) are found at: <http://www.ambest.com>. The Contractor must not perform any part of the Work unless the Contractor has all the required insurance in full force and effect.

- 3.2** The Contractor is required to provide proof of the minimum levels of insurance coverage as indicated below. The purpose of this coverage must be to protect the State from claims which may arise out of or result from the Contractor's performance of services under the terms of this Contract, whether such services are performed by the Contractor, or by any subcontractor, or by anyone directly or indirectly employed by any of them, or by anyone for whose acts they may be liable.

The Contractor waives all rights against the State for recovery of damages to the extent these damages are covered by the insurance policies the Contractor is required to maintain pursuant to this Contract. The Contractor also agrees to provide evidence that all applicable insurance policies contain a waiver of subrogation by the insurance company.

All insurance coverages provided relative to this Contract is PRIMARY and NON-CONTRIBUTING to any comparable liability insurance (including self-insurances) carried by the State.

The Insurance must be written for not less than any minimum coverage herein specified or required by law, whichever is greater. All deductible amounts for any of the required policies are subject to approval by the State.

The State reserves the right to reject insurance written by an insurer the State deems unacceptable.

BEFORE THE CONTRACT IS SIGNED BY BOTH PARTIES, THE CONTRACTOR MUST FURNISH TO THE DIRECTOR-DCD CERTIFICATE(S) OF INSURANCE VERIFYING INSURANCE COVERAGE. THE CERTIFICATE MUST BE ON THE STANDARD "ACCORD" FORM. THE CONTRACT NUMBER MUST BE SHOWN ON THE CERTIFICATE OF INSURANCE TO ASSURE CORRECT FILING. All such Certificate(s) are to be prepared by the Insurance Provider and not by the Contractor. All

such Certificate(s) must contain a provision indicating that coverages afforded under the policies WILL NOT BE CANCELLED, MATERIALLY CHANGED, OR NOT RENEWED without THIRTY days prior written notice, except for 10 days for non-payment of premium, having been given to the Director-DCD. Such NOTICE must include the CONTRACT NUMBER affected and be mailed to the Project Director.

The Contractor is required to provide the type and amount of insurance below:

- (a) Commercial General Liability Insurance with a limit of not less than \$1,000,000 each occurrence. If such CGL insurance contains a general aggregate limit, it must apply separately to this project.

The Contractor must list the State, its departments, divisions, agencies, offices, commissions, officers, employees, and agents as ADDITIONAL INSUREDS on the Commercial General Liability policy.

- (b) Vehicle Liability Insurance for bodily injury and property damage as required by law on any auto including owned, hired, and non-owned vehicles used in the Contractor's business.

The Contractor must list the State, its departments, divisions, agencies, offices, commissions, officers, employers, and agents as ADDITIONAL INSUREDS on the vehicle liability policy.

- (c) Worker's disability compensation, disability benefit or other similar employee benefit act with minimum statutory limits.

NOTE:

- (i) If coverage is provided by a State fund or if Contractor has qualified as a self-insurer, separate certification must be furnished that coverage is in the state fund or that Contractor has approval to be a self-insurer.
(ii) Any citing of a policy of insurance must include a listing of the States where that policy's coverage is applicable; and
(iii) This provision must not be applicable where prohibited or limited by Michigan law.

- (d) Employer's Liability Insurance with the following minimum limits:

\$1,000,000 each accident

\$1,000,000 each employee by disease

\$1,000,000 aggregate disease

- (e) Pollution Liability Insurance in the amounts of not less than \$1,000,000 per occurrence is required.

3.3 **Liability Insurance:** Liability insurance must be endorsed to list as additional insureds the Professional's consultants and agents. Worker's Compensation, Employer's Liability Insurance and all other liability insurance policies must be endorsed to include a waiver of rights to recover from the Owner, Professional and the other additional insureds. The Contractor's liability insurance must remain in effect through the Correction Period and through any special correction periods. For any employee of the Contractor who is resident of and hired in Michigan, the Contractor must have insurance for benefits payable under Michigan's Worker's Compensation Law. For any other employee protected by Worker's Compensation Laws of any other state, the Contractor must have insurance or participate in a mandatory state fund, where applicable, to cover the benefits payable to any such employee. These requirements must not be construed to limit the liability of the Contractor or its insurers. The Owner does not represent that the specified coverage or limits of insurance are sufficient to protect the Contractor's interests or liabilities.

3.4 **Builder's Risk Insurance:** Unless indicated otherwise in the bid document, the Contractor must purchase and maintain property insurance for 100% of the replacement cost value of the insurable Work (minimum amount to be the contract award amount) while in the course of construction, including foundations, additions, attachments, and all fixtures, machinery and equipment belonging to and constituting a permanent part of the building structures. The property insurance must cover temporary structures, materials and supplies to be used in completing the Work, whether stored offsite, in-transit, or on the building site premises. The property insurance insures the interests of the Owner, Contractor and all Subcontractors and Suppliers at any tier as their interest may appear and name the Owner as Loss Payee. The property insurance insures against "all risk" of physical loss or damage to the extent usually provided in policy forms of insurers authorized to transact this insurance in Michigan. A copy of the master insurance policy must be available for review by the State, upon request. The deductible amount and the payment of any deductible is the responsibility of the **Contractor**.

3.5 The Owner and Contractor intend that the required policies of property insurance must protect all the parties insured and provide primary coverage for all losses and damages caused by the perils covered. Accordingly, to the extent that the insurance company pays claims, the Owner and the Contractor and its Subcontractors/Suppliers waive all rights against each other for any such losses and damages and waive all such rights against the Professional and all other persons named as insureds or additional insureds.

4. Prosecutions; Substantial Completion:

- 4.1 The Contractor must not start the Work at the site before the first day established by the Notice to Proceed and/or before all insurance is in effect. A pre-construction conference will be held with the Contractor to review its Progress Schedule, qualifications of its key personnel, its proposed access to the site, traffic and parking, procedures for submittal, change orders, etc., and to exchange emergency contact information. The Contractor must use its accepted Progress Schedule when making proposals or claims for adjustment in Contract Time/Price.
- 4.2 Except in an Emergency, all Work at the site must take place during normal working hours; 6:00 AM to 6:00 PM, during Business Days and in accordance with the special working conditions for the Agency. If the Contract Documents allow work outside the normal hours, the Contractor must provide a written notice to the Owner twenty-four hours before performing such Work and must reimburse the Owner any related increase in the costs incurred by the Owner such as overtime charges of the Professional and payments for custodial and security personnel.
- 4.3 If, upon inspection and completion of all pre-requisite testing of the Work, the Contractor considers that a portion of the work or all the Work is substantially completed, it must provide a list of items to be corrected or completed to the Owner and the Professional for joint inspection. Within ten Calendar Days of this joint inspection, the Professional will deliver to the Owner and Contractor a list of incomplete/Defective work or a Certificate of Substantial Completion with a Punch List. The certificate must:
- fix a reasonable date of Substantial Completion,
 - fix a date for completion of the Punch List, and
 - recommend the division of responsibilities between the Owner and Contractor for utilities, security, safety, insurance, maintenance, etc.

Upon issuing the Certificate of Substantial Completion, the Owner will pay for the completed Work subject to (a) withholding of two hundred percent of the value of any uncompleted Work, as determined by the Professional, and (b) any other deductions as the Professional may recommend or may withhold to cover Defective work, liquidated damages and the fair value of any other items entitling the Owner to a withholding. Prerequisites for Substantial Completion, over and above the extent of Work completion required, include (a) receipt by the **Owner** of operating and maintenance documentation, (b) all systems have been successfully tested and demonstrated by the **Contractor** for their intended use, and (c) the **Owner** having received all required certifications and/or occupancy approvals from the State and those Political Subdivisions having jurisdiction over the Work. Receipt of all certifications and/or occupancy approvals from those Political Subdivisions with jurisdiction in and of itself does not necessarily connote Substantial Completion. The Contractor must provide all related operating and maintenance (O&M) documentation to the Owner before training if training is required and not later than Substantial Completion otherwise. The Contractor must give the Owner the final O&M documentation (with revisions made after Substantial Completion) before the request for final payment.

- 4.4 The Owner may decide to use, at its sole option, any functioning portion of the Work and will inform the Contractor in writing of the decision. The portion of Work to be used must be jointly inspected to determine the extent of completion if it has not undergone the inspection for Substantial Completion. The Professional must prepare a list of items to be corrected/completed and the Owner will allow the Contractor reasonable access to correct/complete the listed items and finish other work.

5. Warranty; Tests, Inspections and Approvals; Corrections of Work:

- 5.1 **Warranty:** The Contractor must furnish the State with a written guarantee to remedy any defects due to faulty materials or labor which appear in the Work within one year from the date of final acceptance by the State. This warranty excludes defect or damage caused by (a) abuse, modification by others, insufficient or improper operation or maintenance, or (b) normal wear and tear under normal usage. Manufacturer warranties for materials and equipment received by the Contractor must be assigned and promptly delivered to the Owner at Substantial Completion. The warranties period starts from the date of the substantial completion and must be in full force and effect for the entire duration of the Correction Period.

Roof Warranty: For roofing systems, the following warranties are required as minimum:

- A two-year contractor's warranty against any defects due to faulty materials or labor.
- A fifteen-year manufacturer's total system warranty; and
- A twenty-year membrane/shingles/tiles warranty.

- 5.2 **Tests, Inspections and Approvals:** The Owner will perform or retain a professional/agency to perform inspections, tests or approvals for those materials required to meet quality control standards specified in the Contract Documents except for those inspections, tests or approvals specifically designated to the Contractor in the Contract Documents. However, the Contractor must assume full responsibility for any testing, inspection, or approval.

- required to meet code requirements, as promulgated by code inspecting authorities.
- required by Law.
- indicated or required by the Contract Documents as designated to the Contractor.

- (d) required for the Professional's acceptance of a Supplier, materials or equipment or mix designs submitted for prior approval by the Contractor; or
- (e) Defective work, including an appropriate portion of the Delay and costs occasioned by discovery of Defective work. The Contractor must (a) pay all related costs; (b) schedule related activities; and (c) secure and furnish to the Professional the required certificates of inspection, testing or approval. The Contractor must provide proper and safe access to the site for inspection, testing or approval. The Contractor must provide the Professional a timely notice whenever any Work is ready for inspection, testing or approval. If the Contractor covers any Work without proper approval by the Professional as required by the Contract Documents, the Contractor must, at its own expense, uncover, expose, or otherwise make available, when requested by the Professional or Owner, for testing, inspection, or approval of the covered Work.
- 5.3 Correction of Work:** If any testing, inspection, or approval reveals Defective Work and the Work is rejected by the Professional, the Contractor, at its sole expense, must promptly, as directed, correct, or remove the Defective Work from the site and replace it with non-Defective Work within the Correction Period. The Contractor must bear responsibility for its proportionate share of the Delay and costs resulting from the correction and/or removal and replacement of Defective Work. If the Contractor, within reasonable and agreed upon time after receipt of written notice, (a) fails to correct Defective Work or remove and replace rejected Work, or (b) fails to correct or complete items on any Punch List, or (c) fails to perform Work in accordance with the Contract Documents, or (d) fails to comply with any other provision of the Contract Documents, the Owner, directly or through others, after seven Calendar Days from the date of the written notice to the Contractor, may correct and remedy the Defective Work. To the extent necessary to correct and remedy such Defective Work, the Owner must be allowed to exclude the Contractor from all or part of the site; take possession of all or part of the Work and stop related operations of the Contractor; take possession of the Contractor's tools, plant and office and construction equipment at the site; and incorporate into the Work materials and equipment for which the Owner has paid the Contractor. The Contractor must allow the Owner and the Professional easy access to the site to correct such Defective Work. The Owner must be entitled to an appropriate decrease in Contract Price for all claims, costs, losses, damages, and Delay incurred or sustained by the Owner which are attributable to the Contractor. Such costs may include, but not limited to, costs of correction or removal and replacement of Defective Work, costs of repair and replacement of other work destroyed or damaged by the action and related charges of the Professional. If the discovery of the Defective Work takes place after final payment and the Contractor fails to correct and pay the Owner any of these costs, the Owner must demand due performance under the Performance Bond. Until the period of limitation provided by Michigan Law, the Contractor must promptly, and upon receipt of written notice from the Owner, correct Defective Work. In the event of an Emergency or unacceptable risk of loss or damage or if appropriate under the circumstances, the Owner, directly or through others under contract with the Owner, may correct or remove and replace the Defective Work. The specified correction of Work requirements has no limitation on the rights of the Owner to have Defective Work corrected or removed and replaced, if rejected, except as otherwise provided by the Michigan Law.
- 5.4 Special Correction Period Requirements:** Whenever the Owner undertakes any portion of the Work because the Contractor's act or omission Delays completion of the Work or it is eligible for Partial Use, the warranties for all materials and equipment incorporated into that portion of the Work must remain in full force and effect between the start of such Partial Use and the date when the Correction Period starts. The Correction Period for any Defective Work that is corrected or rejected and replaced within the last three months of the Correction Period must be extended by an additional six months, starting on the date such Work was made non-Defective.
- 5.5 Special Maintenance Requirements:** If the Contract Documents specify that the entire Work, or a portion of the Work, upon reaching Substantial Completion, must not be placed in use by the Owner, the Contractor must maintain the Work, or specified part of the Work, in good order and proper working condition and must take all other actions necessary for its protection between the certified date of Substantial Completion and the date when the Work, or designated part of the Work, is placed in use. If no separate price for such special maintenance period was requested and made part of the Contract Documents, the Owner will amend the Contract Documents to appropriately increase the Contract Price.
- 6. Changes:**
- 6.1 Changes in the Work:** The Owner may, at any time, without notice to sureties, make any changes bilaterally or unilaterally, by a written Change Order, in the Work within the general scope of the Contract, including but not limited to changes in the Specifications, materials, or Contract Time. In a bilateral change order, the Owner may direct the Professional to prepare a Bulletin describing the change being considered. Upon receiving the Bulletin, the Contractor establishes the cost and returns it to the Professional for review within 15 calendar days. The Contractor's proposal must be irrevocable for 60 Calendar Days after it is submitted to the Professional. If the Professional recommends acceptance of the Bulletin and the Owner agrees with the changes, the Owner issues a written bilateral Contract Change Order to amend the Contract Documents. However, the Owner may issue a unilateral Change Order if the Owner and Contractor are unable to agree on the adjustment in Contract Price or Time. If the Contractor disagrees with such unilateral Contract Change Order, the Contractor must complete the Work and may deliver notice of a claim in accordance with the claim submittal process.
- 6.2 Differing Site Condition:** The Owner does not warrant that any technical data, including the Project reference points, provided by the Owner is necessarily sufficient and complete for the purpose of selecting Means and Methods, initiating, maintaining, and supervising safety precautions and programs or discharging any other obligation assumed by the Contractor under the Contract

Documents. If different or unknown site conditions are discovered, the Contractor must notify the Owner in writing before the conditions are disturbed or before proceeding with the affected Work. Upon review, if the Owner decides to agree with the differing site conditions, with the Professional's advice, the Owner may issue a written Contract Change Order to amend the Contract Price or Time through the Bulletin authorization process. If the Owner decides to disagree with the Contractor and the Contractor disagrees with the Owner's decision, the Contractor must complete the Work and may deliver notice of a claim in accordance with the claim submittal process. No proposal or claim by the Contractor due to differing site conditions will be allowed (a) if the Contractor knew of their existence before submitting its Bid or if those conditions could have been discovered by any reasonable examinations for which the Contractor, as Bidder, was made responsible under the Bidding Requirements and/or (b) unless the Contractor's written notice is provided within not more than 21 days after the contractor first recognizes the condition giving rise to the proposal or claim and gives the Owner adequate opportunity to investigate the asserted differing site conditions. A full and detailed breakdown of cost and time requested, with supporting documentation, if not provided with the initial notice shall be delivered to the Professional and Owner within 15 days of the notice, unless otherwise agreed in writing, by the Owner prior to expiration of such time.

6.3 Responsibilities for Underground Utilities: The Contractor must comply with the 2013 PA 174, as amended, MCL 460.721 et seq., and all other Laws concerning Underground Utilities. Before performing site Work, all Underground Utilities, lines, and cables (public and private) must be located and marked. The Contractor must notify MISS DIG to locate and mark utilities on properties that are not State properties. In addition, the Contractor must be responsible for immediately notifying the Owner of any contact with or damage to Underground Utilities, and for the safety, protection of and repairing any damage done to any Work, surface, and subsurface facilities. If the Contractor encounters Underground Utilities that inaccurately located by the Contract Documents or not previously located/located, which could not be reasonably have been seen, the Owner may issue a written Contract Change Order to amend the Contract Price or Time through the Bulletin authorization process.

6.4 Hazardous Material Conditions: If the Contractor encounters material reasonably believed to be Hazardous Material, which was not described in the Drawings and/or Specifications and was not generated or brought to the site by the Contractor, the Contractor shall immediately stop all affected work, give written notice to the Owner of the conditions encountered, and take appropriate health and safety precautions in accordance with all federal, state, and local laws. Upon receipt of the notice, the Owner will investigate the conditions and (a) may stop the Work and terminate the affected Work or the Contract for convenience; (b) may contract others to have the Hazardous Material removed or rendered harmless or (c) issue a written Contract Change Order to amend the Contract Price/Time through the Bulletin authorization process. If the Hazardous Material is brought to site by the Contractor or as a result in whole or in part from any of its violation of any Law covering the use, handling, storage, disposal of, processing, transport and transfer or from any other act or omission within its control, the Contractor is responsible for the Delay and costs to clean up the site, remove and render harmless the Hazardous Material to the satisfaction of the Owner, State and all Political Subdivisions with jurisdiction.

6.5 Incidents with Archaeological Features: The Contractor must immediately notify the Owner in writing of any Archeological Feature deposits encountered at the site and must protect the deposits in a satisfactory manner. If the Contractor encounters such features, which result in an anticipated change to the Contract Price/Time, the Owner may issue a written Contract Change Order through the Bulletin authorization process.

6.6 Unit Price Work: Quantities as listed have been carefully estimated but are not guaranteed. The Owner reserves the right to increase or decrease the quantities of the Work to be performed at the Unit Price by amounts up to 20 percent of the listed estimated quantities. For Unit Price Work, the Contractor must promptly inform the Professional in writing if actual quantities differ from the estimated quantities for any item. For quantities over 120% or below 80% of the estimated quantity, the Owner may negotiate a Unit Price with the Contractor, or direct a unilateral change, or bid that Work under separate contract. Any adjusted Unit Price agreed upon by the Owner will only apply to the actual quantities above 120% or below 80% of the estimated quantity. No adjustment due to quantity variations must be allowed (a) unless the Contractor met the notice requirements, or (b) if any Unit Price increase results in whole or in part from any act or omission within the control of the Contractor (errors in the Contractor's Bid, unbalanced Unit Prices, etc.). If a dispute arises between the Owner and the Contractor on the adjusted Unit Price, the Contractor must carry on the Work with due diligence during the disputes/disagreements.

6.7 Cash Allowances; Provisionary Allowances: The Contractor must obtain the Professional's and Project Director's written acceptance before providing materials, equipment, or other items covered by Cash Allowance. Work authorized under any Provisionary Allowance may consist of (a) changes required by actual conditions, as determined by the **Professional**, and (b) any other Work authorized and completed under the pertinent provisions of the Contract Documents.

6.8 Changes in Contract Price:

6.8.1 The Contractor's proposals or claims for Work Involved must detail all affected items of Work, whether increased, revised, added, or deleted, and must be fully documented and itemized as to (a) individual adds and deducts in Work quantities and labor man-hours; (b) corresponding itemized cost of Work Involved; (c) materials and equipment cost including transportation, storage, and suppliers' field services; and (d) Fee.

- 6.8.1.1 No proposal or claim by the Contractor on account of any asserted change not issued as a Bulletin by the PSC or Owner, shall be allowed unless initiated by written notice of such proposal or claim to the Professional and Owner within 21 days after the occurrence of the event giving rise to the proposal or claim. A full and detailed breakdown of cost and time requested, with supporting documentation, if not provided with the initial notice shall be delivered to the Professional and Owner within 15 days of the notice, unless otherwise agreed in writing, by the Owner prior to expiration of such time.
- 6.8.2 For Contractor's proposals or claims for adjustments in Contract Price arising from Delays, the Contractor's estimates must be as comprehensive and detailed as may be appropriate to support the proposal or claim. Examples of related information include labor manpower levels, production data and Progress Schedule revision.
- 6.8.3 If the Contract Documents use lump sum or Unit Prices for the Work Involved, those prices must be used in estimating the price change. Otherwise, the Owner may direct the Contractor to proceed (a) on a negotiated lump sum; or (b) on an actual cost basis with or without a guaranteed maximum; or (c) through a unilateral Change Order on a lump sum basis or a not-to-exceed basis, based on the Professional's estimate of the anticipated Cost of the Work Involved and a fee. Items making-up the Cost of the Work Involved must be allowable to the extent (a) consistent with those prevailing in the Project locality, (b) necessary, reasonable, and clearly allocable to the Work Involved, and (c) limited to labor costs, subcontract costs, material and equipment costs, construction equipment costs and general conditions costs.
- 6.8.4 In estimating any additional cost by the Contractor or its Subcontractor, the rates for the craft labor man-hour used in estimating changes in Contract Price must not exceed the rates in Means Cost Data (Means) or other cost guide acceptable to the Owner. If the rates exceed the acceptable cost guides, the Contractor must provide proper justifications acceptable to the Professional and the Owner. The payroll costs may be used to quote a Bulletin. However, the payroll costs must include wages, labor burdens and a factor for field supplies and purchase costs (less market values if not consumed) of tools not owned by the workers. Labor burdens must be certified by an authorized financial representative of the Contractor and may include social security, unemployment, taxes, workers' compensation, health and retirement benefits, vacation, and holiday pay. The factor for field supplies and tools (individually valued at less than \$1,000.00) must not exceed 4% of the wages without burdens, unless detailed data, which supports higher costs, is provided. Rates for owned, rented, or leased construction equipment must be in accordance with the contract price rates. Otherwise, the appropriate hourly, daily, weekly, or monthly rates listed in Means must be used. However, if the total rental or lease cost of an item to the Project exceeds the reasonable purchase price of the rented or leased item, the Owner reserves the right to pay only the purchase price of the item and take title to the item. Operating cost must not exceed the hourly operating rate in Means and for multiple shifts, rates must not exceed the shift work adjustments recommended in the cost guide.
- 6.8.5 The cost of any Work Involved may include necessary general conditions costs to the extent those costs increase or decrease on account of, or are directly attributable to, the performance of the furnishing and/or performance of the additional Work Involved or are required due to an extension in Contract Times or Delays. Such costs may include payroll costs of personnel, temporary facilities at the site, liability insurance and bond premiums, Subcontractors, royalty payments and fees for permits and licenses and taxes on the Work Involved.
- 6.8.6 A contractor or subcontractor who performs the Work may charge a fee of up to 15% of the cost of Work involved for overhead and profit. Contractor may charge a mark-up fee of up to 5% of its Subcontractor's cost excluding fees if the Work is performed by the Subcontractor. If Work is to be performed by lower tier subcontractor(s), intermediate subcontractors and the Contractor must share a fee of up to 5% of the lowest tier subcontractor's cost excluding fees. The total mark-up fees for the Work must not exceed 20% of the lowest tier subcontractor's cost excluding fees. If the adjustment to the Contract Price incorporates a contractor reservation of rights to claim additional adjustments, the fees must be reduced by one-third. Contractor's administrative costs and home office overhead must be non-reimbursable expenses covered by the Fee for the Work.

6.9 Changes in Contract Time:

- 6.9.1 If a justified extension beyond the Contract Time is not reasonably anticipatable under the circumstances, the Owner may approve an extension to the Contract Time through the Bulletin authorization process at no additional cost to the Owner. Examples of events that may justify an extension in the Contract Time include acts of God; acts of the public enemy; fires; floods; and strikes.
- 6.9.2 If, at any time during the life of this Contract, the Contractor finds that for reasons beyond its control, it will be impossible to complete the Work on or before the Contract completion date, a written request for a change to the Contract extending the time of completion must be submitted. Such a request must set forth in precise detail the reasons believed to justify an extension and must be in such format as the State may require.
- 6.9.3 When submitting a quotation for a Contract change authorization for extra work or change in plans, the Contractor must include as part of the quotation, a statement requesting any extra time necessary to complete the related Work. Lack of such a statement will serve as notification that the extra time will not be required to complete the Contract work and will waive the right to a later claim. The Owner will not pay additional compensation to the Contractor for performing Contract Work during any extension period granted.

6.9.4 If the Progress Schedule and the funding allow for an early completion date, the Contractor may submit to the Owner for approval, a request to shorten the Contract Time. If approved by the Owner, the new Contract Time applies to the Project and liquidated damages, if any, will be assessed for any delays after the new completion date.

6.10 Price Reduction for Defective Cost or Pricing Data: Whenever the Contractor signs a proposal for a change in the Contract or claim settlement, the Contractor will be deemed to have certified on behalf of itself, Subcontractors and Suppliers, to its best knowledge and belief that the proposal and its contents (a) were made in good faith and are consistent with the facts and the provisions of the Contract; and (b) are current, complete, and accurate. If the Contract Price/Time is increased by any Change Order, claim or dispute settlement because the Contractor, Subcontractor or Supplier, at any tier, represented or furnished cost or pricing data of any kind that were false, contained math errors or were incomplete, the Contract Price must be correspondingly reduced by Change Order. If there is a good cause to doubt the Contractor's compliance with the Defective cost and pricing data requirements, the Owner must be entitled to make an appropriate withholding from any payment otherwise owed to the Contractor.

7. Payments:

7.1 **Schedule of Values:** The Schedule of Values must be approved by the Professional and accepted by the Owner and must divide the Work into pay items for significant Sections and areas, facilities, or structures, with subtotals for first tier Subcontractors. As required or as noted in Division 1, the accepted Schedule of Values must be supported by a more detailed breakdown allocating the pay items to the Progress Schedule Activities. It must tabulate labor costs, Subcontract costs and material and equipment costs. Labor costs must include appropriate sums for construction equipment costs, general conditions costs, administrative costs, and profit, unless separate pay items are itemized for those costs. The Schedule of Values must include two percent of the Contract Price for each of the following close-out pay items: (a) fire safety inspection, certificate of occupancy and other code approvals, as specified in the Contract Documents, (b) manufacturer warranties, finalized operating and maintenance documentation, Owner training documentation, and test and balance reports, and (c) finalized as built/Record Documents.

7.2 **Requests for Payment:** Not more than once every thirty Calendar Days, the Contractor may submit to the Professional a Request for Payment on the Owner's form signed by the Contractor certifying Work completed and enclosing all supporting documentation. A draft copy of the payment request must be submitted to the Owner Field Representative for review and comments. For projects under \$50,000, the Contractor may not submit more than two requests in addition to the final payment request. Each Request for Payment must certify that all monies owed by the Contractor to Subcontractors and Suppliers for which payment previously has been sought has been paid from payments received and include a sworn statement. No Request for Payment must include amounts for a Subcontractor or Supplier if the Contractor does not intend to use the payments requested, when received, to reduce the Contractor's outstanding obligations on the Work. The Owner will pay the Contractor within thirty Calendar Days after the Owner receives and approves a certified Request for Payment from the Professional. The Contractor will provide a certification in writing that the payment request submittal is true and accurate. If payment is requested based on materials and equipment stored at the site or at another location agreed to in writing, the Request for Payment also must be accompanied by (a) consent of surety, (b) a bill of sale, invoice or other documentation warranting that the Owner has received the materials and equipment free and clear of all liens, and (c) evidence that the materials and equipment are covered by appropriate property insurance and other arrangements to protect them and the Owner's interests. The Contractor warrants and guarantees that title to all Work, materials and equipment covered by any Request for Payment, whether incorporated in the Work or not, will pass to the Owner free and clear of all liens no later than at the time of payment by the Owner to the Contractor.

7.2.1 **Electronic Funds Transfer:** The State will only disburse payments under this Contract through Electronic Funds Transfer (EFT). Contractor must register with the State at <http://www.michigan.gov/SIGMAVSS> to receive electronic fund transfer payments. If Contractor does not register, the State is not liable for failure to provide payment. Without prejudice to any other right or remedy it may have, the State reserves the right to set off at any time any amount then due and owing to it by Contractor against any amount payable by the State to Contractor under this Contract.

7.3 **Review of Request for Payment; Intent of Review:** Within ten Calendar Days after receipt of a Request for Payment, the Professional must certify to the Owner the amount the Professional determines to be due or must return the Request for Payment to the Contractor indicating the reasons for withholding certification. The Professional's certification of any Request for Payment constitutes a representation to the Owner that the Work has progressed to the point indicated; that to the best of the Professional's knowledge, information and belief, the quality of the Work is in accordance with the Contract Documents; and that the Contractor is entitled to payment in the amount certified. In the case of final payment, the Professional's certification of final payment and recommendation that the Work is acceptable must be a further representation that conditions governing final payment to the Contractor have been met.

7.4 **Refusal to Make or to Recommend Payment:** The Owner may withhold from any payment an amount based on the (a) Professional's refusal to recommend payment or (b) Owner's estimate of the fair value of items included in the payment request. The Owner will give the Contractor reasonably prompt written notice supporting such action. The Professional may refuse to recommend any part of any payment, or because of subsequently discovered evidence, inspections or tests or the value of the

Punch List, nullify all or any portion of any payment previously recommended, as the Professional may consider necessary to protect the Owner from loss because:

- (a) the Work is Defective or completed Work has been damaged requiring correction or replacement,
- (b) a defective work/non-compliance notice has not been acknowledged by the Contractor,
- (c) the Contract Price has been reduced by Change Order,
- (d) it has been necessary that the Owner correct Defective Work or complete Work,
- (e) reasonable evidence exists that all or a part of the Work will not be completed within the corresponding Contract Time,
- (f) the Contractor failed to comply with any material requirements of the Contract, including, but not limited to the failure to submit Progress Schedule Submittals or as built/Record Documents when due,
- (g) stored materials for which payment has been made or is sought has been determined by the Professional or the Owner Field Representative to be damaged or missing, or
- (h) the Professional reasonably believes or knows of the occurrence of an event justifying termination for cause.

7.5 Request for Final Inspection: The Contractor must complete the Substantial Completion Punch List within the Contract Time and date. The Contractor must assemble all required documentation before requesting final inspection in writing. The Contractor may request final inspection of the entire Work, or the part of the Work for which final payment is specified in the Contract Documents. Upon this written notice, and if deemed appropriate by the professional, the Professional will make a final completion inspection with the Owner and Contractor and notify the Contractor of all incomplete or Defective Work revealed by the Final Inspection. The Contractor must immediately correct and complete the Work.

7.6 Close-out Documents: The Contractor must prepare and submit the following documentation before requesting final inspection or final payment: final operating and maintenance documentation (with revisions made after Substantial Completion), warranties, inspection certificates, as built/Record Documents, release of payment claim forms, and all other required documents.

7.7 Request for Final Payment: The Contractor may request final payment after correcting or completing the Work to the satisfaction of the Professional and delivering close-out documentation (7.6). The Contractor's request for final payment must also enclose:

- (a) evidence of completed operations insurance and an affidavit certifying that the insurance coverage will not be canceled, materially changed, or renewal refused,
- (b) an affidavit certifying that the surety agrees that final payment does not relieve the surety of any of its obligations under the Performance Bond and Payment Bond,
- (c) a completed DTMB-0460 Form close out checklist,
- (d) a list of all pending insurance claims arising out of or resulting from the Work being handled by the Contractor and/or its insurer
- (e) Contractor's 'Guarantee and Statement' (DTMB-0437) containing a statement of guaranteed indebtedness acceptable to the Owner in the full amount of the Contract Price, or a release of payment claims in the form of a release of liens, or a Bond or other security acceptable to the Owner to indemnify the Owner against any payment claim.

7.8 Final Payment and Acceptance: If the Professional is satisfied that the entire Work, or the part of the Work for which final payment is specified in the Contract Documents, is complete and the Contractor's other obligations under the Contract Documents has been fulfilled, the Professional will furnish to the Owner and Contractor the Professional's certification of final payment and acceptance within thirty Calendar Days after receipt of the final payment request. If the Professional is not satisfied, the Professional will return the request to the Contractor indicating in writing the reasons for not certifying final payment. If the final payment request is returned, the Contractor must correct the deficiencies and re-request final payment. If the Owner concurs with the Professional's certification of final payment the Owner will, within thirty Calendar Days after receipt of the Professional's certification of final payment, pay the balance of the Contract Price subject to those provisions governing final payment specified in the Contract Documents. If the Owner does not concur with the Professional's determination, the Owner will return the request for final payment to the Contractor with written reasons for refusing final payment and acceptance.

7.9 Contractor's Continuing Obligation: The following does not constitute acceptance of the Work in the event the Work or any Work is not in accordance with the Contract Documents, and therefore does not release the Contractor from its obligation to perform and furnish the Work in accordance with the Contract Documents:

- (a) a certification by the Professional of any Request for Payment or final payment.
- (b) the issuance of a Substantial Completion certificate.
- (c) any payment by the Owner to the Contractor.
- (d) any Partial Use.
- (e) any act of acceptance by the Owner or any failure to do so.
- (f) any review and approval of a Shop Drawing, sample, test procedure or other Submittal.
- (g) any review of a Progress Schedule.
- (h) any On-Site Inspection.

- (i) any inspection, test, or approval.
- (j) any issuance of a notice of acceptability by the Professional; or
- (k) any correction of Defective Work or any completion of Work by the Owner.

7.10 Waiver of Claims: The making of final payment does not constitute a waiver by the Owner of any rights as to the Contractor's continuing obligations under the Contract Documents, nor will it constitute a waiver of any claims by the Owner against the Contractor still unsettled, or arising from unsettled payment claims, Defective Work appearing after final inspection or failure by the Contractor to comply with the Contract Documents or the terms of any special warranties provided by the Contract Documents or by Law. The acceptance of final payment will constitute a waiver of all claims by the Contractor against the Owner, other than those claims previously made in writing, on a timely basis.

8. Other Work: During the Contract Time, the Owner may self-perform or Contract for other work at the site. By doing so, the Owner or its representative will coordinate the operations of the Contractor and the other work. Whenever the other work interfaces with the Contractor's Work on site, the Contractor must coordinate its activities with the interfacing work, inspect the other work and promptly report to the Professional in writing if the other work is unavailable or unsuitable. The Contractor's failure to do so will constitute an acceptance of such other work as fit and proper for integration with the Work except for latent or non-apparent defects and deficiencies in the other work. The Contractor must provide proper and safe access to the site for handling, unloading and storage of their materials and equipment and for the execution of the other work. The Contractor must do all cutting, fitting, patching, and interfacing of the Work that may be required to make any part of the Work come together properly and integrate with other work. If the Contractor becomes party to a dispute or claim due to damages caused to its Work/property or other work/their property, the Contractor must promptly attempt, without involving the Owner or the Professional or their agents, to settle with the other party by agreement or otherwise resolve the claim. If the Owner determines that the other work resulted in a delay to the Work to be performed by the Contractor and such delay justifies a Change Order, the Owner will authorize the necessary adjustment in Contract Price and/or Time.

9. Stop Work Orders and Suspension of Work: The Owner may order the Contractor in writing to defer, stop, suspend, or interrupt all or part of the Work, in the event any of the following situations:

- (a) any Work is Defective,
- (b) any Work, when completed, will not conform to the Contract Documents,
- (c) any materials or equipment are unsuitable,
- (d) any workers are insufficiently skilled,
- (e) failure of the Contractor to implement appropriate measures for the SESC, or
- (f) as the Owner may determine appropriate for its convenience. The Contractor is responsible for the Delays and any additional costs if at fault. Any justified increase in Contract Price/Time due to suspension of Work must be submitted within twenty-one Calendar Days of knowing the extent of Delays and before submitting the final payment.

10. Termination:

10.1 Termination for Breach: The Owner may elect to terminate all or any part of the Work if:

- (a) the Contractor fails to complete the Work, or a specified part of the Work, within the corresponding Contract Time; fails or refuses to supply sufficient management, supervision, workers, materials, or equipment; or otherwise fails to prosecute the Work, or any specified part of the Work, with the diligence required to comply with the Contract Time(s).
- (b) the Contractor persistently disregards the authority of the Professional or violates or disregards a provision of the Contract Documents or the Laws of any Political Subdivision with jurisdiction.
- (c) the Contractor admits in writing, or the Owner otherwise establishes, the Contractor's inability or refusal to pay the Contractor's debts generally as they become due.
- (d) in response to the Owner's demand, the Contractor fails to provide adequate, written assurance that the Contractor has the financial resources necessary to complete the Work within the Contract Time.
- (e) the Contractor fails to comply with the Michigan Residency requirements (1984 PA 431, as amended, MCL 18.1241a); or is found to be in violation of Section 4 of 1980 PA 278 concerning unfair labor practices, or any nondiscrimination requirements imposed by Law.
- (f) at any time, the Contractor, Subcontractor or Supplier is in violation of unfair labor practices prohibited by Section 8 of Chapter 327 of the National Labor Relations Act, 29 U.S.C. 158; or
- (g) the Contractor violates or breaches any material provision of the Contract Documents, which provides contractually for cause termination or rescission of the Contract or of the Contractor's right to complete the Work.

Within seven Calendar Days after the Contractor receives a notice requiring assurance of due performance for any of the above occurring non-conformances, the Contractor must meet with the Owner and present the Contractor's plan to correct the problems. If the Owner determines that the Contractor's plan provides adequate assurance of correction, that determination does not waive the Owner's right to subsequently default the Contractor or affect any rights or remedies of the Owner against the Contractor and/or surety then existing or that may accrue in the future. The Owner, after giving the Contractor and surety seven Calendar Days' written notice of intent to default, may declare the Contractor in default and terminate the services of the

Contractor for cause. Unless otherwise agreed between the Owner and Contractor, at the expiration of the Seven-Calendar Day (intent to default) period, the Contractor must immediately stop all Work and proceed in accordance with the Owner's instructions. Following the expiration of the Seven-Calendar Day (intent to default) notice, the Contractor will be sent a default letter – notice of termination for cause. The Owner will issue a Contract Change Order to revise the name of the contract party to the name of the surety company. The surety company must undertake to perform and complete the Work, in accordance with the Contract Documents, in place of the Contractor, either through the surety's agents or by executing agreements with qualified contractors (excluding the Contractor and any of the Contractor's affiliates), or both.

The Owner may issue a fifteen-Calendar Day notice of intent to default the surety company if they fail to execute in a timely manner the completion of the Contract Work. Without an adequate plan of correction, the Owner may issue a notice of termination for cause letter to the surety. If a termination of the contract with the surety occurs, the Owner reserves the right to complete the Work.

If the Owner has terminated the Contractor, any such termination will not affect any rights or remedies of the Owner against the Contractor or surety, or both, then existing or that may accrue after termination. All provisions of the Contract Documents that, by their nature, survive final acceptance of the Work must remain in full force and effect after a termination for cause of the Contractor or default of the surety, or both. The Owner may, in its sole discretion, permit the Contractor to continue to perform Work when the Contractor is in default or has been defaulted. Such decision by the Owner in no way operates as a waiver of any of the Owner's rights under the Contract Documents or Performance Bond, nor in the event of a subsequent default, entitle the Contractor or surety to continue to perform or prosecute the Work to completion.

- 10.2 **Termination on Non-Bonded Project:** For non-bonded projects, the Owner will follow the termination protocol in Paragraph 10.1 without involving a surety.
- 10.3 **Termination for Convenience of the Owner:** Upon fifteen Calendar Days' written notice to the Contractor and surety, or sooner if reasonable under the circumstances, the Owner may, without cause and without prejudice to any other right or remedy it may have, elect to terminate any part of the Work, or the Contract in whole or in part, as the Owner may deem appropriate for its convenience. Upon receipt of any such termination notice, the Contractor must immediately proceed in accordance with any specific instructions, protect and maintain the Work, and make reasonable and diligent efforts to mitigate costs associated with the termination. In such termination, the Contractor must be paid in accordance with the terms of this Contract for only services rendered before the effective date of termination. Upon termination for convenience, the Contractor must be released from any obligation to provide further services and the Owner must have full power and authority to take possession of the Work, assume any agreements with Subcontractors and Suppliers that the Owner selects, and prosecute the Work to completion by Contract or as the Owner may deem expedient.
- 10.4 **Termination for Lack of Funding:** If expected or actual funding is withdrawn, reduced, or limited in any way before the completion date set forth in this Contract or in any amendment, the State may, upon written notice to the Contractor, terminate this Contract in whole or in part in accordance with Paragraph 10.3.
11. **Disputes:** All claims, counterclaims, disputes, and other matters in question between the Owner and Contractor arising out of or relating to the Contract Documents must be submitted in writing to the Professional and otherwise processed and resolved as provided in this Article. *Claims by either the Owner or Contractor must be initiated by written notice to the other party and to the Initial Decision Maker (Professional/PSC). Claims by either party must be initiated within 21 days after the occurrence of the event giving rise to such Claim or within 21 days after the claimant first recognized the condition giving rise to the claim. Provided such timely notice is delivered, a full and detailed breakdown of cost and time requested, with supporting documentation, if not provided with initial notice shall be delivered to Professional and Owner within 15 days of the notice, unless otherwise agreed in writing, by the Owner prior to expiration of such time.* The Contractor must carry on the Work with due diligence during all disputes or disagreements. Work must not be delayed or postponed pending resolution of any disputes or disagreements. The Contractor must exercise reasonable precautions, efforts, and measures to avoid situations that would cause delay.
- 11.1 **Notice of Claim:** Except for Owner claims for liquidated damages, no claim is valid unless it is based upon written notice delivered by the claimant to the other party and the Professional/PSC within 21 days of the event giving rise to the claim. The notice must state the nature of the dispute, the amount involved, if any, and the remedy sought. The claim submittal with all supporting data must be delivered within thirty (30) Calendar Days after the initial notice unless the Professional allows an extension by written approval. A claim by the Contractor must be submitted to the Professional and Project Director for a recommendation or decision from the Professional. A claim by the Owner must be submitted to the Contractor and the Professional for a written recommendation or decision by the Professional. The Owner reserves the right to audit any Contractor claim (or claim package) that the Contractor values at more than \$50,000.00. Pending final resolution of any claim under this Article, the Contractor must proceed diligently with the Work and comply with any decision of the Owner and/or Professional. For all Contractor claims seeking an increase in Contract Price or Contract Time, the Contractor must submit an affidavit, certifying that the amount claimed accurately reflects any Delay and all costs that the Contractor is entitled from the occurrence of the claimed event and that supporting cost and pricing data are current, accurate, complete and represent the Contractor's best knowledge and belief. The affidavit must be signed in the same manner as required in Item 6 of Section 00100.

- 11.2 Recommendations or Decisions from the Professional:** For claims under \$100,000.00, if requested in writing by the Contractor, the Professional will render a recommendation or decision within thirty Calendar Days after the request and the Owner will issue, if necessary, a determination within thirty Calendar Days after the Professional's recommendation or decision. For claims exceeding \$100,000.00, the Professional will issue its recommendation or decision and the Owner, if necessary, will issue its determination, within sixty Calendar Day.

If the Professional denies a Contractor claim or agrees with an Owner claim, that decision must be final and binding on the Contractor, without any determination by the Owner, unless the Contractor files a request for a presentation with the Director-DCD within thirty Calendar Days. To the extent that any recommendation from the Professional is partly or wholly adverse to a claim from the Owner, that determination must be final and binding on both the Owner and Contractor unless either party files a request for a presentation with the Director-DCD within thirty Calendar Days. If the Professional recommends payment of any Contractor claim which increases the Contract Price, that recommendation is subject to the Owner's written approval. In the event any such determination from the Owner is partly or wholly adverse to the preceding recommendation from the Professional, that determination must be final and binding on the Contractor unless the Contractor files suit in the Michigan Court of Claims within thirty Calendar Days after receipt of such determination. The claim is waived if not made in accordance with these requirements.

If either the Contractor or Owner is not satisfied with any decision of the Professional on a claim, that party must, within thirty Calendar Days of receiving that decision, file a written appeal with complete supporting documentation with the Director-DCD. The Director-DCD has discretion concerning the allowability of evidence submitted and is not bound to any rules of evidence. If the right to a presentation is waived or if a presentation is conducted and the dispute remains unresolved, the Director-DCD, at the Director-DCD's sole option, must specify in which forum the dispute must be conducted by issuing a written determination to the Contractor that the dispute if the Contractor so elects, be submitted in writing to the Michigan Court of Claims. The Director-DCD's determination on the dispute is final and binding on the Contractor unless the Contractor files a lawful action in the Michigan Court of Claims within thirty Calendar Days after receiving the Director-DCD's determination. After settlement or final adjudication of any claim, if payment by the Contractor is not made to the Owner, the Owner may offset the appropriate amounts against (a) payments due to the Contractor under any other Contract between the Owner and the Contractor, or (b) any amounts for which the Owner may be obligated to the Contractor in any capacity. The Director-DCD may designate someone to fulfill the Director-DCD's duties under these terms and conditions.

END OF SECTION 00700

SECTION 00750 SPECIAL WORKING CONDITIONS

1. The Work is for the Department of Technology, Management & Budget and their special working conditions are included in Appendix II. Contractor must comply with all security regulations. Access to and egress from the buildings and State Agency grounds must be via routes specifically designated by the State Agency. Whenever the Contractor has caused an operating security or fire system to go out of service or left unsecured openings in existing facilities or security fences, the Contractor must furnish a security guard or fire watch acceptable to the Owner to maintain security of the facility outside of normal working hours and will be held responsible for any losses from the facility.
2. The Contractor must maintain, at all times, dust control measures to the satisfaction of the Owner.

END OF SECTION 00750

SECTION 00800 SUPPLEMENTARY CONDITIONS

1. The following conditions must supplement the general conditions:

Allowance shall be a provisional allowance as defined in specifications.

Clarification: Contractors are required to furnish a preliminary schedule that includes the following items:

- a. Working hours
- b. Crew size and number of crews.
- c. The number of days per week that they will be onsite.

Clarification: Contractors will be allowed to work five days a week, Monday through Friday, from 7:30am to 5:00pm. No work on State Holidays and longer days without prior approval.

Clarification: There will be the following project meetings.

- a. Pre-Construction Meeting – Scheduled after contract is executed.
- b. Progress Meetings – This will be determined at each Pre-Construction conference, minimum one every other week.
- c. Substantial completion and final completion meetings.

Clarification: There will be no substitution request after Bid Date.

Clarification: Contractor is required to fill out daily reports. Reports to be submitted daily or once a week.

END OF SECTION 00800

SECTION 00900 ADDENDA

1. Each Bid submittal must include acknowledgement of receipt and review of all Addenda issued during the Bidding period.

END OF SECTION 00900

DIVISION 01

GENERAL REQUIREMENTS

SECTION 01010 SUMMARY OF WORK**1. General**

1.1 General information covering the "Scope of Work" is specified on the Invitation to Bid.

1.2 The Agency will provide the following Work:

- (a) State Salvage: The State reserves the right to salvage certain items and equipment and those salvaged items will be identified to the Bidder at the time of their inspection of the proposed Work. The State will remove salvaged items before commencement of the Work.
- (b) Moving Furnishings and Equipment: The Contractor must give timely notice to the State Agency representative identified in the pre-construction meeting of all furnishings, window covering and movable equipment that will interfere with the Work or which the Contractor cannot protect with coverings of paper, plastic, drop cloths or clean tarpaulin. The Contractor must furnish, install, maintain, and remove all coverings used to protect furnishings, window coverings and movable equipment.

END OF SECTION 01010**SECTION 01020 ALLOWANCES****1. Allowances****1.1 Cash Allowances:**

- (a) Bidders must include in their Base Proposal Sum an allowance of \$20,000. The base bid shall include bonds and insurance on the value of the allowance.
- (b) Monies in the allowance will be used only if directed in writing by the Project Director and Professional.
- (c) Payments under a Cash Allowance must be on actual cost and exclude cost for supervision, handling, unloading, storage, installation, testing, fee, premiums for bond and insurance, etc.
- (c) Unused allowances will be deducted from the contract amount through contract change order.

1.2 Provisional/Contingency Allowances:

- (a) Bidders must include in their Base Proposal Sum a contingency allowance of \$20,000. The base bid shall include bonds and insurance on the value of the allowance.
- (b) Monies will be used in the contingency allowance only if directed in writing by the Project Director and Professional.
- (c) Payments under a Provisionary Allowance will include not only the purchase/furnished cost of the materials and equipment involved, but also all related labor costs, subcontract costs, construction equipment costs, general conditions costs and Fee, provided they are calculated in accordance with the requirements of the contract documents.
- (c) Unused allowances will be deducted from the contract amount through contract change order.

END OF SECTION 01020**SECTION 01025 MEASUREMENT AND PAYMENT**

1. **Schedule of Values:** Unless noted otherwise, before mobilization and start of construction, the Contractor must submit a Schedule of Values to the Professional for review and approval, of the various tasks that must be performed to complete all the Work. The schedule must show each task and the corresponding value of the task, including separate monies allocated for General Condition items and Project close-out. The aggregate total value for all tasks must be equal to the total Contract sum.

END OF SECTION 01025**SECTION 01030 ALTERNATES**

1. **Use of Alternates:** Determination of the lowest three Bidders shall be based on the sum of the Base Bid and any additive and deductive Alternates the Owner accepts, in the order in which they are listed only. The Owner will accept an Alternate only if all other previously listed Alternates are also accepted unless acceptance by the Owner of Alternates in a different order does not affect determination of the lowest three bidders in any way.
2. **Execution:** (a) Coordinate pertinent related Work and modify surrounding work as required to complete the Project for each alternate.
(b) Description of Alternates:

Alternate No. 1: Contractor to not provide and install new air dryer and all associated accessories in the location shown.

END OF SECTION 01030**SECTION 01040 COORDINATION****1. Project Coordination:**

- (a) Before beginning Work the Contractor must coordinate with the State Agency representative to implement the schedule for the Project. Once the Project is started, it must be carried to completion without delay. (b) Any building utility service interruptions or outages including security required by the Contractor in performing the Work must be prearranged with the staff of the State Agency and must occur only during those scheduled times. (c) The Contractor is not responsible for removing room furnishings unless is required by the Contract Documents.

2. Cutting and Patching:

- (a) The Contractor must do all cutting, fitting, or patching of the Work that may be required to make its several parts fit together properly or make new Work join with the existing structure. The Contractor must take proper precautions so as not to endanger any existing Work. The Contractor must not cut or alter existing structural members or foundations unless specifically required by the Contract Documents.
- (b) Holes or openings cut in exterior walls and roofs for installation of materials or equipment must be waterproofed by appropriate, approved materials and methods.
- (c) All adjacent finished surfaces that are damaged by the new Work must be patched with materials matching existing surfaces. Joints between patched and existing material must be straight, smooth, and flush. Workers skilled in its installation must apply all patching material.

END OF SECTION 01040**SECTION 01050 FIELD ENGINEERING**

1. When applicable, the Contractor must employ a surveyor who must establish and maintain all lines and levels required for laying out and constructing the Work. The Contractor agrees to assume all responsibility due to inaccuracy of any Work of the surveyor, and including incorrect benchmarks, their loss or disturbance. Upon completion of the Project, the Contractor must submit two copies of site layout Drawings prepared for the Project and certified by the surveyor.

END OF SECTION 01050**SECTION 01060 REGULATORY REQUIREMENTS**

1. **Laws:** The Contractor and its Subcontractors/Suppliers must comply with all Federal, State, and local Laws applicable to the Work and site.
2. **Codes:** All Works must be provided in accordance with the State Construction Code Act, 1972 PA 230, as amended, MCL 125.1501 et seq., International Building and Residential Codes and all applicable Michigan construction codes and fire safety including but not limited to: Michigan Building Code, Michigan Residential Code, Michigan Uniform Energy Code, Michigan Electrical Code, Michigan Rehabilitation Code for Existing Buildings, Michigan Mechanical Code, Michigan Elevator Code and Michigan Plumbing Code. If the Contractor observes that any Contract Document conflicts with any Laws or the State Construction Code or any permits in any respect, the Contractor must promptly notify the Professional in writing. If the Contractor provides any Work knowing or having to reason to know of such conflict, the Contractor must be responsible for that performance.
3. **Permits:** All required construction permits must be secured and their fees including inspection costs must be paid by the Contractor. The time incurred by the Contractor in obtaining construction permits must constitute time required to complete the Work and does not justify any increases to the Contract Time or Price, except when revisions to the Drawings and/or Specifications required by the permitting authority cause the Delays. The Contractor must pay all charges of Public Utilities for connections to the Work, unless otherwise provided by Cash Allowances specific to those connections. The following permit fees will be paid by the Owner N/A, all permits to be paid by the contractor.
4. **Taxes:** The Contractor must pay all Michigan sales and use taxes and any other similar taxes covering the Work that are currently imposed by legislative enactment and as administered by the Michigan Department of Treasury, Revenue Division. If the Contractor is not required to pay or bear the burden or obtains a refund of any taxes deemed to have been included in the Bid and Contract Price, the Contract Price must be reduced by a like amount and that amount, whether as a refund or otherwise, must ensure solely to the benefit of the State of Michigan.
5. **Safety and Protection:** The Contractor and its Subcontractors/Suppliers must comply with all applicable Federal, State, and local Laws governing the safety and protection of persons or property, including, but not limited to the Michigan Occupational Safety and Health Act (MIOSHA), 1974 PA 154, as amended, MCL 408.1001 et seq., and all rules promulgated under the Act. The Contractor is responsible for all damages, injury or loss to the Work, materials, equipment, fines, penalties as a result of any violation of such Laws, except when it's due to the fault of the Drawings or Specifications or to the Act, error, or omission of the

Owner or Professional. The Contractor is solely responsible for initiating, maintaining, and supervising all safety precautions and programs and such responsibility must continue until such time as the Professional is satisfied that the Work, or Work inspected, is completed and ready for final payment. In doing the Work and/or in the event of using explosives, the Contractor must take all necessary precautions for the safety of, and must erect and maintain all necessary safeguards and provide the necessary protection to prevent damage, injury or loss to: (a) all employees on the Work and other persons who may be affected by the Work, (b) all the Work and materials and equipment to be incorporated into the Work, whether stored on or off the site, and (c) other property at or adjacent to the site, including trees, shrubs, lawns, walks, pavements, roadways, structures, utilities and Underground Utilities not designated for removal, relocation or replacement. In the event of severe weather, the Contractor must inspect the Work and the site and take all reasonably necessary actions and precautions to protect the Work and ensure that public access and safety are maintained.

6. Fire Hazard Conditions:

- (a) The fire hazard classification of finish materials where used in the specification must be in accordance with the current Michigan Building Code.
- (b) Classification must be determined by tunnel test in accordance with National Fire Protection Association (NFPA-255), American Society for Testing Materials (ASTM E-84) or Underwriters' Laboratories, Inc. (UL-723).

7. Flame/Smoke Resistance Standards: The Contractor must provide carpeting complying with "Class B" requirements as set forth in Michigan Department of State Police State Fire Safety Board "Health Care Facilities Fire Safety Rules' R29.1243, Rule 243, when tested in accordance with the following procedures:

- (a) Tunnel Test: Test for surface burning characteristics, with ratings for flame spread, fuel contribution, and/or smoke density; ASTM E 84, UL 723, or NFPA No. 255.
- (b) Pill Test: Test for flammability; ASTM D 2859, or DOC FF-1-70.
- (c) Floor Radiant Panel Test: Test for burning under varying radiant energy levels; ASTM E 648, with minimum average radiant flux ratings not less than 0.45 watts/sq. cm.
- (d) Smoke Density Test: Test in radiant heat chamber, with and without flame, for density of smoke generated; ASTM E 662, or NFPA No. 258, also known as NBS Smoke Density Chamber Test.***

8. Michigan Right-To-Know Law: The Contractor and its Subcontractors/Suppliers must comply with MIOSHA, Michigan Right-to-Know Law (Public Act 80 of 1986) and the rules promulgated under it. The Act places certain requirements on employers to develop a communication program designed to safeguard the handling of hazardous chemicals through labeling of chemical containers and development and availability of Safety Data Sheets (SDS), and to provide training for employees who work with these chemicals and develop a written hazard communications program. The Act also provides for specific employee rights, including the right to be notified of the location of SDS and to be notified at the site of new or revised SDS within five Business Days after receipt and to request SDS copies from their employers. The Contractor, employer or Subcontractor must post and update these notices at the site.

9. Environmental Requirements: The Contractor and its Subcontractors/Suppliers must comply with all applicable Federal, State and local environmental Laws, standards, orders or requirements including but not limited to the National Environmental Policy Act of 1969, as amended, Michigan Natural Resources and Environmental Protection Act, P.A. 451 of 1994, as amended, the Clean Air Act, as amended, the Clean Water Act, as amended, the Safe Drinking Water Act, as amended, Pollution Prevention Act, as amended, Resource Conservation and Recovery Act, as amended, National Historic Preservation Act, as amended and Energy Policy and Conservation Act and Energy Standards for Buildings Except Low-Rise Residential Buildings, ANSI/ASHRAE/IESNA Standard 90.1.

10. Nondiscrimination: For all State Contracts for goods or services in amount of \$5,000 or more, or for Contracts entered into with parties employing three or more employees; in connection with the performance of Work under this Contract, the Contractor and its Subcontractors and Suppliers must comply with the following requirements:

- 10.1 Not to discriminate against any employee or applicant for employment because of race, color, religion, national origin, age, sex (as defined in *Executive Directive 2019-09*), height, weight or marital status and take affirmative action to ensure that applicants are employed, and the employees are not subject to such discrimination. Such action must include, but is not limited to, the following: employment, upgrading, demotion or transfer; recruitment advertising; layoff or termination; rates of pay or other forms of compensation; and selection for training.
- 10.2 To state in all solicitations or advertisements for employees that all qualified applicants will receive consideration for employment without regard to race, color, religion, national origin, age, sex, height, weight, or marital status.
- 10.3 To send, or have its collective bargaining representative send, each labor union or representative of workers with which there is a collective bargaining agreement or other contract or understanding, a notice advising the labor unions or workers' representative of the commitments under this provision.
- 10.4 To comply with the Elliot-Larsen Civil Rights Act, 1976 PA 453, as amended, MCL 37.2201 et seq.; the Michigan Persons with Disability Civil Rights Act, 1976 PA 220, as amended, MCL 37.1101 et Seq.; *Executive Directive 2019-09*; and all published rules,

regulations, directives, and orders of the Michigan Civil Rights Commission (MCRC) which may be in effect on or before the date of Bid opening.

- 10.5 The Contractor must furnish and file compliance reports within the times, and using the forms prescribed by the MCRC. Compliance report forms may also elicit information as to the practices, policies, programs, and employment statistics of the Contractor and Subcontractors. The Contractor must permit access to Records by the MCRC and its agent for purposes of ascertaining compliance with the Contract and with rules, regulations, and orders of the MCRC.
- 10.6 If, after a hearing held under its rules, the MCRC finds that the Contractor has not complied with the Elliott-Larson requirements of the Contract Documents, MCRC may, as part of its order, certify its findings to the Administrative Board of the State of Michigan, which may order the cancellation of the Contract and/or declare the Contractor ineligible for future contracts with the State until the Contractor complies with the MCRC's order.
11. **Michigan Residency for Employees:** Fifty percent of the persons employed on the Work by the Contractor must have been residents of the State of Michigan for not less than one year before beginning employment on the Work. This residency requirement may be reduced or waived to the extent that Michigan residents are not available or to the extent necessary to comply with the federal funds used for the Project. This requirement does not apply to employers who are signatories to collective bargaining agreements that allow for the portability of employees on an interstate basis.

END OF SECTION 01060

SECTION 01090 REFERENCES

1. References will be made in an abbreviated alpha numeric form to specific standard specifications, reference publications and building codes of federal or state agencies, manufacturers, associations, or trade organizations. Such references will be identified by the alphabetic abbreviation which identifies the government agency, the association or organization followed by the rule, section or detail number that are to form a part of these specifications, the same as if fully set forth herein, and must be of latest issued date in effect three months before the Bid opening date shown on the Proposal and Contract. The abbreviations used are referred to as follows:

| <u>Abbreviation</u> | <u>Agency, Association or Organization</u> |
|---------------------|---|
| ACI | American Concrete Institute |
| AISC | American Institute of Steel Construction, Inc. |
| AMCA | Air Moving and Conditioning Association |
| ANSI | American National Standards Institute, Inc. |
| ASHRAE | American Society of Heating, Refrigerating and Air Conditioning Engineers |
| ASME | American Society of Mechanical Engineers |
| ASSE | American Society of Sanitary Engineering |
| ASTM | American Society of Testing and Materials |
| AWS | American Welding Society |
| AWWA | American Water Works Association |
| BOCA | Building Officials and Code |
| CDA | Copper Development Assn., Inc. |
| CLFMI | Chain Link Fence Manufacturer's Institute |
| CISPI | Cast Iron Soil Pipe Institute |
| CRSI | Concrete Reinforcing Steel Institute |
| CS | Commercial Standard |
| F/M | Factory Mutual Research Corporation |
| FS | Federal Specifications |
| HEW | United States Department of Health Education and Welfare |
| MDOT | Michigan Department of Transportation |
| NFPA | National Fire Protection Association |
| NSF | National Sanitation Foundation Testing Laboratory, Inc |
| NSWMA | National Solid Waste Management Association |
| PCA | Portland Cement Association |
| PDI | Plumbing and Drainage Institute |
| SMACNA | Sheet Metal & Air Conditioning Contractors |
| UL | Underwriters Laboratories, Inc. |
| USBM | United States Bureau of Mines |
| USDC | United States Department of Commerce |

END OF SECTION 01090

SECTION 01100 PROJECT PROCEDURES

1. **Signage and Safety:** The Contractor must post appropriate construction signs to advise the occupants and visitors of occupied facilities of the limits of construction work areas, hardhat areas, excavations, construction parking and staging areas, etc. Advertising signage by contractors, subcontractors, or suppliers is not allowed. The Contractor must maintain safe and adequate pedestrian and vehicular access to fire hydrants, commercial and industrial establishments, churches, schools, parking lots, hospitals, fire, and police stations and like establishments. The Contractor must obtain written approval from the Owner ten Calendar Days before connecting to existing facilities or interrupting the services on site.
2. **Required Project Sign:** For projects costing in excess of \$500,000, the Contractor must provide and install a project sign conforming to the requirements shown in Appendix IV. The Project Director will designate the wording for the sign.
3. **Barrier and Enclosures:**
 - (a) The Contractor must furnish, install, and maintain as long as necessary and remove when no longer required adequate barriers, warning signs or lights at all dangerous points throughout the Work for protection of property, workers, and the public. The Contractor must hold the State of Michigan harmless from damage or claims arising out of any injury or damage that may be sustained by any person or persons as a result of the Work under the Contract.
 - (b) **Temporary Fence:** The Contractor must entirely enclose the Contract area by means of woven wire or snow fence having minimum height of four feet. Gates must be provided at all points of access. Gates must be closed and secured in place at all times when Work under the Contract is not in progress. The fence must be removed, and grounds restored to original condition upon completion of the Work.
 - (c) **Street Barricades:** The Contractor must erect and maintain all street barricades, signal lights and lane change markers during the periods that a traffic lane is closed for their operations. There must be full compliance with rules and ordinances respecting such street barricading and devices must be removed when hazard is no longer present.
4. **Construction Aids:**
 - (a) The Contractor must furnish, install, and maintain as long as necessary and remove when no longer required, safe and adequate scaffolding, ladders, staging, platforms, chutes, railings, hoisting equipment, etc., as required for proper execution of the Work. All construction aids must conform to Federal, State, and local codes or Laws for protection of workers and the public.
 - (b) **Debris Chute:** The Contractor must use a chute to lower debris resulting from their Work. The chute must be the enclosed type with its discharge directly into the truck or approved container.
 - (c) **Pumping and Drainage:** The Contractor must provide all pumping necessary to keep excavations and trenches free from water the entire period of Work on the Contract. The Contractor must construct and maintain any necessary surface drainage systems on the Work site so as to prevent water entering existing structures or to flow onto public or private property adjacent to the Agency's land, except for existing drainage courses or into existing drainage systems. The Contractor must prevent erosion of soils and blockage of any existing drainage system.

END OF SECTION 01100**SECTION 01200 PROJECT MEETINGS**

1. **Pre-Construction Conferences:** The Project Director will schedule a pre-construction conference to be attended by the Professional, State Agency staff, and the Contractors. A project procedure as outlined in Form DTMB-0460, will be established for the Work during the pre-construction meeting. When no organizational meeting is called, the Contractor, before beginning any Work, must meet with the staff of the Agency and arrange a Work schedule for the Project. Once the Project has been started, the Contractor must carry it to completion without delay.
2. **Progress Meetings:** The Professional will schedule progress meetings to be held on the job site whenever needed to supply information necessary to prevent job interruptions, to observe the Work or to inspect completed Work. The Contractor must be represented at each progress meeting by persons with full authority to act for the Contractor in regard to all portions of the Work.

END OF SECTION 01200

SECTION 01300 SUBMITTALS**1. Shop Drawings, Samples and Technical Submittals:** .**1.1 Contractor's Review:** Before each submission, the Contractor must:

- (a) determine and verify all field measurements, quantities, dimensions, instructions for installation and handling of equipment and systems, installation requirements (including location, dimensions, access, fit, completeness, etc.), materials, color, catalog numbers and other similar data as to correctness and completeness, and
- (b) have reviewed and coordinated that technical Submittal with other technical submittals and the requirements of the Contract Documents.

1.2 Notice of Variation: The Contractor must give the Professional specific written notice of any variation from the requirements of the Contract Documents.**1.3 Contractor's Approval:** The Contractor shall not submit unapproved submittals. Each submittal shall be stamped/certified to indicate that the submittal satisfies the requirements of the Contract Documents before submission to the Professional.**1.4 Responsibility and Authority:** Neither the Owner's authority to review any of the Submittals by the Contractor, nor the Owner's decision to raise or not to raise any objections about the Submittals, creates or imposes any duty or responsibility on the Owner to exercise any such authority or decision for the benefit of the Contractor/Subcontractor/Supplier, any surety to any of them or any other third party. The Contractor is not relieved of responsibility for errors or omissions in shop drawings, product data, samples, or similar submittals just because the Professional approved them for general design intent.**1.5 Final As-Built/Record Documents and Submittals:** The approved Submittals are a part of the final As-Built/Record Documents required for processing final payment to the Contractor.**1.6 Submissions:** Contractor must submit to the Professional:

- (a) A 3-inch wide by 2-inch-high clear space for State approval stamp must be provided on the Title Sheet of the shop drawings.
- (b) all required samples; and
- (c) all other technical submittals (test, results, test and safety procedures, O&M manuals, etc.) that are required by the Contract Documents. In addition to electronic copies up to 2 hard copies of the approved O&M manuals may be required to be provided to the agency

1.7 Professional's Review and Return: Professional's Review and Return: Submittals will be returned to the Contractor within fifteen Calendar Days. The Contractor is responsible for any time Delay and any cost incurred by the Professional, Contractor or Subcontractors/Suppliers as a result of resubmissions and re-reviews of a particular Submittal. The Contractor shall revise, and correct submittals returned for revision and resubmittal until approval by the Professional is achieved. All time consumed by the resubmissions and rereviews of a particular Submittal shall constitute time required to furnish that Submittal or shall represent Delays not justifying any increase in Contract Time or Contract Price, or both.**2. Progress Schedule:****2.1 SUMMARY**

A. The **Contractor** will submit CPM Progress Schedules to the **Owner** depicting its approach to prosecution of the Work. This includes but is not limited to the **Contractor's** approach to recovering schedule and managing the effect of changes, substitutions, and Delays on Work sequencing.

B. The Progress Schedule will include the Rev. 0 Submittal (par. 2.14), Update Submittals (par. 2.15) and Revision Submittals (par. 2.16). Each Submittal will be assigned a unique number. For a resubmission, the initial number will be modified by the letter A, B, C, etc., as appropriate.

C. Through the Progress Schedule, the **Owner** will seek to stay current on progress, updated Activity and Milestone Dates, and the **Contractor's** approach to Work remaining.

D. References to the Critical Path Method (CPM) are to CPM construction industry standards that are consistent with the requirements of this Section.

2.2 RELATED SECTIONS

A. Section 00700 General Conditions; and Section 00800 Supplementary Conditions.

2.3 GLOSSARY OF TERMS

A. Capitalized terms not already defined in any Division 0 Specification have the following intent and meanings:

1. Milestone—A key point of progress, designating interim targets toward the Contract Times. They may pinpoint critical path foundations, key deliveries, building framing, start of MEP rough-in, building enclosure, partitions, interior finishes, conditioned space, commissioning stages, Substantial Completion, and other events of like import.
2. Official Schedule—The most recent Revision Submittal returned to the **Contractor** as Resubmittal Not Required. The Rev. 0 Official Schedule is the *As-Planned* Schedule.
3. Revision 0 Submittal—Progress Schedule submitted by the **Contractor** depicting the entire Work as awarded.
4. Update Submittal—A monthly Progress Schedule update reflecting progress and minor adjustments on the Activities, sequencing and restraints for Work remaining.

2.4 QUALITY ASSURANCE

A. The **Contractor** will obtain a written interpretation from the **Professional**, if the **Contractor** believes the selection of Activities, logic ties or restraints requires an interpretation of the Contract Documents. With each submission, the **Contractor** will point out by specific, written notation, any Progress Schedule feature that may reflect variations from any requirements of the Contract Documents.

B. The **Contractor** is responsible to obtain information from each Subcontractor and Supplier when scoping their respective Activities, Values, logic ties and restraints

C. No review of any Progress Schedule by or on behalf of the **Owner** will relieve the **Contractor** from complying with the Contract Times and any required sequence of Work or from completing Work omitted from the Progress Schedule. No review will imply approval of any variation from or interpretation of the Contract Documents, unless approved by the **Professional** through a written interpretation or by means of a separate, written notation.

2.5 ALLOWANCES

A. Work covered by Cash Allowances will be completed within the Contract Times. To the extent reasonable and consistent with the **Contractor's** plan, Work authorized by provisional contingency allowances will be completed within the Contract Times. The Progress Schedule will incorporate the **Contractor's** best estimate of the Activities, logic and restraints required, using the information in the Contract Documents, or as indicated by the **Professional** in writing.

2.6 "OR EQUALS" AND SUBSTITUTIONS

A. Activities in the Rev. 0 Progress Schedule will be based on materials and equipment required by the Contract Documents and will not reflect any "or equal" or substitute materials or equipment, even if the **Contractor** intends to pursue "or equal" and substitution proposals. This limitation also applies to any Means and Methods indicated in or required by the Contract Documents.

2.7 MEASUREMENT AND PAYMENT

A. The Schedule of Values will include a Progress Schedule *pay item*. Fifteen percent (15%) of this *pay item* will be eligible for payment upon delivery of the *complete* Rev. 0 Submittal. The balance of this *pay item* will be eligible for payment, on a prorated basis, with each Request for Payment attaching an Update Submittal.

2.8 PROGRESS SCHEDULE SUBMITTALS

A. Each Progress Schedule Submittal will consist of an electronic copy the **Contractor's file**, a narrative and a PDF file of the project schedule report and plots, each file appropriately titled for the schedule version and date of publishing.

B. The CPM scheduling software will be Primavera Project Planner®, SureTrak® or Microsoft Project®.

C. In addition to the monthly update schedule submittal, **Contractor** shall provide prior to each Progress Meeting, a 2-week look ahead schedule extracted from the current overall schedule and providing sufficient additional activity detail to appropriately define the expected activity during the upcoming 2-week period.

2.9 PRINTOUTS

A. Schedule Reports will include Activity (ID) code and description, duration, calendar, Early Dates, Late Dates and Total Float, all of which will comport with the requirements of paragraph 8.3.4 of Section 00700 General Conditions.

1. Late Finish Date for an Activity pinpointing a Contract Time will equal that Contract Time. Early Start Date for an Activity designating a Contract restraint will equal the proper Notice to Proceed date. Schedule Reports may or may not append CPM Plots (time-scaled Activity/logic).

2. For Precedence Diagram Method, separate Schedule Reports will tabulate, for each Activity, all preceding and succeeding logic types and lead times, whether CPM Plots displaying vertical logic ties are appended or not.

B. CPM Schedule Plots will be plotted on a suitable time scale and identify the Contract Times, Critical Paths, and sub-Critical Paths. Activities will be shown on the Early Dates with Total Floats noted by Late Date flags.

c. Line of Balance Plots will reflect industry practice for repetitive construction and will segregate the production lines for all trades within the hammock Activities.

2.10 NARRATIVE REQUIREMENTS

A. In general, a narrative will describe the **Contractor's** approach to prosecution of the Work, subject to the requirements of the Contract Documents. Further, each narrative will list the Critical Path Activities and compare Early and Late Dates with Contract Times and Milestone Dates. The basis for restraint dates will be explained.

B. For each Update Submittal, the narrative will compare current Dates to the respective Milestone Dates, describe changes in crewing and construction equipment and identify new Delays. For each Revision Submittal, the narrative also will itemize changes in Activities, logic ties and restraint dates made necessary by each change, Delay, schedule recovery, substitution and **Contractor**-initiated revision occurring since the previous Submittal.

2.12 ACTIVITY REQUIREMENTS

A. The Progress Schedule will detail Work sequencing only to the extent necessary to allow the **Owner** to correlate percent complete, compare actual dates with Milestones and Contract Times and the data in Requests for Payment.

B. Separate Activities will designate permits, construction, Submittal preparation/review (and resubmission and re-review, for same); MEP coordination drawings; deliveries; commissioning; and Punch List. Separate Activities will designate **Owner**-furnished items, interface with other work and the **Owner** and **Professional's** responsibilities.

C. Activities will be detailed only to the extent required to show the transition of trade Work. Activities will detail the progression through site/excavation, foundations, building framing, start/completion of interior partitions, MEP rough-in, building enclosure, interior finishes, conditioned space, and commissioning.

1. Submittal Activities will segregate long-lead items, any item requiring structural access and other procurements that, in the **Contractor's** judgment, may bear on the rate of progress. Separate MEP coordination drawing Activities will be used for each floor. Beyond these requirements, it is not necessary to burden the Progress Schedule with Activities for less significant Submittals and deliveries.

2. For multiunit Work (e.g., rough-in overhead MEP for each floor, etc.), detailed Activities will be shown for a typical (often, the first) unit). Other or follow-on units may be replicated, as appropriate, or modeled with a hammock Activity combining the sum total of the typical detailed Activities. Separate Activities, as may be suitable to the Divisions of Work involved, will be identified

for single-unit Work. This requirement applies to such scope as Work in mechanical rooms, building framing, commissioning, etc.

3. Activities will not combine separate or non-concurrent items of Unit Price or lump sum Work, Work in separate structures and Work in distinct areas, locations or floors within an area or structure; or rough-in and finish Work.

D. Activity durations will equal the Business Days required to sufficiently complete the Work designated by the Activity (i.e., when finish-to-start successors may start, even if the Activity is not quite 100% complete). Installation Activities will last from twenty (20) to forty (40) Days.

E. Activities will be assigned consistent descriptions and identification codes. Sort codes will group Activities by building or structure, floor or area, Change Order and Change Authorization and other meaningful schemes.

2.13 FLOAT TOLERANCES

A. Any Progress Schedule with Early Dates after a Contract Time will yield negative Total and Contract Floats, whether shown/calculated or not. Any Revision Submittal with less than negative twenty (20) Days of Float will be returned as "Revise and Resubmit," unless a time extension is requested, or the **Owner** withholds liquidated damages or asserts intent to do so in the event schedule is not recovered.

B. Floats calculated from the definitions given in Section 00020 Glossary supersede any conflicting Float values calculated within any early completion Progress Schedule.

2.14 REVISION 0 (Rev. 0) SUBMITTAL

A. The complete Revision 0 Submittal will be due with the first Request for Payment. The Rev. 0 Submittal will show the Work as awarded, without Delays, "or equal" or substitutions, Change Orders or Change Authorizations.

1. The Rev. 0 narrative will detail the **Contractor's** management of the site (lay down, parking, etc.). Further, the Rev. 0 narrative will identify shifts, weekend Work, Activity calendars, Delays since award and all pending and anticipated "or equal" and substitution proposals.

B. Once endorsed by the **Owner** and returned as "Resubmittal Not Required," the Rev. 0 Progress Schedule (or Rev. 0A, etc.) will be the As-Planned Schedule and the basis for Update Submittals until the Rev. 1 Official Schedule is established. Once the As-Planned Schedule is established, the **Owner** will select Milestones and note Milestone Early and Late Dates. As the Official Schedule evolves, Milestone Dates will be revised accordingly.

D. If the **Owner** refuses to endorse the Rev. 0 Submittal (or Rev. 0A, for a resubmission) as "Resubmittal Not Required," the As-Planned Schedule will not be established. In that event, the **Contractor** will continue to submit Update and Revision Submittals reflecting progress and the **Contractor's** approach to remaining Work. The **Owner** will rely on the available Update and Revision Submittals, subject to whatever adjustments it determines appropriate.

2.15 UPDATE SUBMITTALS

A. Update Submittals with progress up to the closing date and updated Early and Late Dates for progress and remaining Activities will be due with each Request for Payment. As-built data will consist of actual start dates, percent complete, actual finish dates, changes, Delays, and other significant events occurring before the closing date.

2.16 REVISION SUBMITTALS

A. Progress Schedule Revisions will be submitted with the third Request for Payment and every two (2) months after that, or more often, if necessary due to schedule recovery or other Progress Schedule revisions. Revisions will revise the Update Submittal attached to the prior Request for Payment.

B. Progress Schedule revisions will detail all impacts on pre-existing Activity scope, logic ties and restraint dates and reflect the Contractor's current approach to Work remaining. Revisions may be required because of changes in the Work, substitutions, schedule recovery and Delays.

C. Once endorsed by the **Owner** and returned as "Resubmittal Not Required," a Revision Submittal becomes the Rev. 1, Rev. 2, etc. Official Schedule and the basis for subsequent Update Submittals until a more current Official Schedule is established. If the **Owner** refuses to endorse a Revision Submittal as "Resubmittal Not Required," the **Contractor** will continue to submit Update and Revision Submittals when and as required in this Section.

2.17 RETROSPECTIVE DELAY ANALYSIS

A. If the **Owner** refuses to endorse any Revision Submittal as "Resubmittal Not Required," the **Contractor** and **Owner** will use the latest Official Schedule when evaluating the effect of Delays on Contract Time and/or Contract Price. The procedure will consist of progressively revising the latest Official Schedule at key Revision Submittal closing dates. For each Progress Schedule iteration, slippage between actual Milestone Dates and Rev. 0 Milestone Dates will be correlated to Delays occurring solely in that iteration. Revisions affecting Work after any iteration will be included only to the extent consented by the **Owner** at that time and/or if confirmed by as-built progress.

3. **Shop Drawings:** The Contractor shall deliver shop drawings of products, materials, assemblies, or equipment to the Professional as required by the specifications.
4. **Samples:** The Contractor must deliver all samples of material or equipment to the job site for examination by the State Agency and the Professional. Samples will be examined by the Professional for conformance with the design concept of the Project and for compliance with the information given in the Contract Documents.

The Contractor must furnish all Work in accordance with approved samples. The following general classifications of material and equipment require submission of samples. Samples of other items may be requested by the Professional at any time.

| <u>Item of Work</u> | <u>Type of Sample</u> | <u>Section Number</u> |
|--------------------------|-----------------------|-----------------------|
| Unit Masonry | Sample Units | 04200 |
| Stone | Sample Units | 04400 |
| RFA Board Insulation | Sample Units | 07220 |
| Fiberglass Shingles | Color Samples | 07312 |
| Gutters and Downspouts | Sample Units | 07631 |
| Ceramic Tile | Sample Panel | 09310 |
| Ceramic Mosaics | Sample Panel | 09320 |
| Quarry Tiles | Sample Units | 09330 |
| Terrazzo Bonded | Color Plates | 09411 |
| Plastic Matrix Terrazzo | Color Plates | 09440 |
| Epoxy Terrazzo | Color Plates | 09441 |
| Acoustical Ceilings | Sample Units | 09510 |
| Resilient Flooring | Sample Units | 09650 |
| Carpeting | Sample Units | 09680 |
| Special Flooring | Sample Panels | 09700 |
| Seamless Quartz Flooring | Sample Panels | 09721 |
| Coating System | Color Samples | 09872 |
| Painting | Color Samples | 09900 |

END OF SECTION 01300

SECTION 01400 QUALITY CONTROL

1. **Testing Laboratory Services:** All tests required by the Owner must fulfill ASTM, ANSI, Commercial and other Standards for testing. The Contractor must submit a minimum of three copies of each test report to the Professional for evaluation and subsequent distribution. The following general classifications of Work require submission of test reports and/or certificates of inspection. Additional submissions may be requested by the Professional at any time.

| <u>Item of Work</u> | <u>Test Type</u> | <u>Section Number</u> |
|------------------------------|------------------------|-----------------------|
| Earthwork | Compaction and Density | 02200 |
| Portland Cement Conc. Paving | Core Analysis | 02512 |
| Asphaltic Concrete Paving | Core Analysis | 02513 |
| Cast-in-place Concrete | Compression Tests | 03300 |

2. **Tests:**

- (a) Paid by Owner: N/A
- (b) Paid by Contractor: N/A

3. **Concrete/Asphalt Materials:** Before placement of any concrete, the Contractor must submit for the Professional's approval complete data on the trial concrete mix formulation and a testing laboratory report for ASTM C94, twenty-eight-day standard cylinder test for compressive strength of a sample of the concrete mix. For asphalt paving, the Contractor must submit the data and testing reports for ASTM D946, AC-5. The mix must have 4.5 to 6 percent of asphalt cement by weight for binder course and 5 to 7 percent of asphalt cement by weight for surface course in accordance with Asphalt Institute Manual MS-4, MS-13, and the current Michigan Department of Transportation (MDOT) Standard Specifications for Construction.

- (a) The Contractor must furnish to the Professional tickets showing mix formulation, Contractor's name, Project name, mix identification for each load of concrete/asphalt delivered and installed. If the technical specifications allow added water to the concrete mix after leaving the batch plant, the delivery ticket must reflect the added water. The Owner Field Representative must receive a copy of each delivery ticket for transmittal to the Professional for evaluation.
- (b) The Professional may require the Contractor to core drill questionable cast-in-place concrete/asphalt for laboratory testing. Should the laboratory analysis indicate the concrete/asphalt fails to meet specification requirements, the Contractor must pay all costs for core drilling and testing in the laboratory and replace the concrete/asphalt found to fail meeting the specification requirements.

Should the laboratory analysis confirm that the concrete/asphalt meets specification requirements, the Owner will pay the Contractor for their costs for core drilling, concrete/asphalt patching and the laboratory fee for testing of the concrete/asphalt core samples.

END OF SECTION 01400

SECTION 01500 CONSTRUCTION FACILITIES AND TEMPORARY CONTROLS

1. The Contractor must furnish and install all temporary facilities and controls required by the Work, must remove them from State property upon completion of the Work, and the grounds and existing facilities must be restored to their original condition.
2. If water or electricity is available in the area where Work will be performed, the Contractor will not be charged for reasonable use of these services for construction operation. The Contractor must pay costs for installation and removal of any temporary connections including necessary safety devices and controls. Use of services must not disrupt or interfere with operations of the State Agency.
3. **Temporary Sanitary Facilities:**
 - (a) **Portable Toilets:** The Contractor must provide and maintain a sufficient number of portable temporary toilets in locations approved by the State Agency. They must comply with all Federal, State, and local code requirements. The Contractor must maintain the temporary toilets in a sanitary condition at all times and must remove them when the Work under this Contract is complete. The Contractor's employees are not allowed to use any existing State toilet facility.
 - (b) **State Toilets:** If available, the State Agency will designate a permanent toilet facility on the premises for use by personnel employed in the Work. The Contractor must repair any damage to the toilet facility caused by their employees and maintain it in a clean and sanitary condition.
4. **Field Office:**
 - (a) **On Site Trailer:** At the beginning of the Work, the Contractor may provide a field office and storage building at the site in a location acceptable to the Owner. The building may be a trailer. The Contractor may provide such other temporary buildings as he may require for the use of workers and safe storage for tools and materials. Job signs with the Contractor's name, logos, specialty, ... etc., are not allowed.

END OF SECTION 01500

SECTION 01600 MATERIAL AND EQUIPMENT

1. The Contractor must furnish and be responsible for all materials, equipment, facilities, tools, supplies and utilities necessary for completing the Work. All materials and equipment must be provided as described in the Contract Documents and of good quality, free of defect and new and must be applied, installed, connected, erected, used, cleaned and conditioned following the manufacturer's and Suppliers' instructions.
2. **Delivery, Storage, and Handling:** All materials and equipment delivered to and used in the Work must be suitably stored and protected from the elements. The areas used for storage must only be those approved by the State Agency. The Owner assumes no responsibility for stored material. The ownership and title to materials will not be vested in the Owner before materials are incorporated in the Work unless payment is made by the Owner for stored materials and equipment. After delivery, before and after installation, the Contractor must protect materials and equipment against theft, injury, or damage from all causes. For all materials and equipment, the Contractor must provide complete information on installation, operation, and preventive maintenance.
 - (a) The Contractor must cover and protect bulk materials while in storage which are subject to deterioration because of dampness, the weather or contamination. The Contractor must keep materials in their original sealed containers, unopened, with labels plainly indicating manufacturer's name, brand, type, and grade of material and must immediately remove from the Work site containers which are broken, opened, watermarked and/or contain caked, lumpy, or otherwise damaged materials.
 - (b) The Contractor must keep equipment stored outdoors from contact with the ground, away from areas subject to flooding and covered with weatherproof plastic sheeting or tarpaulins.

(b) The Contractor must certify that any materials stored off-site are:

- a) Stored on property owned or leased by the Contractor or owned by the agency.
- b) Insured against loss by fire, theft, flood, or other hazards.
- c) Properly stored and protected against loss or damage.
- d) In compliance with the plans and specifications.
- e) Specifically allotted, identified, and reserved for the project.
- f) Itemized for tracking and payment.
- g) Subject to these conditions until the items are delivered to the project site.

END OF SECTION 01600

SECTION 01650 FACILITY START-UP

1. **Tests:** The complete installation consisting of the several parts of equipment and systems installed according to the requirements of the Contract Documents must be ready in all respects for use by the State Agency and must be subjected to a test at full operating conditions and pressures for normal conditions of use.
2. **Adjustments:** Contractor must adjust and replace the Work which is necessary to fulfill the requirements of the Contract Documents and to comply with the directions and recommendations of the manufacturer of the several parts of equipment, and to comply with all provisions of architectural and/or engineering drawings/specifications and all codes and regulations which may apply to the entire installation.
3. **Demonstration:** Contractor must provide an on-site demonstration and training of all systems operations to the Owner when it is substantially completed.

END OF SECTION 01650

SECTION 01700 CONTRACT CLOSE-OUT

1. **Substantial Completion:** The Contractor must notify the Professional, the Project Director and the Agency when the Work will be substantially complete. If the Professional, Owner, and Agency agree that the project is Substantially Complete, the Professional and Project Director will inspect the Work. The Professional, upon determining that the Work, or a portion of the Work inspected, is substantially complete, will prepare a Punch List and will attach it to the respective Certificate of Substantial Completion. The Contractor must be represented on the job site at the time this inspection is made and thereafter must complete all Work by the date set for final acceptance by the Owner.
2. **Cleaning:**
 - (a) **Regular Cleaning:** The Contractor must remove all scrap or removed material, debris, or rubbish from the Project work site at the end of each working day and more frequently whenever the Owner Field Representative deems such material to be a hazard. The Contractor cannot discard materials on the grounds of the State Agency without the express permission of the Project Director. No salvage or surplus material may be sold on the premises of the State Agency. No burning of debris or rubbish is allowed. Any recyclable materials must be recycled, and the Contractor will be required to provide recycling plan.
 - (b) **Final Cleaning:** Before final acceptance by the State, the Contractor must clean all Work and existing surfaces, building elements and contents that were soiled by their operations and make repairs for any damage or blemish that was caused by the Work.

END OF SECTION 01700

SECTION 01800 MAINTENANCE

1. The Contractor is responsible for maintaining the new components parts of Work in good order and proper working conditions and must take all necessary actions for their protection until they are placed for use by the Owner.

END OF SECTION 01800

APPENDIX I

GLOSSARY

GLOSSARY

Activity– An element in the Progress Schedule establishing a requisite step, or the time and resources required, for completing the part of the Work associated with that Activity.

Addenda– Written instruments that are used by the Owner and/or Professional to incorporate interpretations or clarifications, modifications, and other information into the Bidding Documents. An Addendum issued after Bid opening to those Bidders who submitted a Bid, for the purpose of re-bidding the Work without re-advertising, is referred to as a **post-Bid Addendum**.

Agency- Any unit, section, division, department, or other instrumentality of the State that benefits from the Work.

Alternate– Refers to work specified in the Bidding Documents for which the Bidder must bid a Bid Price.

Apparent Low Bidders: Those Bidders whose Base Bid, when added to those specific Alternates the Owner intends to accept, yields the three lowest sums of Bid and Alternates. Additional Bidders may be considered Apparent Low Bidders if their Bid, when added to those specific Alternates the Owner intends to accept, yields a sum within 10% of the lowest of the Apparent Low Bidder's sum. If a qualified disabled veteran meets the requirements of the contract solicitation, provides acceptable responses to both Part One and Part Two of the Best Value Construction Bidder Evaluation to achieve a Best Value recommendation and with the veteran's preference is the lowest responsive, responsible, best value Bidder it is considered the Apparent Low Bidder.

Archaeological Feature– Any prehistoric or historic deposit of archaeological value, as determined by a representative of a State Agency that is duly authorized to evaluate such findings and render such judgments. An Archaeological Feature deposit may include, but is not limited to Indian habitations, ceremonial sites, abandoned settlements, treasure trove, artifacts, or other objects with intrinsic archaeological value and that relate to the history and culture of the State of Michigan.

Authorized Technical Data– Information and data contained in a report of exploration and tests of subsurface conditions. Also, any physical data (dimension, location, conditions, etc.) contained in those Drawings of physical conditions of existing surface and subsurface facilities.

Best Value- The bids will be evaluated for best value based on price and qualitative components that may include but are not limited to technical design, technical approach, quality of proposed personnel, and management plans, per PA 430 of 2012.

Bid– Written offer by a Bidder for the Work, as specified, which designates the Bidder's Base Bid and Bid Prices for all Alternates. The term *Bid* includes a *re-bid*.

Bidder– The Person acting directly, or through an authorized representative, who submits a Bid directly to the **Owner**.

Bidding Documents– The proposed Contract Documents as advertised, and all Addenda issued before execution of the Contract.

Bid Price– The Bidder's price for a lump sum item of work, or the product of the Bidder's unit price for an item of Unit Price Work times the quantity given on the Bid Form for that item.

Bid Security– A security serving as a guarantee that the Bidder will conform to all conditions.

Bidding Requirements–The Advertisement, Instructions to Bidders, Supplementary Instructions, Information for Bidders, Bid Form, Bid Form Attachments, and qualification submittals, as advertised and as modified by Addenda, and any other Section included within Division 0 of the Bidding Documents for the purpose of governing bidding and award of the Contract.

Board– The Administrative Board of the State of Michigan.

Bond– Security furnished by the **Contractor**, as required by the Contract Documents.

Business Day– Any Day except Saturdays, Sundays and holidays observed by the **Owner**.

Bulletin– A request used by the **Owner** to describe a change in the Work under consideration by the **Owner** and to request the **Contractor** to submit a proposal for the corresponding adjustment in Contract Price and/or Contract Time, if any.

Calendar Day– Every day shown on the calendar, Saturdays, Sundays, and holidays included.

Cash Allowance– An **Owner**-specified sum included within the Contract Price to reimburse the **Contractor** for the actual purchase/furnished cost of materials and/or equipment or other designated items, as specifically provided in the Contract Documents. Although the scope (e.g., the required quantity) of any Work covered by a Cash Allowance is sufficiently detailed in the Contract Documents for the purposes of bidding the required labor costs, Subcontract costs, construction equipment costs and general conditions costs and Fee, it is understood that the required materials, equipment or other designated items are of uncertain purchase cost at the time of Bid or are yet to be specified in more detail by the **Professional** as to quality, appearance, durability, finish and such other necessary features affecting purchase price.

Change Order– A written order issued and signed by the **Owner**, which amends the Contract Documents for changes in the Work or an adjustment in Contract Price and/or Contract Time, or both.

Construction Mechanic– A skilled or unskilled mechanic, laborer, worker, helper, assistant, or apprentice working on a state project but shall not include executive, administrative, professional, office, or custodial employees.

Contract Award– The official action of the **Board**, the **Director-SFA** or the **Director-DCD** awarding the Contract to the **Contractor**.

Contract Documents– Written and graphic documents that form the legal agreement between the **Owner** and the **Contractor**, consisting of this document, completed Bid and Contract forms, terms and conditions of the contract, specifications, drawings, addenda, Notice of Award, Notice-to-Proceed and contract change orders.

Contract Price– The total compensation, including authorized adjustments, payable by the **Owner** to the **Contractor** (subject to provisions for Unit Price Work).

Contract Times–The Contract Times for the entire Work are the periods allowed, including authorized adjustments, for Substantial Completion and final completion of the Work. The Contract Times for a designated portion of the Work are the periods allowed for Substantial Completion and final completion of any such portion of the Work, as specified in the Contract Documents.

Contractor– Business enterprise with which the **Owner** has entered into the Contract.

Correction Period– A period during which the **Contractor** must, in accordance with the Contract Documents, (a) correct or, if rejected, remove, and replace Defective Work, and (b) maintain warranties for materials and equipment in full force and effect.

Cost of the Work Involved– The sum of all costs that would be, or were, necessarily incurred by the **Contractor** in providing any Work Involved with the related change, less the costs that would be, or would have been, incurred by the **Contractor** to provide such Work without the related change.

Defective– As determined by the Professional, an adjective which when referring to or when applied to the term “Work” refers to (a) Work not conforming to the Contract Documents or not meeting the requirements of an inspection, test, or approval, or (b) Work itemized in a Punch List which the **Contractor** fails to complete or correct within a reasonable time after issuance of the Punch List by the **Professional**.

Delay– Any act or omission or other event that in any manner adversely affects or alters the schedule, progress or completion of all or any part of the Work. Delay is a generic term intended to include deferral, stoppage, slow down, interruption and extended performance, and all related hindrance, rescheduling, disruption, interference, inefficiency and productivity and production losses.

Department (DTMB)– Department of Technology, Management and Budget of the State of Michigan.

Director- The Director of the **Department**.

Director-SFA- The Director of **DTMB** State Facilities Administration.

Director-DCD- The Director of **DTMB** State Facilities Administration, Design and Construction Division.

Division– Each of the numbered, distinct parts (starting with Division 0) into which the Specifications are divided.

Drawings– Part of the Contract Documents showing the Work. Drawings must neither serve nor be used as Shop Drawings.

Emergency– A condition affecting the safety or protection of persons, or the Work, or property at or adjacent to the site.

State Facilities Administration (SFA)-Entity in the **Department** responsible for design, construction, and operations and maintenance of facilities.

Fee for the Work Involved (Fee)– An established, percentage mark-up on the Cost of the Work Involved which is allowed to the **Contractor** for (a) reasonable administrative costs, and (b) negotiated, reasonable profit on the Cost of the Work Involved.

Hazardous Material– Asbestos containing materials (ACMs), Polychlorinated biphenyls (PCBs), petroleum products, such construction materials as paint thinners, solvents, gasoline, oil, etc., and any other like material the manufacture, use, treatment, storage, transportation, or disposal of which is regulated by federal, state, or local Laws governing the protection of public health, natural resources, or the environment.

Invitation To Bid (ITB) - The solicitation document presenting the terms and conditions that will become part of the Contract when the Bid is accepted.

Law(s)– Means federal, state, and local statutes, ordinances, orders, rules and/or regulations.

MCL– The Michigan Compiled Laws of the State of Michigan.

Means and Methods– Includes means, methods, techniques, sequences and/or procedures applicable to the Work.

Notice of Award– Written notice accepting the Bid to the lowest responsive, responsible Bidder and designating the Contract Price (and establishing the Alternates accepted by the **Owner**).

Notice-to-Proceed– Written notice issued by the Project Director directing the Contractor to commence the construction activities and establishing the start date of the Contract Time.

On-Site Inspection– The **Professional's** on-site examination of the **Contractor's** completed or in progress Work to determine and verify to the Project Director that the quantity and quality of all Work complies with the requirements of the Contract Documents.

Owner– The State of Michigan, with whom the **Contractor** has entered into the Contract and for whom the Work is to be provided.

Owner Field Representative– A State employee or consultant, acting collaboratively with the Project Director, providing on-site, periodic observation and documentation of the Work for compliance with the Contract Documents.

Partial Use– The use, by the **Owner**, of a designated portion of the Work before accomplishing Substantial Completion of the entire Work. Partial Use does not mean Substantial Completion of the portion of the Work placed in use by the **Owner**.

Person–Individuals, partnerships, corporations, receivers, trustees, joint ventures or any other legal entity and any combinations of any of them.

Political Subdivision– Any county, city, village, or other local unit of the State, including any agency, department, or instrumentality of any such county, city, village, or other local unit.

Post-Bid Submittal– A Qualification Submittal required of the Bidder selected under Section 00100 - 22 before Contract Award, and which is used by the Owner in the evaluation of the Bid of the selected Bidder.

Professional Services Contractor (PSC or Professional)– The individual or business entity who has the authority to practice the design disciplines required by the Contract Documents. An Agency with appropriate licensing may replace the PSC in their role if a consultant is not used.

Project– The total construction, which includes the Work and possibly other work completed by others, as indicated in the Contract Documents.

Project Director- Designated State employee(s) (a) Responsible for directing and supervising the **Professional's** services during the period allowed for completion of the Work; and/or (b) Acting as representative for the **Owner** and for the enforcement of the Contract Documents, approving payment to the **Contractor** and coordinating the activities of the State, **Owner, Professional** and **Contractor**.

Project Schedule– Work Schedule that shows the **Contractor's** approach to planning, scheduling, and execution of the Work and that accurately portrays completed Work as to sequencing and timing, as provided in the Contract Documents.

Project Specifications– The Contract Documents organized into Divisions. "Technical Specifications" means Divisions of the Specifications consisting of technical descriptions of materials, equipment, construction systems, standards, and workmanship.

Provisionary Allowance– An amount included within the Contract Price to reimburse the **Contractor** for the cost to furnish and perform Work that is uncertain because, for example, it is indeterminate in scope and may not be shown or detailed in the Contract Documents.

Punch List– A list of minor items to be completed or corrected by the **Contractor**, any one of which do not materially impair the use of the Work for its intended purpose.

Qualified Disabled Veteran (QDV)- QDV as defined by Public Act 22 of 2010, MCL 18.1241.3 and supported by a DD214 Proof of Service and Discharge, a Veterans Administration rating decision letter, proof of disability (if the disability is not indicated on the DD214), and appropriate legal documents setting forth the 51% natural persons QDV ownership.

Record Documents– Drawings, Specifications, Addenda, Change Orders, Change Authorizations, Bulletins, inspection, test and approval reports, photographs, written clarifications and interpretations and all other documents recording, or annotated to show, all revisions and deviations between the as-built installation and the Contract Documents, all approved Submittals and all clarifications and interpretations.

Records– Books, reports, documents, electronic data, and other evidence relating to the bidding, award and furnishing and performance of the Work.

Recycled Material– Recycled paper products, structural materials made from recycled plastics, re-refined lubricating oils, reclaimed solvents, recycled asphalt and concrete, recycled glass products, re-treaded tires, ferrous metals containing recycled scrap metals and all other materials that contain (a) waste materials generated by a business or consumer, (b) materials that have served their intended purpose, and/or (c) materials that have been separated from solid waste for collection, recycling and disposition in the percentage determined by the State as provided by Law.

Request for Payment– The form provided by the **Owner** (Payment Request DTMB-0440) to be used by the **Contractor** in requesting payment for Work completed, which must enclose all supporting information required by the Contract Documents.

Schedule of Values– A schedule of pay items, which subdivides the Work into its various parts and which details, for each itemized part, cost and pricing information required for making payments for Work performed. The sum of all pay item costs in the Schedule of Values must equal the Contract Price for the Work.

Shop Drawings– Includes drawings, diagrams, illustrations, standard schedules, performance charts, instructions and other data prepared by or for the **Contractor** to illustrate some part of the Work, or by a Supplier and submitted by the **Contractor** to illustrate items of material or equipment.

Soil Erosion and Sedimentation Control– The planning, design and installation of appropriate Best Management Practices designed and engineered specifically to reduce or eliminate the off-site migration of soils via water runoff, wind, vehicle tracking, etc. Soil erosion and sedimentation control in the State of Michigan is regulated under The Natural Resources Environmental Protection Act; Soil Erosion and Sedimentation Control, 1994 PA 451, Part 91, as amended, MCL 324.9101 et seq. Soil erosion and sedimentation control associated with this Contract is monitored and enforced by the DTMB-SFA.

State– The State of Michigan in its governmental capacity, including its departments, divisions, agencies, boards, offices, commissions, officers, employees, and agents. Non-capitalized references to a state refer to a state other than the State of Michigan.

State Construction Code– The Michigan State Construction Code Act, 1972 PA 230, as amended, MCL 125.1501 et seq.

Subcontractor– A Person having an agreement with the Contractor to provide labor at the site and furnishing materials and/or equipment for incorporation into the Work.

Submittals– Includes technical Submittals, Progress Schedules and those other documents required for submission by the Contract Documents. The term "technical Submittal" includes Shop Drawings, brochures, samples, Operation and Maintenance (O&M) Manuals, test procedures and any other Submittal the Contract Documents require the **Contractor** to submit to demonstrate how the items covered, after installation or incorporation into the Work, will conform to the information given in the Contract Documents and be compatible with the design of the completed Work as a functioning whole as indicated in the Contract Documents.

Substantial Completion– The Work, or a portion of the Work designated in the Contract Documents as eligible for separate Substantial Completion, has been completed in accordance with the Contract Documents as determined by the PSC, to the extent that the **Owner** can use or occupy the entire Work, or the designated portion of the Work, for the use intended without any outstanding, concurrent Work at the site, except as may be required to complete or correct Punch List items.

Supplier– A manufacturer or fabricator, or a distributor, material man or vendor representing a manufacturer or fabricator, who has an agreement with the Contractor to furnish materials and/or equipment.

Underground Utilities– Pipelines, piping, conduit, duct, cables, wells, tanks, tunnels and appurtenances, or other similar facilities, installed underground to convey or support conveyance of potable water, sprinkler or irrigation water, fire protection systems, electricity, gases, steam, petroleum products, sewerage and drainage removal, telephone, communications, cable TV, traffic, or control systems.

Unit Price Work– The work involving specified quantities (i.e., related Work quantities) which, when performed, is measured by the **Professional** and paid using the measured quantities and unit prices contained in the Contract Documents. Performance of Unit

Price Work for undefined quantities is contingent upon conditions encountered at the site, as determined, and authorized by the **Professional**.

Unit Price Work, Specific– Work of specified and defined quantities (i.e., quantities are detailed in, and can be taken-off from, the Contract Documents) that when performed is measured by the **Professional** and paid based on the measured quantities and unit prices contained in the Contract Documents.

Work- (as in “*the Work*,” “*the entire Work*”)– The entire *completed Construction* required by the Contract Documents. The Work results from furnishing and performing all services, obligations, responsibilities, management, supervision, labor, materials, equipment, construction equipment, general conditions, permits, taxes, patent fees and royalties, testing, inspection and approval responsibilities, warranties, temporary facilities, small tools, field supplies, Bonds, insurance, mobilization, close-out, overhead and all connections, devices and incidental items of any kind or nature required and/or made necessary by the Contract Documents.

Work Involved, any Work Involved– Existing or prospective Work (a) reflected in any notice, proposal, or claim, or (b) reflected in changes ordered or in process, or (c) affected by Delay

APPENDIX II
SPECIAL WORKING CONDITIONS

DTMB State Facilities Administration
Security Clearance Request

Contractor Instructions

The purpose of this document is to establish security and supervision requirements for contract personnel requiring access to Department of Technology, Management and Budget (DTMB) facilities.

A DTMB Security Clearance form must be completed before an individual is granted access to a facility. Access approval will be in effect for one year from date of DTMB Facility Services approval or until estimated project completion date (whichever occurs first).

Contract personnel agree to adhere to all DTMB rules and regulations which in DTMB facilities. Access will only be granted for normal business hours. (Monday-Friday, 8:00 a.m.-5:00 p.m. except State holidays). DTMB State Facilities Administration, Facility Services section must clear any exception in advance.

Contract personnel will be required to submit the following to DTMB Facility Services Manager or Regional Manager before entering a DTMB facility:

Procedure for submitting form electronically (preferred and recommended)

1. Complete a *DTMB Security Clearance form* (using Microsoft Excel) and include the following:
 - Company name
 - Company Contact name and phone number
 - Complete name (**last name first**) and date of birth for all employees requiring access.
2. Email completed form to DTMB Facility Manager for an individual building or DTMB Regional Facility Manager for multiple building requests.

Procedure for submitted in person or mail delivery

1. Complete a *DTMB Security Clearance form* (using Microsoft Excel) and include the following:
 - Company name
 - Company Contact name and phone number
 - Complete name (**last name first**) and date of birth for all employees requiring access.
2. Return completed form to DTMB Facility Manager for an individual building or DTMB Regional Facility Manager for multiple building requests.

Note: This request must be received a minimum of 48 hours before entering a DTMB Facility.

DTMB Facility Access Criteria:

1. Present pictured ID.
2. Name must appear on the clearance list.
3. Sign-in and wear a dated visitor's pass (*must be visibly displayed at all times*).
4. Return visitor pass to security desk at days end.

Note: Individuals whose name does not appear on the clearance list are required to be signed in by a member of the DTMB Facility Services staff.

Failure to comply with the above procedure will result in the individual(s) being delayed and may be cause for denying access to DTMB facilities.

APPENDIX III
SPECIAL PROJECT PROCEDURES

DEMOLITION/REMODELING PROJECT PROCEDURES

Furnish all equipment, materials, labor, and services necessary to complete all building demolition required in connection with the existing building, in order to permit the installation of new Work. The goal of the Owner is to generate the least amount of waste or debris possible. However, inevitable waste and debris that are generated shall be reused, salvaged, or recycled, and disposal in landfills shall be minimized to the extent economically feasible. The Contractor will be required to prepare waste management plan for the collection, handling, storage, transportation, and disposal of the waste generated at the construction site for the Owner's review and approval. The Contractor will be required to produce waste management progress reports.

1. Locations: Notations are made in various places on the Drawings to call attention to building demolition which is required; however, these Drawings are not intended to show every item to be removed. The Contractor and the Subcontractors for the various trades must remove the materials related to their respective trades as required to permit the construction of the new Work as shown.
2. Permits: The Contractor must secure from the appropriate agencies all required permits necessary for proper execution of the work before starting work on the project site. All fees for securing the permits must be paid by the Contractor, including all inspection costs which may be legally assessed by the Bureau of Construction Codes in accordance with the authority granted under the Public Act 1980 PA 371, as amended.
3. Enclosures: Where it is necessary to make alterations to walls, floors or roof of the existing building, the Contractor must provide and maintain dustproof partitions to separate the parts where Work is being done from the adjoining parts occupied by the State Agency. Where any parts are opened and exposed to the elements, the Contractor must provide weather tight enclosures to fully protect the structure and its contents.
4. Waste Management Plan: The management plan must address waste source identification and separation, returns, reuse and salvage, recycling, landfill options, alternatives to landfilling, materials handling procedures and transportation.
5. Preparation: Protect all existing Work that is to remain and restore in an approved manner any such Work that becomes damaged.
 - 5.1 Rubbish and debris resulting from the Work must be removed immediately from the site by the Contractor. However, any recyclable materials must be recycled; the Contractor will be required to use alternatives to landfills for waste disposal such as reuse or recycle of asphalt, bricks, concrete, masonry, plastics, paint, glass, carpet, metals, wood, drywall, insulation, and any other waste materials to the extent practical.
 - 5.2 Unless otherwise specified, the Agency will remove existing furniture, drapery tracks, draperies, window blinds, and other equipment items, which might interfere with the new construction.
6. Coordination: Demolition work, in connection with any new unit of Work, must not be commenced until all new materials required for completion of that new item of Work are at hand.
7. Waste Management Plan Progress Reports: Submit an updated report with the payment requests. The progress reports shall include:
 - a. The amount of waste sent to a landfill, tipping fees paid and the total disposal cost. Include supporting documents such as manifests, weight tickets, receipts and/or invoices.
 - b. Records for each material recycled/reused/salvaged from the project including the amount, date removed from the job site, destination, transportation cost, recycled materials, and the net cost/ savings.
 - c. Breakdown of waste by type generated to date.
 - d. Recycling/salvage/landfill rates.
 - e. Percent of waste recycled/salvaged to date.

HAZARDOUS MATERIALS PROJECT PROCEDURES

1. The Contractor must use, handle, store, dispose of, process, transport and transfer any material considered a Hazardous Material in accordance with all federal, state, and local Laws. If the Contractor encounters material reasonably believed to be a Hazardous Material and which may present a substantial danger, the Contractor must immediately stop all affected work, give written notice to the Owner of the conditions encountered, and take appropriate health and safety precautions.
2. This project has been identified by the DTMB-SFA as having a possibility of containing Hazardous Waste materials to be legally removed from the Project job site to complete the Work as described in the Proposal and Contract. If removal of friable asbestos material is required, the Contractor must contact the Air Quality Division, Department of Environment, Great Lakes, and Energy, at **(517) 284-6773**, for a permit and furnish all training, labor, materials, services, insurance, and equipment necessary to carry out the removal operations of all Hazardous Materials from the Project job site, as identified by the Scope of Work, or encountered on the Project job site, in accordance with State and Federal Hazardous Waste Codes. A Contract Change Order will be written to modify the existing Contract to pay for the additional cost.
3. Environmental Hazards (air, water, land and liquid industrial) are handled by the Waste and Hazardous Materials Division, Michigan Department of Environment, Great Lakes, and Energy (EGLE) in carrying out the requirements of the Federal Environmental Protection Agency (EPA). For general information and/or a copy of the latest regulations and publications call (517) 335-2690.
4. The Michigan Occupational Safety and Health Administration (MIOSHA) provides protection and regulations for the safety and health of workers. The Department of Licensing and Regulatory Affairs provides for the safety of workers. The Department of Community Health provides for the health of workers (517/373-3740) (TDD 517/373-3573).
 - 4.1 Contractor must post any applicable State and/or Federal government regulations at the job site in a prominent location.
 - 4.2 Contractor must be responsible for training their workers in safe work practices and in proper removal methods when encountering hazardous chemicals.
5. Applicable Regulations:
 - 5.1 Natural Resources and Environmental Protection Act – PA 451 of 1994, as amended, including Part 111 – Hazardous Waste Management, Part 121 – Liquid Industrial Waste and Part 147 – PCB compounds.
 - 5.2 RCRA, 1976 - Resource Conservation and Recovery Act: This federal statute regulates generation, transportation, treatment, storage, or disposal of hazardous wastes nationally.
 - 5.3 TSCA, 1979 – Toxic Substances Control Act: This statute regulates the generation, transportation, storage, and disposal of industrial chemicals such as PCBs.
6. Definitions: Hazardous substances are ignitable, corrosive, reactive, and/or toxic, based on their chemical characteristics.
 - 6.1 Under Federal and Michigan Law, a Small Quantity Generator of hazardous waste provides from 220 to less than 2,000 lbs./month or never accumulates 2,200 lbs. or more.
 - 6.2 A Generator size provider of hazardous waste provides 2,200 lbs. or more/month or accumulates above 2,200 lbs.
7. Disposals: To use an off-site hazardous waste disposal facility, the Contractor must use the Uniform Hazardous Waste Manifest (shipping paper). Small quantities of hazardous waste may not be disposed of in sanitary landfills used for solid waste.
8. Federal, state, and local Laws and regulations may apply to the storage, handling and disposal of Hazardous Materials and wastes at each State Agency. Contact the **Environmental Assistance Center** of the Michigan Department of Environment, Great Lakes, and Energy (EGLE) at **1-800-662-9278**, Fax to: 517-241-0673 or e-mail to: DEQ-EAD-env-assist@michigan.gov for general EGLE information including direct and referral assistance on air, water and wetlands permits; contaminated site clean-ups; underground storage tank removals and remediation; hazardous and solid waste disposal; pollution prevention and recycling; and compliance-related assistance. The Center provides businesses, municipalities, and the public with a single point of access to EGLE's environmental programs.

ASBESTOS ABATEMENT PROJECT PROCEDURES

Should this Work require the renovation or demolition of a building or structure initially constructed on or prior to 1980, the Contractor will use the attached copy of a Comprehensive Asbestos Building Survey for those portions of the building or structure being impacted and must plan his or her work to minimize disturbance of any known or assumed asbestos containing materials (ACM). In addition, if this building or structure was constructed on or prior to 1980, the Contractor's On-Site Superintendent and all Subcontractor On-Site Superintendents for trades that could potentially disturb known or assumed ACM, must, as a minimum, have and provide documentation of current Asbestos Awareness Training.

If the Comprehensive Asbestos Building Survey identifies known or assumed ACM that will potentially be disturbed as a part of the Contractor's renovation or demolition activities, the Contractor must remove, transport, and dispose of these materials at no additional cost to the Owner and prior to any other work taking place within the immediate vicinity of said material. If required, the Contractor must provide the Owner a minimum of 10 working day notification prior to the start of any asbestos abatement activities with abatement in occupied buildings being completed even if they will be conducted during off hours (nights, weekends, and state holidays).

If the Contractor encounters a suspected ACM that was not previously identified within the Comprehensive Asbestos Building Survey, the Contractor must immediately stop all affected work, give written notice to the Owner of the conditions encountered, and take appropriate health and safety precautions. If, after providing Owner notification, the Contractor is directed to sample and/or remove the suspected ACM in question, a Contract Change Order will be written to modify the existing Contract to pay for the additional cost. Any abatement shall be completed in accordance with the requirements of this Section.

If removal of ACM is required, removal must be completed by a contractor currently licensed to remove asbestos by the State of Michigan, Department of Licensing and Regulatory Affairs (DLARA) Asbestos Program and abatement must be performed in accordance with all federal, state, and local Laws and Regulations. Prior to commencing any asbestos abatement activities, the licensed abatement contractor must submit, as required by Federal, State and Local Laws and Regulations, a "Notification of Intent to Renovate/Demolish" to both the State of Michigan, Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division and to the DLARA, Asbestos Program, to comply with National Emission Standards for Hazardous Air Pollutants (NESHAP), and the Clean Air Act (CAA). All regulated ACM must be disposed of at an approved Type II (general refuse) landfill and must be in leak-tight wrapping or containers. ACM that is non friable and is not in poor condition or will not become regulated ACM at any time can be disposed of in a Type III (construction debris) landfill.

At the completion of each abatement activity, the Contractor must perform clearance testing in accordance with National Institute for Occupational Safety and Health (NIOSH) 582 "Sampling and Evaluating Airborne Asbestos Dust". All air samples shall indicate concentrations of less than 0.01 fibers/cc for clearance to be met. Clearance testing shall be performed by a third-party Asbestos Consultant. The Asbestos Consultant selected by the Contractor shall be experienced and knowledgeable about the methods for asbestos air sampling and be able to select representative numbers and locations of samples. It is mandatory that the Asbestos Consultant's on-site hygienist performing sampling and analysis have certification that he/she has passed a NIOSH 582 or equivalent course.

The NESHAP asbestos regulations, notification form, guidelines and fact sheets are available on EGLE's web site www.michigan.gov/egle under heading Air; then click on Compliance; then click on Asbestos NESHAP Program. For guidelines on submitting notifications pursuant to the Asbestos Contractors Licensing Act, contact the DLARA, Occupational Health Division, Asbestos Program at (517) 322-1320 or visit DLARA's web site www.michigan.gov/asbestos.

LEAD ABATEMENT PROJECT PROCEDURES

Should this Work require the renovation or demolition of a building or structure, the workers are assumed to be exposed to lead or materials containing lead above acceptable levels until proven otherwise through personal air sampling and analysis. The Contractor shall take all steps necessary to assure that his/her employees, are not exposed to lead at concentrations greater than the Permissible Exposure Limit as per the State of Michigan Department of Licensing and Regulatory Affairs Occupational Health Standards Part 603 "Lead Exposure in Construction". In addition, the Contractor shall convey this same requirement to all subcontractors that may be under his/her control.

The employer shall comply with the Michigan Lead Abatement Act, as amended, and the Lead Hazard Control rules and must communicate information concerning lead hazards according to the requirements of Michigan Occupational Safety and Health Administration (MIOSHA) Part 603 and the Occupational Safety and Health Administration's (OSHA's) Hazard Communication Standard for the construction industry, 29 CFR 1926.59, including but not limited to safety equipment (e.g. personal fit-tested and approved respirators and protective clothing), worker rotation (on a short-cycle and regular basis), working practices (e.g. sanding, cutting, grinding, abraded, burning and heat-gun stripping of lead based paint are not allowed), the requirements concerning warning signs and labels, Safety Data Sheets (SDS), and employee information and training. Employers shall comply with the requirements of 29 CFR 1926.62(l) - Employee Information and Training.

If lead or materials containing lead will be disturbed as a part of the work to be performed, the Contractor must remove, transport, and dispose of these materials at no additional cost to the Owner and prior to any other work taking place within the immediate vicinity of said material. The Contractor must provide the Owner a minimum 10 working day notification prior to the start of any lead abatement activities with abatement in occupied buildings being completed even if they will be conducted during off hours (nights, weekends, and state holidays). Abatement is defined as an activity specifically designed to permanently remove lead paint, lead-contaminated dust or other lead containing materials, the installation of a permanent enclosure or encapsulation of lead paint or other lead containing materials, the replacement of lead-painted surfaces or fixtures, the removal or covering of lead-contaminated soil, and any preparation, cleanup, disposal, and post-abatement clearance testing associated with these activities. Renovation, remodeling, landscaping, or other activity, that is not designed to permanently eliminate lead paint hazards, but is instead designed to repair, restore, or remodel a structure, or housing unit even though the activity may incidentally result in a reduction or elimination of a lead paint hazard is not considered abatement.

If abatement of lead or materials containing lead is required, abatement must be completed by a qualified Lead Abatement Contractor. In addition, Specifications for the Lead Abatement should be based upon a Lead Inspection/Risk Assessment report. The Lead Inspection/Risk Assessment report and clearance testing upon completion should be performed by a Certified Inspector or Risk Assessor. Lead abatement including clearance testing shall be performed in accordance with the State of Michigan, Lead Abatement Act, Part 54A Lead Abatement and with all other federal, state, and local Laws and Regulations that may apply.

For additional information about certifications, guidance, and regulations for lead hazard control activities, visit www.michigan.gov/lead.

APPENDIX IV
PREVAILING WAGE RATE SCHEDULES

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--|-------------------|-----------------|-------------|
| 3.1 Power Equip. Operator - Highway & Heavy | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$71.46 | \$94.57 | \$117.67 |
| Apprentice: Level 1 0 - 6 Months | \$57.61 | \$73.79 | \$89.97 |
| Apprentice: Level 2 7 -12 Months | \$59.93 | \$77.28 | \$94.61 |
| Apprentice: Level 3 13 - 18 Months | \$62.23 | \$80.73 | \$99.21 |
| Apprentice: Level 4 19 - 24 Months | \$64.54 | \$84.19 | \$103.83 |
| Apprentice: Level 5 25 - 30 Months | \$66.85 | \$87.66 | \$108.45 |
| Apprentice: Level 6 31 - 36 Months | \$69.15 | \$91.10 | \$113.05 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--|-------------------|-----------------|-------------|
| 3.2 Power Equip. Operator - Highway & Heavy | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$70.31 | \$92.84 | \$115.37 |
| Apprentice: Level 1 0 - 6 Months | \$56.81 | \$72.59 | \$88.37 |
| Apprentice: Level 2 7 -12 Months | \$59.06 | \$75.97 | \$92.87 |
| Apprentice: Level 3 13 - 18 Months | \$61.31 | \$79.35 | \$97.37 |
| Apprentice: Level 4 19 - 24 Months | \$63.56 | \$82.72 | \$101.87 |
| Apprentice: Level 5 25 - 30 Months | \$65.81 | \$86.09 | \$106.37 |
| Apprentice: Level 6 31 - 36 Months | \$68.06 | \$89.47 | \$110.87 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--|-------------------|-----------------|-------------|
| 3.3 Power Equip. Operator - Highway & Heavy | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$63.58 | \$82.75 | \$101.91 |
| Apprentice: Level 1 0 - 6 Months | \$52.10 | \$65.53 | \$78.95 |
| Apprentice: Level 2 7 -12 Months | \$54.02 | \$68.41 | \$82.79 |
| Apprentice: Level 3 13 - 18 Months | \$55.92 | \$71.26 | \$86.59 |
| Apprentice: Level 4 19 - 24 Months | \$57.84 | \$74.14 | \$90.43 |
| Apprentice: Level 5 25 - 30 Months | \$59.75 | \$77.00 | \$94.25 |
| Apprentice: Level 6 31 - 36 Months | \$61.67 | \$79.89 | \$98.09 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--|-------------------|-----------------|-------------|
| 3.4 Power Equip. Operator - Highway & Heavy | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$63.02 | \$81.91 | \$100.79 |
| Apprentice: Level 1 0 - 6 Months | \$51.70 | \$64.93 | \$78.15 |
| Apprentice: Level 2 7 -12 Months | \$53.59 | \$67.76 | \$81.93 |
| Apprentice: Level 3 13 - 18 Months | \$55.48 | \$70.60 | \$85.71 |
| Apprentice: Level 4 | \$57.36 | \$73.42 | \$89.47 |
| Apprentice: Level 5 25 - 30 Months | \$59.25 | \$76.25 | \$93.25 |
| Apprentice: Level 6 31 - 36 Months | \$61.13 | \$79.07 | \$97.01 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--|-------------------|-----------------|-------------|
| 3.5 Power Equip. Operator - Highway & Heavy | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$44.80 | \$60.98 | \$77.15 |
| Apprentice: Level 1 0 - 6 Months | \$35.09 | \$46.42 | \$57.73 |
| Apprentice: Level 2 7 -12 Months | \$36.71 | \$48.84 | \$60.97 |
| Apprentice: Level 3 13 - 18 Months | \$38.33 | \$51.27 | \$64.21 |
| Apprentice: Level 4 19 - 24 Months | \$39.95 | \$53.71 | \$67.45 |
| Apprentice: Level 5 25 - 30 Months | \$41.57 | \$56.13 | \$70.69 |
| Apprentice: Level 6 31 - 36 Months | \$43.18 | \$58.55 | \$73.91 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---|-------------------|-----------------|-------------|
| 4.1 Power Equip. Operator - Commercial | 10/31/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$71.22 | \$94.21 | \$117.19 |
| Apprentice: Level 1 0 - 6 Months | \$57.43 | \$73.52 | \$89.61 |
| Apprentice: Level 2 7 - 12 Months | \$59.73 | \$76.97 | \$94.21 |
| Apprentice: Level 3 13 - 18 Months | \$62.03 | \$80.42 | \$98.81 |
| Apprentice: Level 4 19 - 24 Months | \$64.32 | \$83.86 | \$103.39 |
| Apprentice: Level 5 25 - 30 Months | \$66.62 | \$87.31 | \$107.99 |
| Apprentice: Level 6 31 - 36 Months | \$68.92 | \$90.76 | \$112.59 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---|-------------------|-----------------|-------------|
| 4.2 Power Equip. Operator - Commercial | 10/31/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$70.93 | \$93.77 | \$116.61 |
| Apprentice: Level 1 0 - 6 Months | \$57.22 | \$73.21 | \$89.19 |
| Apprentice: Level 2 7 - 12 Months | \$59.51 | \$76.65 | \$93.77 |
| Apprentice: Level 3 13 - 18 Months | \$61.80 | \$71.52 | \$89.80 |
| Apprentice: Level 4 19 - 24 Months | \$64.07 | \$83.48 | \$102.89 |
| Apprentice: Level 5 25 - 30 Months | \$66.36 | \$86.92 | \$107.47 |
| Apprentice: Level 6 31 - 36 Months | \$68.64 | \$90.33 | \$112.03 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---|-------------------|-----------------|-------------|
| 4.3 Power Equip. Operator - Commercial | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$70.11 | \$92.55 | \$114.97 |
| Apprentice: Level 1 0 - 6 Months | \$56.66 | \$72.37 | \$88.07 |
| Apprentice: Level 2 7 - 12 Months | \$58.90 | \$75.73 | \$92.55 |
| Apprentice: Level 3 13 - 18 Months | \$61.14 | \$79.09 | \$97.03 |
| Apprentice: Level 4 19 - 24 Months | \$63.38 | \$82.45 | \$101.51 |
| Apprentice: Level 5 25 -30 Months | \$65.63 | \$85.82 | \$106.01 |
| Apprentice: Level 6 31 - 36 Months | \$67.87 | \$89.18 | \$110.49 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---|-------------------|-----------------|-------------|
| 4.4 Power Equip. Operator - Commercial | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$69.25 | \$91.25 | \$113.25 |
| Apprentice: Level 1 0 - 6 Months | \$56.05 | \$71.45 | \$86.85 |
| Apprentice: Level 2 7 - 12 Months | \$58.25 | \$74.75 | \$91.25 |
| Apprentice: Level 3 13 -18 Months | \$60.45 | \$78.06 | \$95.65 |
| Apprentice: Level 4 19 - 24 Months | \$62.65 | \$81.35 | \$100.05 |
| Apprentice: Level 5 25 - 30 Months | \$64.85 | \$84.66 | \$104.45 |
| Apprentice: Level 6 31 -36 Months | \$67.05 | \$87.96 | \$108.85 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---|-------------------|-----------------|-------------|
| 4.5 Power Equip. Operator - Commercial | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$68.28 | \$89.80 | \$111.31 |
| Apprentice: Level 1 0 - 6 Months | \$55.37 | \$70.44 | \$85.49 |
| Apprentice: Level 2 7 -12 Months | \$57.53 | \$73.68 | \$89.81 |
| Apprentice: Level 3 13 - 18 Months | \$61.83 | \$80.12 | \$98.41 |
| Apprentice: Level 5 25 - 30 Months | \$63.98 | \$83.35 | \$102.71 |
| Apprentice: Level 6 31 - 36 Months | \$66.13 | \$86.58 | \$107.01 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---|-------------------|-----------------|-------------|
| 4.6 Power Equip. Operator - Commercial | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$66.57 | \$87.24 | \$107.89 |
| Apprentice: Level 1 0 - 6 Months | \$54.17 | \$68.64 | \$83.09 |
| Apprentice: Level 2 7 -12 Months | \$56.24 | \$71.74 | \$87.23 |
| Apprentice: Level 3 13 - 18 Months | \$58.30 | \$74.82 | \$91.35 |
| Apprentice: Level 4 19 -24 Months | \$60.37 | \$77.93 | \$95.49 |
| Apprentice: Level 5 25 - 30 Months | \$62.44 | \$81.04 | \$99.63 |
| Apprentice: Level 6 31 - 36 Months | \$64.50 | \$84.13 | \$103.75 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---|-------------------|-----------------|-------------|
| 4.7 Power Equip. Operator - Commercial | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$59.26 | \$67.72 | \$84.72 |
| Apprentice: Level | \$54.15 | \$68.61 | \$83.05 |
| Apprentice: Level 1 0 - 6 Months | \$49.05 | \$60.95 | \$72.85 |
| Apprentice: Level 2 7 -12 Months | \$50.76 | \$63.52 | \$76.27 |
| Apprentice: Level 3 13 - 18 Months | \$52.46 | \$66.07 | \$79.67 |
| Apprentice: Level 5 25 - 30 Months | \$55.85 | \$71.16 | \$86.45 |
| Apprentice: Level 6 31 - 36 Months | \$57.55 | \$73.71 | \$89.85 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---|-------------------|-----------------|-------------|
| 4.8 Power Equip. Operator - Commercial | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$58.23 | \$74.72 | \$91.21 |
| Apprentice: Level 1 0 - 6 Months | \$48.34 | \$59.88 | \$71.43 |
| Apprentice: Level 2 7 -12 Months | \$49.99 | \$62.37 | \$74.73 |
| Apprentice: Level 3 13 - 18 Months | \$51.63 | \$64.82 | \$78.01 |
| Apprentice: Level 4 19 - 24 Months | \$53.29 | \$67.31 | \$81.33 |
| Apprentice: Level 5 25 - 30 Months | \$54.93 | \$69.78 | \$84.61 |
| Apprentice: Level 6 25 - 30 Months | \$56.59 | \$72.27 | \$87.93 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|-------------------------------|-------------------|-----------------|-------------|
| 5.1 Truck Driver Class | 01/05/2026 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$54.10 | \$70.52 | \$86.94 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--------------------------------|-------------------|-----------------|-------------|
| Articulated Hauler | 10/28/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$63.02 | \$81.91 | \$100.79 |
| Apprentice: Apprentice Level 1 | \$51.70 | \$64.93 | \$78.15 |
| Apprentice: Apprentice Level 2 | \$53.59 | \$67.76 | \$81.93 |
| Apprentice: Apprentice Level 3 | \$55.48 | \$70.60 | \$85.71 |
| Apprentice: Apprentice Level 4 | \$57.36 | \$73.42 | \$89.47 |
| Apprentice: Apprentice Level 5 | \$59.25 | \$76.25 | \$93.25 |
| Apprentice: Apprentice Level 6 | \$61.13 | \$79.07 | \$97.01 |

Four 10-hour days allowed? - No

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--|-------------------|-----------------|-------------|
| Asbestos abatement worker or environmental remediation worker | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$56.20 | \$73.24 | \$90.28 |
| Apprentice: Trainee 600 hours + 1 year | \$43.12 | \$55.01 | \$66.90 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|------------------------|-------------------|-----------------|-------------|
| Boilermaker | 10/29/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$79.64 | \$119.12 | \$158.58 |
| Apprentice: 1st Period | \$58.07 | \$86.78 | \$115.44 |
| Apprentice: 2nd Period | \$59.89 | \$89.50 | \$119.08 |
| Apprentice: 3rd Period | \$61.81 | \$92.24 | \$122.74 |
| Apprentice: 4th Period | \$63.50 | \$94.91 | \$126.30 |
| Apprentice: 5th Period | \$65.26 | \$97.54 | \$129.82 |
| Apprentice: 6th Period | \$68.89 | \$103.00 | \$137.08 |
| Apprentice: 7th Period | \$72.46 | \$108.36 | \$144.22 |
| Apprentice: 8th Period | \$76.07 | \$113.77 | \$151.44 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--------------------------------|-------------------|-----------------|-------------|
| Boom Truck | 10/28/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$70.31 | \$92.84 | \$115.37 |
| Apprentice: Apprentice Level 1 | \$56.81 | \$72.59 | \$88.37 |
| Apprentice: Apprentice Level 2 | \$59.06 | \$75.97 | \$92.87 |
| Apprentice: Apprentice Level 3 | \$61.31 | \$79.35 | \$97.37 |
| Apprentice: Apprentice Level 4 | \$63.56 | \$82.72 | \$101.87 |

Four 10-hour days allowed? - No

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|------------------------------------|-------------------|-----------------|-------------|
| Bricklayer | 10/29/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$63.77 | \$81.75 | \$99.73 |
| Apprentice: Apprentice Level 1 | \$43.54 | \$54.94 | \$66.34 |
| Apprentice: Apprentice Level 2 | \$45.67 | \$58.06 | \$70.45 |
| Apprentice: Apprentice Level 3` | \$47.66 | \$61.05 | \$74.43 |
| Apprentice: Apprentice Level 4 | \$49.64 | \$64.02 | \$78.39 |
| Apprentice: Apprentice Level 5 | \$51.62 | \$66.99 | \$82.35 |
| Apprentice: Apprentice Level 6 | \$53.61 | \$69.97 | \$86.33 |
| Apprentice: Apprentice Level 7 & 8 | \$55.59 | \$72.94 | \$90.29 |

Four 10-hour days allowed? - No

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--------------------------------|-------------------|-----------------|-------------|
| Carpenter | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$60.20 | \$78.38 | \$96.56 |
| Apprentice: Apprentice Level 1 | \$49.29 | \$62.02 | \$74.74 |
| Apprentice: Apprentice Level 2 | \$51.11 | \$64.75 | \$78.38 |
| Apprentice: Apprentice Level 3 | \$54.75 | \$70.21 | \$85.66 |
| Apprentice: Apprentice Level 4 | \$58.95 | \$76.51 | \$94.06 |

Four 10-hour days allowed? - No

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---------------------------------|-------------------|-----------------|-------------|
| Carpet layers (linoleum) | 11/03/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$53.72 | \$70.77 | \$87.81 |
| Apprentice: Level 1 | \$43.49 | \$55.42 | \$67.35 |
| Apprentice: Level 2 | \$45.20 | \$57.99 | \$70.77 |
| Apprentice: Level 3 | \$48.61 | \$63.10 | \$77.59 |
| Apprentice: Level 4 | \$52.02 | \$68.22 | \$84.41 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|------------------------------------|-------------------|-----------------|-------------|
| Cement Mason | 10/29/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$58.41 | \$74.70 | \$90.98 |
| Apprentice: Apprentice Level 1 | \$43.67 | \$55.79 | \$67.90 |
| Apprentice: Apprentice Level 2 | \$45.47 | \$58.49 | \$71.50 |
| Apprentice: Apprentice Level 3 | \$47.27 | \$61.19 | \$75.10 |
| Apprentice: Apprentice Level 4 | \$49.08 | \$63.90 | \$78.72 |
| Apprentice: Apprentice Level 5 & 6 | \$50.88 | \$66.60 | \$82.32 |

Four 10-hour days allowed? - No

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--------------------------------|-------------------|-----------------|-------------|
| Drywall Taper | 10/31/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$51.67 | \$68.44 | \$85.21 |
| Apprentice: Apprentice Level 1 | \$39.93 | \$50.83 | \$61.73 |
| Apprentice: Apprentice Level 2 | \$43.29 | \$55.87 | \$68.45 |
| Apprentice: Apprentice Level 3 | \$48.32 | \$63.42 | \$78.51 |

Four 10-hour days allowed? - No

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--------------------------------|----------------------|------------------------|--------------------|
| Electrician | 10/31/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$74.61 | \$106.29 | \$137.94 |
| Apprentice: Level 1 Apprentice | \$33.59 | \$45.90 | \$58.20 |
| Apprentice: Level 2 Apprentice | \$36.33 | \$50.02 | \$63.68 |
| Apprentice: Level 3 Apprentice | \$39.07 | \$54.12 | \$69.16 |
| Apprentice: Level 4 Apprentice | \$41.81 | \$58.23 | \$74.64 |
| Apprentice: Level 5 Apprentice | \$44.54 | \$62.32 | \$80.10 |
| Apprentice: Level 6 Apprentice | \$51.00 | \$72.02 | \$93.02 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

The Employer, with 48 hours prior notice to the Union, or the approval of the business manager, may institute a work week consisting of four (4) consecutive ten (10) hour days between the hours of 7:00 a.m. and 6:00 p.m., Monday through Thursday, with one-half hour allowed for a lunch period. Friday

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|-----------------------------|-------------------|-----------------|-------------|
| Elevator Constructor | 10/29/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$110.76 | \$143.49 | \$176.21 |
| Apprentice: 4th Year | \$95.57 | \$121.75 | \$147.93 |

Four 10-hour days allowed? - No

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|------------------------------|-------------------|-----------------|-------------|
| Elevator Constructors | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$110.76 | \$143.49 | \$176.21 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---------------------|-------------------|-----------------|-------------|
| Glaziers | 10/31/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$56.55 | \$76.37 | \$96.20 |
| Apprentice: Level 1 | \$40.70 | \$52.61 | \$64.50 |
| Apprentice: Level 2 | \$44.66 | \$58.55 | \$72.42 |
| Apprentice: Level 3 | \$48.63 | \$64.50 | \$80.36 |
| Apprentice: Level 4 | \$52.59 | \$70.44 | \$88.28 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|----------------------|-------------------|-----------------|-------------|
| Ground Person | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$50.85 | \$72.32 | \$93.78 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|-------------------------------------|-------------------|-----------------|-------------|
| Heating and frost Insulators | 11/03/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$63.85 | \$83.85 | \$103.85 |
| Apprentice: 1st period | \$44.28 | \$56.28 | \$68.28 |
| Apprentice: 2nd period | \$49.17 | \$63.17 | \$77.17 |
| Apprentice: 3rd period | \$54.06 | \$70.06 | \$86.06 |
| Apprentice: 4th period | \$58.96 | \$76.96 | \$94.96 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Friday for cancelled work in a 4 10 schedule

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--------------------------------|-------------------|-----------------|-------------|
| Ironworker | 10/31/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$75.42 | \$93.70 | \$111.97 |
| Apprentice: Apprentice Level 1 | \$57.42 | \$70.40 | \$83.37 |
| Apprentice: Apprentice Level 2 | \$59.59 | \$73.12 | \$86.64 |
| Apprentice: Apprentice Level 3 | \$61.54 | \$75.43 | \$89.32 |
| Apprentice: Apprentice Level 4 | \$64.59 | \$79.40 | \$94.20 |
| Apprentice: Apprentice Level 5 | \$67.64 | \$83.36 | \$99.07 |
| Apprentice: Apprentice Level 6 | \$75.42 | \$93.70 | \$111.97 |

Four 10-hour days allowed? - No

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|-------------------------------------|-------------------|-----------------|-------------|
| Laborer, Common - Commercial | 11/04/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$50.13 | \$63.66 | \$77.18 |
| Apprentice: Apprentice Level 1 | \$43.37 | \$53.52 | \$63.66 |
| Apprentice: Apprentice Level 2 | \$46.07 | \$57.56 | \$69.06 |
| Apprentice: Apprentice Level 3 | \$48.32 | \$61.17 | \$74.02 |

Four 10-hour days allowed? - No

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--|-------------------|-----------------|-------------|
| Laborer, Common - Highway & Heavy | 11/05/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$50.32 | \$65.58 | \$80.83 |
| Apprentice: Level 1 | \$42.69 | \$54.13 | \$65.57 |
| Apprentice: Level 2 | \$44.22 | \$56.43 | \$68.63 |
| Apprentice: Level 3 | \$45.74 | \$58.71 | \$71.67 |
| Apprentice: Level 4 | \$48.79 | \$63.28 | \$77.77 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--------------------------------|-------------------|-----------------|-------------|
| Laborer, Landscaping | 11/03/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$36.87 | \$49.23 | \$61.58 |
| Apprentice: Apprentice Level 1 | \$30.69 | \$39.96 | \$49.22 |
| Apprentice: Apprentice Level 2 | \$31.93 | \$41.82 | \$51.70 |
| Apprentice: Apprentice Level 3 | \$33.16 | \$43.66 | \$54.16 |
| Apprentice: Apprentice Level 4 | \$35.63 | \$47.37 | \$59.10 |

Four 10-hour days allowed? - No

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---|-------------------|-----------------|-------------|
| Laborer, Skilled - Highway & Heavy | 11/05/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$51.22 | \$66.93 | \$82.63 |
| Apprentice: Level 1 | \$43.37 | \$55.15 | \$66.93 |
| Apprentice: Level 2 | \$44.94 | \$57.51 | \$70.07 |
| Apprentice: Level 3 | \$46.51 | \$59.86 | \$73.21 |
| Apprentice: Level 4 | \$49.65 | \$64.57 | \$79.49 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|------------------------------|----------------------|------------------------|--------------------|
| Landscaping equipment | 10/28/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$39.09 | \$52.56 | \$66.02 |

Four 10-hour days allowed? - No

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|-------------------------------------|-------------------|-----------------|-------------|
| Lineman | 10/30/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$76.81 | \$111.26 | \$145.70 |
| Apprentice: Level 1 0-1000 hours | \$49.26 | \$69.94 | \$90.60 |
| Apprentice: Level 2 1001-2000 Hours | \$52.71 | \$75.11 | \$97.50 |
| Apprentice: Level 3 2001-3000 Hours | \$56.15 | \$80.28 | \$104.38 |
| Apprentice: Level 4 3001-4000 hours | \$59.60 | \$85.44 | \$111.28 |
| Apprentice: Level 5 4001-5000 Hours | \$63.04 | \$90.60 | \$118.16 |
| Apprentice: Level 6 5001-6000 Hours | \$66.48 | \$95.77 | \$125.04 |
| Apprentice: Level 7 | \$69.93 | \$100.94 | \$131.94 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|-------------------------------|-------------------|-----------------|-------------|
| Low Voltage Technician | 02/04/2026 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$55.21 | \$72.46 | \$89.71 |
| Apprentice: Level 1 | \$24.76 | \$34.25 | \$43.74 |
| Apprentice: Level 2 | \$26.56 | \$36.91 | \$47.26 |
| Apprentice: Level 3 | \$31.87 | \$40.15 | \$51.36 |
| Apprentice: Level 4 | \$36.01 | \$48.95 | \$61.89 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---------------------|-------------------|-----------------|-------------|
| Millwright | 11/05/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$82.65 | \$126.09 | \$165.30 |
| Apprentice: Level 1 | \$60.79 | \$91.21 | \$121.58 |
| Apprentice: Level 2 | \$68.09 | \$102.15 | \$136.18 |
| Apprentice: Level 3 | \$75.36 | \$113.05 | \$150.72 |
| Apprentice: Level 4 | \$79.01 | \$118.54 | \$158.02 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--------------------------------|-------------------|-----------------|-------------|
| Off-Road Truck | 10/29/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$63.02 | \$81.91 | \$100.79 |
| Apprentice: Apprentice Level 1 | \$51.70 | \$64.93 | \$78.15 |
| Apprentice: Apprentice Level 2 | \$53.59 | \$67.76 | \$81.93 |
| Apprentice: Apprentice Level 3 | \$55.48 | \$70.60 | \$85.71 |
| Apprentice: Apprentice Level 4 | \$57.36 | \$73.42 | \$89.47 |
| Apprentice: Apprentice Level 5 | \$59.25 | \$76.25 | \$93.25 |
| Apprentice: Apprentice Level 6 | \$61.13 | \$79.07 | \$97.01 |

Four 10-hour days allowed? - No

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--------------------------------|-------------------|-----------------|-------------|
| Painter | 10/31/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$50.90 | \$67.19 | \$83.48 |
| Apprentice: Apprentice Level 1 | \$37.87 | \$47.65 | \$57.42 |
| Apprentice: Apprentice Level 2 | \$41.13 | \$52.54 | \$63.94 |
| Apprentice: Apprentice Level 3 | \$44.38 | \$57.41 | \$70.44 |
| Apprentice: Apprentice Level 4 | \$47.64 | \$62.30 | \$76.96 |

Four 10-hour days allowed? - No

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--------------------------------|-------------------|-----------------|-------------|
| Piledriver | 11/01/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$60.20 | \$78.38 | \$96.56 |
| Apprentice: Apprentice Level 1 | \$49.29 | \$62.02 | \$74.74 |
| Apprentice: Apprentice Level 2 | \$51.11 | \$64.75 | \$78.38 |
| Apprentice: Apprentice Level 3 | \$54.75 | \$70.21 | \$85.66 |
| Apprentice: Apprentice Level 4 | \$58.95 | \$76.51 | \$94.06 |

Four 10-hour days allowed? - No

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---------------------------------|-------------------|-----------------|-------------|
| Pipefitters—Steamfitters | 11/03/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$70.71 | \$105.22 | \$139.72 |
| Apprentice: Level 1 | \$36.10 | \$53.70 | \$71.29 |
| Apprentice: Level 2 | \$45.33 | \$68.00 | \$90.66 |
| Apprentice: Level 3 | \$50.07 | \$75.11 | \$100.14 |
| Apprentice: Level 4 | \$54.80 | \$82.21 | \$109.60 |
| Apprentice: Level 5 | \$59.54 | \$89.32 | \$119.08 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--------------------------------|-------------------|-----------------|-------------|
| Plasterer | 10/29/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$58.68 | \$75.07 | \$91.46 |
| Apprentice: Apprentice Level 1 | \$43.94 | \$56.07 | \$68.20 |
| Apprentice: Apprentice Level 2 | \$45.77 | \$58.82 | \$71.86 |
| Apprentice: Apprentice Level 3 | \$47.60 | \$61.56 | \$75.52 |
| Apprentice: Apprentice Level 4 | \$49.43 | \$64.31 | \$79.18 |
| Apprentice: Apprentice Level 5 | \$51.27 | \$67.07 | \$82.86 |
| Apprentice: Apprentice Level 6 | \$51.27 | \$67.07 | \$82.86 |

Four 10-hour days allowed? - No

Make Up Day Allowed? - No

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---------------------|----------------------|------------------------|--------------------|
| Plumbers | 10/29/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$70.71 | \$105.22 | \$139.72 |
| Apprentice: Level 1 | \$36.10 | \$53.70 | \$71.29 |
| Apprentice: Level 2 | \$45.33 | \$68.00 | \$90.66 |
| Apprentice: Level 3 | \$45.33 | \$68.00 | \$90.66 |
| Apprentice: Level 5 | \$50.07 | \$75.11 | \$100.14 |
| Apprentice: Level 7 | \$54.80 | \$82.21 | \$109.60 |
| Apprentice: Level 8 | \$59.54 | \$89.32 | \$119.08 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|----------------------------|-------------------|-----------------|-------------|
| Roofer/Waterproofer | 11/03/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$49.76 | \$63.95 | \$78.14 |
| Apprentice: Apprentice 1 | \$35.27 | \$42.22 | \$49.16 |
| Apprentice: Apprentice 2 | \$36.91 | \$44.68 | \$52.44 |
| Apprentice: Apprentice 3 | \$36.31 | \$43.78 | \$51.24 |
| Apprentice: Apprentice 4 | \$37.93 | \$46.20 | \$54.48 |
| Apprentice: Apprentice 5 | \$34.45 | \$40.98 | \$47.52 |
| Apprentice: Apprentice 6 | \$41.18 | \$51.08 | \$60.98 |
| Apprentice: Apprentice 7 | \$42.51 | \$53.08 | \$63.64 |
| Apprentice: Apprentice 8 | \$44.42 | \$55.94 | \$67.46 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---------------------------|-------------------|-----------------|-------------|
| Sheet Metal Worker | 04/17/2026 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$63.20 | \$81.64 | \$100.07 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Saturday

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|--------------------------|-------------------|-----------------|-------------|
| Sprinkler Fitters | 11/03/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$60.34 | \$78.45 | \$96.56 |
| Apprentice: Class 1 | \$24.57 | \$32.72 | \$40.87 |
| Apprentice: Class 10 | \$52.07 | \$68.37 | \$84.67 |
| Apprentice: Class 2 | \$26.38 | \$35.43 | \$44.49 |
| Apprentice: Class 3 | \$39.14 | \$49.10 | \$59.06 |
| Apprentice: Class 4 | \$40.95 | \$51.82 | \$62.68 |
| Apprentice: Class 5 | \$43.01 | \$54.78 | \$66.55 |
| Apprentice: Class 6 | \$44.82 | \$57.49 | \$70.17 |
| Apprentice: Class 7 | \$46.63 | \$60.21 | \$73.79 |
| Apprentice: Class 8 | \$48.45 | \$62.94 | \$77.43 |
| Apprentice: Class 9 | \$50.26 | \$65.65 | \$81.05 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---------------------------|-------------------|-----------------|-------------|
| Terrazzo Workers | 04/17/2026 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$56.86 | \$72.84 | \$88.81 |
| Apprentice: Level 1 | \$43.04 | \$53.11 | \$63.17 |
| Apprentice: Level 2 | \$44.96 | \$55.99 | \$67.01 |
| Apprentice: Level 3 | \$46.55 | \$58.37 | \$70.19 |
| Apprentice: Level 4 | \$48.47 | \$61.25 | \$74.03 |
| Apprentice: Level 5 | \$51.98 | \$66.52 | \$81.05 |
| Apprentice: Level 6 and 7 | \$53.90 | \$69.40 | \$84.89 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|-----------------------|----------------------|------------------------|--------------------|
| Tile Finishers | 04/17/2026 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$49.30 | \$62.80 | \$76.30 |
| Apprentice: Level 1 | \$40.55 | \$50.68 | \$60.80 |
| Apprentice: Level 2 | \$42.17 | \$53.11 | \$64.04 |
| Apprentice: Level 3 | \$43.79 | \$55.53 | \$67.28 |
| Apprentice: Level 4 | \$45.14 | \$57.56 | \$69.98 |
| Apprentice: Level 5 | \$46.76 | \$59.99 | \$73.22 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---------------------|---------------|-----------------|-------------|
| Tile Setters | | | |
| 04/17/2026 | | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$56.36 | \$72.09 | \$87.81 |
| Apprentice: Level 1 | \$42.72 | \$52.63 | \$62.53 |
| Apprentice: Level 2 | \$44.61 | \$55.46 | \$66.31 |
| Apprentice: Level 3 | \$46.18 | \$57.82 | \$69.45 |
| Apprentice: Level 4 | \$48.07 | \$60.65 | \$73.23 |
| Apprentice: Level 5 | \$51.53 | \$65.84 | \$80.15 |
| Apprentice: Level 6 | \$53.42 | \$68.68 | \$83.93 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---------------------|-------------------|-----------------|-------------|
| Tunnel Miner | 11/03/2025 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$52.82 | \$70.02 | \$87.22 |
| Apprentice: Level 1 | \$44.22 | \$57.12 | \$70.02 |
| Apprentice: Level 2 | \$45.94 | \$59.70 | \$73.46 |
| Apprentice: Level 3 | \$47.66 | \$62.28 | \$76.90 |
| Apprentice: Level 4 | \$51.10 | \$61.35 | \$75.66 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

Prevailing Wage Rates for State Of Michigan Funded Projects

Official Rate Schedule

Genesee

| Classification Name | Last Updated | | |
|---|-------------------|-----------------|-------------|
| Underground and Open Cut Laborer | 01/06/2026 | | |
| Wage Rates | Straight Time | Time and a Half | Double Time |
| Journeyman | \$48.76 | \$63.91 | \$79.05 |
| Apprentice: Level 1 | \$41.19 | \$52.55 | \$63.91 |
| Apprentice: Level 2 | \$42.70 | \$54.82 | \$66.93 |
| Apprentice: Level 3 | \$44.22 | \$57.10 | \$69.97 |
| Apprentice: Level 4 | \$47.25 | \$61.64 | \$76.03 |

Four 10-hour days allowed? - Yes

Make Up Day Allowed? - Yes

SECTION 013000 - SUBMITTALS

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes: This Section includes, but not necessarily limited to, the submittal of Shop Drawings. Samples and other information as indicated on the Drawings, as specified herein, and as necessary for the proper and complete performance of the Work.
- B. Related Sections:
 - 1. Documents affecting work of this Section include, but are not necessarily limited to:
 - a. General Conditions, Supplementary Conditions and Sections in Division 1 of these Specifications.
 - b. Individual submittals required: Pertinent Sections of these Specifications.

PART 2 - PRODUCTS

2.1 SUBMITTALS REQUIRING ENGINEER'S REVIEW AND RETURN

- A. Drawings:
 - 1. Scale required: Unless otherwise specifically directed by ENGINEER, make all drawings accurately to a scale sufficiently large to indicate all pertinent features of the item and its method of connection to the Work.
 - 2. Type and number of prints required:
 - a. Submit the number of copies which are required to be returned plus 4.
- B. Manufacturer's literature and product data:
 - 1. General: Where content of submitted literature from Manufacturers includes data not pertinent to this submittal, clearly indicate which portion of the contents is being submitted for ENGINEER's review.
 - 2. Number of copies required: Submit the number of copies which are required to be returned plus 4.
- C. Calculations:

1. Performance type design calculations: Shall be prepared and sealed by a Professional Engineer licensed in the state where the project is being constructed.
 2. Number of copies required: Submit the number of copies which are required to be returned plus 4.
- D. Samples:
1. General:
 - a. Samples:
 - 1) Illustrate materials, equipment and workmanship.
 - 2) Establish standards by which completed work is judged.
 2. Accuracy of Sample: Unless otherwise specifically directed by ENGINEER, all Samples shall be of the precise articles proposed to be furnished.
 3. Number of Samples required: Submit all Samples in the quantity which is required to be returned plus 1.
- E. Colors and patterns: Unless the precise color and pattern is specifically described in the Contract Documents, whenever a choice of color or pattern is available in a specified Product, submit accurate color charts and pattern charts to ENGINEER for review and selection.
- F. Manuals :
1. General:
 - a. Where manuals are required to be submitted covering items included in this Work, prepare all such manuals in durable plastic binders approximately 8 ½ inches x 11 inches in size and with at least the following:
 - 1) Identification on, or readable through, the front cover stating general nature of the manual.
 - 2) Neatly typewritten index near the front of the manual.
 - 3) Complete instructions regarding operation and maintenance of all equipment involved.
 - 4) Complete nomenclature of all replaceable parts, their part numbers, current costs and name and address of nearest vendor of parts.
 - 5) Copies of all guarantees and warranties issued.
 - 6) Copies of the reviewed drawings.
 - 7) Copies of all data concerning all changes made during construction.
 2. Extraneous Data: Where contents of the manuals include Manufacturer's catalog pages. Clearly indicate the precise items included in this installation and delete or otherwise clearly indicate all Manufacturer's data with which this installation is not concerned.

3. Number of copies required: Unless otherwise specifically directed by ENGINEER or stipulated in the pertinent Section of these Specifications. Deliver 4 copies of the manual to ENGINEER.

2.2 SUBMITTALS NOT REQUIRING ENGINEER’S RETURN

A. General:

1. Including, but not necessarily limited to:
 - a. Test Reports.
 - b. Certifications and affidavits.
 - c. Installation instructions.
2. Number required: Submit 4 copies.

PART 3 - EXECUTION

3.1 SCHEDULE OF SUBMITTALS

A. Preparation and submittal of a schedule of submittals:

1. Prepare and submit a schedule of submittals as required by Section 00700: General Conditions.
2. The schedule of submittals shall include the following:
 - a. Shop Drawings.
 - b. Manufacturer’s literature and product data.
 - c. Samples.
 - d. Colors and patterns.
 - e. Manuals.
 - f. Other submittals required by the Contract Documents.
3. Allow at least 15 full working days for ENGINEER’s review following ENGINEER’s receipt of the submittal unless ENGINEER has agreed to a shorter period for specific submittals.
4. Schedule submittals, except operation and maintenance manuals, far enough in advance of scheduled dates for installation to provide all required time for reviews for securing necessary approvals for possible revision and resubmittal, and for placing orders and securing delivery.
5. Schedule submittal of operation and maintenance manuals at least 60 days prior to system Substantial Completion unless otherwise specified.

- B. Make all submittals in accordance with the schedule of submittals.
- C. Be responsible for costs of delays caused by tardiness of submittals.

3.2 COORDINATION OF SUBMITTALS

A. General:

- 1. Prior to submittals for ENGINEER's review. Use all means necessary to fully coordinate all material including the following procedures.
 - a. Determine and verify all field dimensions and conditions, catalog numbers and similar data.
 - b. Coordinate as required with all trades and all public involved.
 - c. Secure all necessary approvals from public agencies and others; signify by stamp or other means that all required approvals have been obtained.
 - d. Clearly indicate all deviations from the Contract Documents.

B. Grouping of submittals:

- 1. Unless otherwise specifically permitted by ENGINEER, make all submittals in groups containing all associated items.
- 2. ENGINEER may reject partial submittals as not complying with the provisions of the Contract Documents.

3.3 IDENTIFICATION OF SUBMITTALS

A. General:

- 1. Consecutively number all submittals.
- 2. Accompany each submittal with a letter of transmittal showing the following:
 - a. Project title and number.
 - b. OWNER.
 - c. Subcontractor.
 - d. Date of submittal.
 - e. Specification Section or Drawing number to which the submittal pertains.
 - f. Brief description of the material submitted.
 - g. Submittal identification number.
- 3. Mark each submittal with:

- a. Company name of the originator of the submittal.
- b. Deviations from Contract Documents.
- c. CONTRACTOR's approval of the submittal.
- d. Submittal identification number adjacent to CONTRACTOR's approval.

B. Resubmittal:

1. When material is resubmitted for any reason, transmit under a new letter of transmittal with a suffix added to the original submittal identification number.
2. Indicate that this is a resubmittal and refer to the previous submittal.

C. Submittal Log:

1. Maintain an accurate submittal log for the duration of the construction period showing the status of all submittals of all types.
2. Make the log available to ENGINEER for review upon request.

3.4 RETURN OF SUBMITTALS

A. Submittals requiring ENGINEER review and return:

1. With status. "Rejected. Resubmit":
 - a. Drawings: ENGINEER will retain 1 copy and return the rejected copies to CONTRACTOR.
 - b. Manufacturer's literature and product data: ENGINEER will retain 1 copy and return remaining copies to CONTRACTOR.
 - c. Other submittals: ENGINEER will notify CONTRACTOR of rejection.
2. With status: "Reviewed. No Exceptions Taken" and "Reviewed w/Corrections Noted":
 - a. Drawings: ENGINEER will retain 4 copies and return the remaining copies to CONTRACTOR.
 - b. Manufacturer's literature and product data: ENGINEER will retain 4 copies and return the remaining copies to CONTRACTOR.
 - c. Samples: ENGINEER will retain 1 Sample and return the remaining Samples to CONTRACTOR.
 - d. Colors: ENGINEER will retain color charts and pattern charts and will indicate color and pattern choices to CONTRACTOR.

B. Submittals not requiring ENGINEER return: No copies will be returned.

3.5 RESUBMISSION REQUIREMENTS

A. Drawings:

1. Revise initial drawings as required and resubmit as specified for initial submittal.
2. Indicate on drawings all changes which have been made other than those requested by ENGINEER.
3. If the same drawings are submitted with additional data and revisions, clearly identify the added data and revisions on the drawings.

B. Other submittals: Submit as required for initial submittal.

3.6 RE-REVIEW COST

- A. Should ENGINEER be required to review a submittal more than twice because of failure of the submittal to meet the requirements of the Contract Documents, ENGINEER will record ENGINEER's expenses for performing all additional reviews. The OWNER will compensate ENGINEER for these additional services and deduct the amount paid from payments to CONTRACTOR.

END OF SECTION 013000

SECTION 017823 - OPERATION AND MAINTENANCE MANUAL (S)

I. GENERAL:

- A. The Contractor shall provide six (6) complete hard copy sets of an Operation & Maintenance Manual (s) and two (2) CD (s) for all equipment and systems. The manual (s) shall include, as a minimum, the following information:
1. A complete system description which includes a narrative of significant design features, layout, circuiting and block diagram.
 2. List of Equipment.
 3. Operating Instructions.
 4. Maintenance Instructions.
 5. Parts List for each component.
 6. Shop drawings and product data.
 7. Certificates.
 8. Photocopies of Warranties.
- B. The Operation and Maintenance Manual (s) shall be bound in durable 8 ½ X 11 three D side ring plastic cover binders. Individual binders shall be a maximum of 3 inches thick.
- C. Binders shall be identified on the cover with printed title “OPERATION AND MAINTENANCE INSTRUCTIONS”, title of project, State Of Michigan file number, and contained subject if multiple binders are required.
- D. Binders shall have durable permanent internal page dividers, logically organized as described in E. below with tab titles clearly printed under reinforced laminated plastic tabs.
- E. A Table of Contents of the Operating & Maintenance Manual (s) shall be provided with each Product or system identified. A “complete” Table of Contents shall be included in each binder if there are multi-volumes. The Table of Contents shall be type written on 30-pound white paper and have three parts as follows:
- Part 1: Directory, listing names, addresses, and telephone numbers of Engineer, Contractor, Subcontractors, and major equipment suppliers.
- Part 2: Operation and Maintenance instructions arranged by systems and subdivided by specification Section. For each category identify names, addresses, and telephone numbers of Subcontractors and suppliers. Identify the following:
- a) A complete system description which includes a narrative of significant design features, layout, circuiting and block diagrams.

- b) List of Equipment.
- c) Operating Instructions.
- d) Maintenance Instructions.
- e) Parts List for each component.

Part 3: Project documents and certificates, including the following:

- a) Shop drawings and product data.
- b) Certificates.
- c) Photocopies of Warranties.

END OF SECTION 017823

SECTION 099114 – INTERIOR/EXTERIOR PAINTING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Surface preparation and application of paint systems on the following exterior substrates:
 - a. Steel Fire Suppression Piping

1.3 DEFINITIONS

- A. MPI Gloss Level 1: Not more than five units at 60 degrees and 10 units at 85 degrees, according to ASTM D523.
- B. MPI Gloss Level 3: 10 to 25 units at 60 degrees and 10 to 35 units at 85 degrees, according to ASTM D523.
- C. MPI Gloss Level 4: 20 to 35 units at 60 degrees and not less than 35 units at 85 degrees, according to ASTM D523.
- D. MPI Gloss Level 5: 35 to 70 units at 60 degrees, according to ASTM D523.
- E. MPI Gloss Level 6: 70 to 85 units at 60 degrees, according to ASTM D523.
- F. MPI Gloss Level 7: More than 85 units at 60 degrees, according to ASTM D523.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.
 - 1. Include preparation requirements and application instructions.
 - 2. Include printout of current "MPI Approved Products List" for each product category specified, with the proposed product highlighted.
 - 3. Indicate VOC content.

- B. Samples for Verification: For each type of paint system and each color and gloss of topcoat.
 - 1. Submit Samples on rigid backing, 8 inches (200 mm) square.
 - 2. Apply coats on Samples in steps to show each coat required for system.
 - 3. Label each coat of each Sample.
 - 4. Label each Sample for location and application area.

- C. Product List: Cross-reference to paint system and locations of application areas. Use same designations indicated on Drawings and in the Exterior Painting Schedule to cross-reference paint systems specified in this Section. Include color designations.

1.5 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
 - 1. Paint: 5 percent, but not less than 1 gal. (3.8 L) of each material and color applied.

1.6 QUALITY ASSURANCE

- A. Mockups: Apply mockups of each paint system indicated and each color and finish selected to verify selections made under Sample submittals, to demonstrate aesthetic effects, and to set quality standards for materials and execution.
 - 1. Architect will select one surface to represent surfaces and conditions for application of each paint system.
 - a. Vertical and Horizontal Surfaces: Provide samples of at least 100 sq. ft. (9 sq. m).
 - b. Other Items: Architect will designate items or areas required.
 - 2. Final approval of color selections will be based on mockups.
 - a. If preliminary color selections are not approved, apply additional mockups of additional colors selected by Architect at no added cost to Owner.
 - 3. Approval of mockups does not constitute approval of deviations from the Contract Documents contained in mockups unless Architect specifically approves such deviations in writing.
 - 4. Subject to compliance with requirements, approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Store materials not in use in tightly covered containers in well-ventilated areas with ambient temperatures continuously maintained at not less than 45 deg F (7 deg C).
 - 1. Maintain containers in clean condition, free of foreign materials and residue.
 - 2. Remove rags and waste from storage areas daily.

1.8 FIELD CONDITIONS

- A. Apply paints only when temperature of surfaces to be painted and ambient air temperatures are between 50 and 95 deg F (10 and 35 deg C).
- B. Do not apply paints in snow, rain, fog, or mist; when relative humidity exceeds 85 percent; at temperatures less than 5 deg F (3 deg C) above the dew point; or to damp or wet surfaces.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to products listed in the Exterior Painting Schedule for the paint category indicated.
- B. Source Limitations: Obtain paint from single source from single manufacturer.

2.2 PAINT PRODUCTS

- A. MPI Standards: Provide products complying with MPI standards indicated and listed in its "MPI Approved Products List."
- B. Material Compatibility:
 - 1. Provide materials for use within each paint system that are compatible with one another and substrates indicated, under conditions of service and application as demonstrated by manufacturer, based on testing and field experience.
 - 2. For each coat in a paint system, provide products recommended in writing by topcoat manufacturers for use in paint system and on substrate indicated.
- C. Colors: Fire Suppression piping and hangers to be painted red.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates and conditions, with Applicator present, for compliance with requirements for maximum moisture content and other conditions affecting performance of the Work.
- B. Verify suitability of substrates, including surface conditions and compatibility, with existing finishes and primers.
- C. Proceed with coating application only after unsatisfactory conditions have been corrected.
 - 1. Application of coating indicates acceptance of surfaces and conditions.

3.2 PREPARATION

- A. Comply with manufacturer's written instructions and recommendations in "MPI Manual" applicable to substrates and paint systems indicated.
- B. Remove hardware, covers, plates, and similar items already in place that are removable and are not to be painted. If removal is impractical or impossible because of size or weight of item, provide surface-applied protection before surface preparation and painting.
 - 1. After completing painting operations, use workers skilled in the trades involved to reinstall items that were removed. Remove surface-applied protection.
- C. Clean substrates of substances that could impair bond of paints, including dust, dirt, oil, grease, and incompatible paints and encapsulants.
 - 1. Remove incompatible primers and reprime substrate with compatible primers or apply tie coat as required to produce paint systems indicated.
- D. Steel Substrates: Remove rust, loose mill scale, and shop primer if any. Clean using methods recommended in writing by paint manufacturer[.] [but not less than the following:]
 - 1. SSPC-SP 2.

3.3 INSTALLATION

- A. Apply paints in accordance with manufacturer's written instructions and recommendations in "MPI Manual."
 - 1. Use applicators and techniques suited for paint and substrate indicated.
 - 2. Paint surfaces behind movable items same as similar exposed surfaces. Before final installation, paint surfaces behind permanently fixed items with prime coat only.

3. Do not paint over labels of independent testing agencies or equipment name, identification, performance rating, or nomenclature plates.
 4. Primers specified in the Exterior Painting Schedule may be omitted on items that are factory primed or factory finished if compatible with intermediate and topcoat coatings and acceptable to intermediate and topcoat paint manufacturers.
- B. If undercoats or other conditions show through topcoat, apply additional coats until cured film has a uniform paint finish, color, and appearance.
- C. Apply paints to produce surface films without cloudiness, spotting, holidays, laps, brush marks, roller tracking, runs, sags, ropiness, or other surface imperfections. Cut in sharp lines and color breaks.
- D. Painting Fire Suppression, Plumbing, HVAC, Electrical, Communication, and Electronic Safety and Security Work:
1. Paint the following work where exposed to view:
 - a. Uninsulated fire suppression piping.
 - b. Fire Suppression pipe hangers and supports.

3.4 FIELD QUALITY CONTROL

- A. Dry Film Thickness Testing: Owner may engage the services of a qualified testing and inspecting agency to inspect and test paint for dry film thickness.
1. Contractor shall touch up and restore painted surfaces damaged by testing.
 2. If test results show that dry film thickness of applied paint does not comply with paint manufacturer's written instructions, Contractor shall pay for testing and apply additional coats as needed to provide dry film thickness that complies with paint manufacturer's written instructions.

3.5 CLEANING AND PROTECTION

- A. At end of each workday, remove rubbish, empty cans, rags, and other discarded materials from Project site.
1. Do not clean equipment with free-draining water and prevent solvents, thinners, cleaners, and other contaminants from entering into waterways, sanitary and storm drain systems, and ground.
 2. Dispose of contaminants in accordance with requirements of authorities having jurisdiction.
 3. Allow empty paint cans to dry before disposal.
- B. After completing paint application, clean spattered surfaces. Remove spattered paints by washing, scraping, or other methods. Do not scratch or damage adjacent finished surfaces.

- C. Protect work of other trades against damage from paint application. Correct damage to work of other trades by cleaning, repairing, replacing, and refinishing, as approved by Architect, and leave in an undamaged condition.
- D. At completion of construction activities of other trades, touch up and restore damaged or defaced painted surfaces.

3.6 EXTERIOR PAINTING SCHEDULE

A. Steel and Iron Substrates:

1. Water-Based Industrial Coating System:

- a. Water based, corrosion resistant acrylic coating.
- b. Surface Preparation: SSPC-SP10
- c. Finish:
 - 1) 1 coat Pro Industrial Pro-Cryl Primer with 2 coats Pro Industrial DTM Acrylic B66W01051, 3.0 DFT per coat
 - 2) Glass 70+ at 60 degrees
 - 3) Color: Red
 - 4) Paint all new exposed fire suppression piping and hangers.
 - 5) Interior/Exterior Paint
- d. Apply product pre the manufacturer's installation instructions
- e. Based on Sherwin Williams Pro Industrial DTM Acrylic Gloss B66-1050 Series or approved equal.

END OF SECTION 099114

SECTION 210500 - COMMON WORK RESULTS FOR FIRE SUPPRESSION

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes the following:
 - 1. Piping materials and installation instructions common to most piping systems.
 - 2. Mechanical sleeve seals.
 - 3. Sleeves.
 - 4. Escutcheons.
 - 5. Grout.
 - 6. Fire-suppression equipment and piping demolition.
 - 7. Equipment installation requirements common to equipment sections.
 - 8. Painting and finishing.
 - 9. Supports and anchorages.

1.3 DEFINITIONS

- A. Finished Spaces: Spaces other than mechanical and electrical equipment rooms, furred spaces, pipe chases, unheated spaces immediately below roof, spaces above ceilings, unexcavated spaces, crawlspaces, and tunnels.
- B. Exposed, Interior Installations: Exposed to view indoors. Examples include finished occupied spaces and mechanical equipment rooms.
- C. Exposed, Exterior Installations: Exposed to view outdoors or subject to outdoor ambient temperatures and weather conditions. Examples include rooftop locations.
- D. Concealed, Interior Installations: Concealed from view and protected from physical contact by building occupants. Examples include above ceilings and in chases.
- E. Concealed, Exterior Installations: Concealed from view and protected from weather conditions and physical contact by building occupants but subject to outdoor ambient temperatures. Examples include installations within unheated shelters.
- F. The following are industry abbreviations for rubber materials:

1. EPDM: Ethylene-propylene-diene terpolymer rubber.
2. NBR: Acrylonitrile-butadiene rubber.

1.4 SUBMITTALS

A. Product Data: For the following:

1. Mechanical sleeve seals.
2. Escutcheons.

B. Welding certificates.

1.5 QUALITY ASSURANCE

A. Steel Support Welding: Qualify processes and operators according to AWS D1.1, "Structural Welding Code--Steel."

B. Steel Pipe Welding: Qualify processes and operators according to ASME Boiler and Pressure Vessel Code: Section IX, "Welding and Brazing Qualifications."

1. Comply with provisions in ASME B31 Series, "Code for Pressure Piping."
2. Certify that each welder has passed AWS qualification tests for welding processes involved and that certification is current.

C. Electrical Characteristics for Fire-Suppression Equipment: Equipment of higher electrical characteristics may be furnished provided such proposed equipment is approved in writing and connecting electrical services, circuit breakers, and conduit sizes are appropriately modified. If minimum energy ratings or efficiencies are specified, equipment shall comply with requirements.

1.6 DELIVERY, STORAGE, AND HANDLING

A. Deliver pipes and tubes with factory-applied end caps. Maintain end caps through shipping, storage, and handling to prevent pipe end damage and to prevent entrance of dirt, debris, and moisture.

1.7 COORDINATION

A. Arrange for pipe spaces, chases, slots, and openings in building structure during progress of construction, to allow for fire-suppression installations.

B. Coordinate installation of required supporting devices and set sleeves in poured-in-place concrete and other structural components as they are constructed.

- C. Coordinate requirements for access panels and doors for fire-suppression items requiring access that are concealed behind finished surfaces.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. In other Part 2 articles where subparagraph titles below introduce lists, the following requirements apply for product selection:
 - 1. Manufacturers: Subject to compliance with requirements, provide products by the manufacturers specified.

2.2 PIPE, TUBE, AND FITTINGS

- A. Refer to individual Division 21 piping Sections for pipe, tube, and fitting materials and joining methods.
- B. Pipe Threads: ASME B1.20.1 for factory-threaded pipe and pipe fittings.

2.3 JOINING MATERIALS

- A. Refer to individual Division 21 piping Sections for special joining materials not listed below.
- B. Pipe-Flange Gasket Materials: Suitable for chemical and thermal conditions of piping system contents.
 - 1. ASME B16.21, nonmetallic, flat, asbestos-free, 1/8-inch maximum thickness unless thickness or specific material is indicated.
 - a. Full-Face Type: For flat-face, Class 125, cast-iron and cast-bronze flanges.
 - b. Narrow-Face Type: For raised-face, Class 250, cast-iron and steel flanges.
 - 2. AWWA C110, rubber, flat face, 1/8 inch thick, unless otherwise indicated; and full-face or ring type, unless otherwise indicated.
- C. Flange Bolts and Nuts: ASME B18.2.1, carbon steel, unless otherwise indicated.

2.4 MECHANICAL SLEEVE SEALS

- A. Description: Modular sealing element unit, designed for field assembly, to fill annular space between pipe and sleeve.

1. Available Manufacturers:
 - a. Advance Products & Systems, Inc.
 - b. Calpico, Inc.
 - c. Metraflex Co.
 - d. Pipeline Seal and Insulator, Inc.
2. Sealing Elements: EPDM or NBR interlocking links shaped to fit surface of pipe. Include type and number required for pipe material and size of pipe.
3. Pressure Plates: Stainless steel. Include two for each sealing element.
4. Connecting Bolts and Nuts: Stainless steel of length required to secure pressure plates to sealing elements. Include one for each sealing element.

2.5 SLEEVES

- A. Galvanized-Steel Sheet: 0.0239-inch minimum thickness; round tube closed with welded longitudinal joint.
- B. Steel Pipe: ASTM A 53, Type E, Grade B, Schedule 40, galvanized, plain ends.
- C. Cast Iron: Cast or fabricated "wall pipe" equivalent to ductile-iron pressure pipe, with plain ends and integral waterstop, unless otherwise indicated.
- D. Stack Sleeve Fittings: Manufactured, cast-iron sleeve with integral clamping flange. Include clamping ring and bolts and nuts for membrane flashing.
 1. Underdeck Clamp: Clamping ring with set screws.

2.6 ESCUTCHEONS

- A. Description: Manufactured wall and ceiling escutcheons and floor plates, with an ID to closely fit around pipe, tube, and insulation of insulated piping and an OD that completely covers opening.
- B. One-Piece, Deep-Pattern Type: Deep-drawn, box-shaped brass with polished chrome-plated finish.
- C. One-Piece, Cast-Brass Type: With set screw.
 1. Finish: Polished chrome-plated and rough brass.
- D. Split-Casting, Cast-Brass Type: With concealed hinge and set screw.
 1. Finish: Polished chrome-plated and rough brass.
- E. One-Piece, Stamped-Steel Type: With set screw or spring clips and chrome-plated finish.

- F. Split-Plate, Stamped-Steel Type: With concealed hinge, set screw or spring clips, and chrome-plated finish.
- G. One-Piece, Floor-Plate Type: Cast-iron floor plate.
- H. Split-Casting, Floor-Plate Type: Cast brass with concealed hinge and set screw.

2.7 GROUT

- A. Description: ASTM C 1107, Grade B, nonshrink and nonmetallic, dry hydraulic-cement grout.
 - 1. Characteristics: Post-hardening, volume-adjusting, nonstaining, noncorrosive, nongaseous, and recommended for interior and exterior applications.
 - 2. Design Mix: 5000-psi, 28-day compressive strength.
 - 3. Packaging: Premixed and factory packaged.

PART 3 - EXECUTION

3.1 FIRE-SUPPRESSION DEMOLITION

- A. Refer to Division 01 Section "Cutting and Patching" and Division 02 Section "Selective Structure Demolition" for general demolition requirements and procedures.
- B. Disconnect, demolish, and remove fire-suppression systems, equipment, and components indicated to be removed.
 - 1. Piping to Be Removed: Remove portion of piping indicated to be removed and cap or plug remaining piping with same or compatible piping material.
 - 2. Equipment to Be Removed: Disconnect and cap services and remove equipment.
 - 3. Equipment to Be Removed and Reinstalled: Disconnect and cap services and remove, clean, and store equipment; when appropriate, reinstall, reconnect, and make equipment operational.
 - 4. Equipment to Be Removed and Salvaged: Disconnect and cap services and remove equipment and deliver to Owner.
- C. If pipe, insulation, or equipment to remain is damaged in appearance or is unserviceable, remove damaged or unserviceable portions and replace with new products of equal capacity and quality.

3.2 PIPING SYSTEMS - COMMON REQUIREMENTS

- A. Install piping according to the following requirements and Division 21 Sections specifying piping systems.

- B. Drawing plans, schematics, and diagrams indicate general location and arrangement of piping systems. Indicated locations and arrangements were used to size pipe and calculate friction loss, expansion, pump sizing, and other design considerations. Install piping as indicated unless deviations to layout are approved on Coordination Drawings.
- C. Install piping in concealed locations, unless otherwise indicated and except in equipment rooms and service areas.
- D. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- E. Install piping above accessible ceilings to allow sufficient space for ceiling panel removal.
- F. Install piping to permit valve servicing.
- G. Install piping at indicated slopes.
- H. Install piping free of sags and bends.
- I. Install fittings for changes in direction and branch connections.
- J. Install piping to allow application of insulation.
- K. Select system components with pressure rating equal to or greater than system operating pressure.
- L. Install escutcheons for penetrations of walls, ceilings, and floors according to the following:
 - 1. New Piping:
 - a. Piping with Fitting or Sleeve Protruding from Wall: One-piece, deep-pattern type.
 - b. Chrome-Plated Piping: One-piece, cast-brass type with polished chrome-plated finish.
 - c. Insulated Piping: One-piece, stamped-steel type with spring clips.
 - d. Bare Piping at Wall and Floor Penetrations in Finished Spaces: One-piece, cast-brass type with polished chrome-plated finish.
 - e. Bare Piping at Wall and Floor Penetrations in Finished Spaces: One-piece, stamped-steel type.
 - f. Bare Piping at Ceiling Penetrations in Finished Spaces: One-piece or split-casting, cast-brass type with polished chrome-plated finish.
 - g. Bare Piping at Ceiling Penetrations in Finished Spaces: One-piece, stamped-steel type or split-plate, stamped-steel type with concealed hinge and set screw.
 - h. Bare Piping in Unfinished Service Spaces: One-piece, cast-brass type with rough-brass finish.

- i. Bare Piping in Unfinished Service Spaces: One-piece, stamped-steel type with concealed or exposed-rivet hinge and set screw or spring clips.
 - j. Bare Piping in Equipment Rooms: One-piece, cast-brass type.
 - k. Bare Piping in Equipment Rooms: One-piece, stamped-steel type with set screw or spring clips.
 - l. Bare Piping at Floor Penetrations in Equipment Rooms: One-piece, floor-plate type.
- M. Sleeves are not required for core-drilled holes.
- N. Permanent sleeves are not required for holes formed by removable PE sleeves.
- O. Install sleeves for pipes passing through concrete and masonry walls and concrete floor and roof slabs.
- P. Install sleeves for pipes passing through concrete and masonry walls, gypsum-board partitions, and concrete floor and roof slabs.
- 1. Cut sleeves to length for mounting flush with both surfaces.
 - a. Exception: Extend sleeves installed in floors of mechanical equipment areas or other wet areas 2 inches above finished floor level. Extend cast-iron sleeve fittings below floor slab as required to secure clamping ring if ring is specified.
 - 2. Install sleeves in new walls and slabs as new walls and slabs are constructed.
 - 3. Install sleeves that are large enough to provide 1/4-inch annular clear space between sleeve and pipe or pipe insulation. Use the following sleeve materials:
 - a. Steel Pipe Sleeves: For pipes smaller than NPS 6.
 - b. Steel Sheet Sleeves: For pipes NPS 6 and larger, penetrating gypsum-board partitions.
 - c. Stack Sleeve Fittings: For pipes penetrating floors with membrane waterproofing. Secure flashing between clamping flanges. Install section of cast-iron soil pipe to extend sleeve to 2 inches above finished floor level. Refer to Division 07 Section "Sheet Metal Flashing and Trim" for flashing.
 - 1) Seal space outside of sleeve fittings with grout.
 - 4. Except for underground wall penetrations, seal annular space between sleeve and pipe or pipe insulation, using joint sealants appropriate for size, depth, and location of joint. Refer to Division 07 Section "Joint Sealants" for materials and installation.

- Q. Fire-Barrier Penetrations: Maintain indicated fire rating of walls, partitions, ceilings, and floors at pipe penetrations. Seal pipe penetrations with firestop materials. Refer to Division 07 Section "Penetration Firestopping" for materials.
- R. Verify final equipment locations for roughing-in.
- S. Refer to equipment specifications in other Sections of these Specifications for roughing-in requirements.

3.3 PIPING JOINT CONSTRUCTION

- A. Join pipe and fittings according to the following requirements and Division 21 Sections specifying piping systems.
- B. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
- C. Remove scale, slag, dirt, and debris from inside and outside of pipe and fittings before assembly.
- D. Threaded Joints: Thread pipe with tapered pipe threads according to ASME B1.20.1. Cut threads full and clean using sharp dies. Ream threaded pipe ends to remove burrs and restore full ID. Join pipe fittings and valves as follows:
 - 1. Apply appropriate tape or thread compound to external pipe threads unless dry seal threading is specified.
 - 2. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged. Do not use pipe sections that have cracked or open welds.
- E. Flanged Joints: Select appropriate gasket material, size, type, and thickness for service application. Install gasket concentrically positioned. Use suitable lubricants on bolt threads.
- F. Grooved Joints: Comply with manufacturer's installation instructions.

3.4 PAINTING

- A. Painting of fire-suppression systems, equipment, and components is specified in Division 09 Sections "Interior/Exterior Painting".
- B. Damage and Touchup: Repair marred and damaged factory-painted finishes with materials and procedures to match original factory finish.

3.5 ERECTION OF METAL SUPPORTS AND ANCHORAGES

- A. Cut, fit, and place miscellaneous metal supports accurately in location, alignment, and elevation to support and anchor fire-suppression materials and equipment.

- B. Field Welding: Comply with AWS D1.1.

3.6 GROUTING

- A. Mix and install grout for fire-suppression equipment base bearing surfaces, pump and other equipment base plates, and anchors.
- B. Clean surfaces that will come into contact with grout.
- C. Provide forms as required for placement of grout.
- D. Avoid air entrapment during placement of grout.
- E. Place grout, completely filling equipment bases.
- F. Place grout on concrete bases and provide smooth bearing surface for equipment.
- G. Place grout around anchors.
- H. Cure placed grout.

END OF SECTION 210500

SECTION 210517 - SLEEVES AND SLEEVE SEALS FOR FIRE-SUPPRESSION PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Sleeves.
 - 2. Stack-sleeve fittings.
 - 3. Sleeve-seal systems.
 - 4. Sleeve-seal fittings.
 - 5. Grout.
 - 6. Silicone sealants.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.

1.4 INFORMATIONAL SUBMITTALS

- A. Field quality-control reports.

PART 2 - PRODUCTS

2.1 SLEEVES

- A. Cast-Iron Pipe Sleeves: Cast or fabricated of cast or ductile iron and equivalent to ductile-iron pressure pipe, with plain ends and integral waterstop.
- B. Steel Pipe Sleeves: ASTM A53/A53M, Type E, Grade B, Schedule 40, anticorrosion coated or galvanized, with plain ends and integral welded waterstop collar.
- C. Galvanized-Steel Sheet Sleeves: 0.0239-inch (0.6-mm) minimum thickness; round tube closed with welded longitudinal joint.

2.2 STACK-SLEEVE FITTINGS

- A. Description: Manufactured, Dura-coated or Duco-coated cast-iron sleeve with integral clamping flange for use in waterproof floors and roofs. Include clamping ring, bolts, and nuts for membrane flashing.

1. Underdeck Clamp: Clamping ring with setscrews.

2.3 SLEEVE-SEAL SYSTEMS

- A. Description:

1. Modular sealing-element unit, designed for field assembly, for filling annular space between piping and sleeve.
2. Designed to form a hydrostatic seal of 20 psig (137 kPa) minimum.
3. Sealing Elements: EPDM-rubber interlocking links shaped to fit surface of pipe. Include type and number required for pipe material and size.
4. Connecting Bolts and Nuts: Carbon steel, with corrosion-resistant coating, ASTM B633 of length required to secure pressure plates to sealing elements.

2.4 SLEEVE-SEAL FITTINGS

- A. Description: Manufactured plastic, sleeve-type, waterstop assembly made for imbedding in concrete slab or wall.
- B. Plastic or rubber waterstop collar with center opening to match piping OD.

2.5 GROUT

- A. Description: Nonshrink, for interior and exterior sealing openings in non-fire-rated walls or floors.
- B. Standard: ASTM C1107/C1107M, Grade B, post-hardening and volume-adjusting, dry, hydraulic-cement grout.
- C. Design Mix: 5000-psi (34.5-MPa), 28-day compressive strength.
- D. Packaging: Premixed and factory packaged.

PART 3 - EXECUTION

3.1 SLEEVE INSTALLATION

- A. Install sleeves for piping passing through penetrations in floors, partitions, roofs, and walls.
- B. Reuse existing wall penetrations where possible.
- C. For sleeves that will have sleeve-seal system installed, select sleeves of size large enough to provide 1-inch (25-mm) annular clear space between piping and concrete slabs and walls.
 - 1. Sleeves are not required for core-drilled holes.
- D. Install sleeves in concrete floors, concrete roof slabs, and concrete walls as new slabs and walls are constructed.
 - 1. Permanent sleeves are not required for holes in slabs formed by molded-PE or -PP sleeves.
 - 2. Cut sleeves to length for mounting flush with both surfaces.
 - a. Exception: Extend sleeves installed in floors of mechanical equipment areas or other wet areas 2 inches (50 mm) above finished floor level.
 - 3. Using grout, seal space outside of sleeves in slabs and walls without sleeve-seal system.
- E. Install sleeves for pipes passing through interior partitions.
 - 1. Cut sleeves to length for mounting flush with both surfaces.
 - 2. Seal annular space between sleeve and piping or piping insulation; use joint sealants appropriate for size, depth, and location of joint.
- F. Fire-Resistance-Rated Penetrations, Horizontal Assembly Penetrations, and Smoke Barrier Penetrations: Maintain indicated fire or smoke rating of walls, partitions, ceilings, and floors at pipe penetrations. Seal pipe penetrations with fire- and smoke-stop materials.

3.2 STACK-SLEEVE-FITTING INSTALLATION

- A. Install stack-sleeve fittings in new slabs as slabs are constructed.
 - 1. Secure flashing between clamping flanges for pipes penetrating floors with membrane waterproofing.
 - 2. Install section of cast-iron soil pipe to extend sleeve to 2 inches (50 mm) above finished floor level.
 - 3. Extend cast-iron sleeve fittings below floor slab as required to secure clamping ring if ring is specified.
 - 4. Use silicone sealant to seal around the outside of stack-sleeve fittings.

- B. Fire-Resistance-Rated Penetrations, Horizontal Assembly Penetrations, and Smoke Barrier Penetrations: Maintain indicated fire or smoke rating of floors at pipe penetrations. Seal pipe penetrations with fire- or smoke-stop materials.

3.3 SLEEVE-SEAL-SYSTEM INSTALLATION

- A. Install sleeve-seal systems in sleeves in exterior concrete walls and slabs-on-grade at service piping entries into building.
- B. Select type, size, and number of sealing elements required for piping material and size and for sleeve ID or hole size. Position piping in center of sleeve. Center piping in penetration, assemble sleeve-seal system components, and install in annular space between piping and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make a watertight seal.

3.4 SLEEVE-SEAL-FITTING INSTALLATION

- A. Install sleeve-seal fittings in new walls and slabs as they are constructed.
- B. Assemble fitting components of length to be flush with both surfaces of concrete slabs and walls. Position waterstop flange to be centered in concrete slab or wall.
- C. Secure nailing flanges to concrete forms.
- D. Use grout, to seal the space around outside of sleeve-seal fittings.

3.5 FIELD QUALITY CONTROL

- A. Perform the following tests and inspections:
 - 1. Leak Test: After allowing for a full cure, test sleeves and sleeve seals for leaks. Repair leaks and retest until no leaks exist.
- B. Sleeves and sleeve seals will be considered defective if they do not pass tests and inspections.
- C. Prepare test and inspection reports.

3.6 SLEEVE AND SLEEVE-SEAL SCHEDULE

- A. Use sleeves and sleeve seals for the following piping-penetration applications:
 - 1. Exterior Concrete Walls above Grade:

- a. Piping Smaller Than NPS 6 (DN 150): Cast-iron pipe sleeves or Steel pipe sleeves.
 - b. Piping NPS 6 (DN 150) and Larger: Cast-iron pipe sleeves or Steel pipe sleeves.
2. Exterior Concrete Walls below Grade:
- a. Piping Smaller Than NPS 6 (DN 150): Cast-iron pipe sleeves with sleeve-seal system or Steel pipe sleeves with sleeve-seal system.
 - 1) Select sleeve size to allow for 1-inch (25-mm) annular clear space between piping and sleeve for installing sleeve-seal system.
 - b. Piping NPS 6 (DN 150) and Larger: Cast-iron pipe sleeves with sleeve-seal system or Steel pipe sleeves with sleeve-seal system.
 - 1) Select sleeve size to allow for 1-inch (25-mm) annular clear space between piping and sleeve for installing sleeve-seal system.
3. Interior Partitions:
- a. Piping Smaller Than NPS 6 (DN 150): Steel pipe sleeves.
 - b. Piping NPS 6 (DN 150) and Larger: Galvanized-steel sheet sleeves.

END OF SECTION 210517

SECTION 210518 - ESCUTCHEONS FOR FIRE-SUPPRESSION PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Escutcheons.
 - 2. Floor plates.

1.3 DEFINITIONS

- A. Existing Piping to Remain: Existing piping that is not to be removed and that is not otherwise indicated to be removed, removed and salvaged, or removed and reinstalled.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - 1. BrassCraft Manufacturing Co.; a Masco company.
 - 2. Dearborn Brass.
 - 3. Jones Stephens Corp.
 - 4. Keeney Manufacturing Company (The).
 - 5. Mid-America Fittings, LLC; A Midland Industries Company.

2.2 ESCUTCHEONS

- A. One-Piece, Steel Type: With polished, chrome-plated finish and setscrew fastener.
- B. One-Piece, Stainless-Steel Type: With polished stainless-steel finish.
- C. One-Piece, Cast-Brass Type: With polished, chrome-plated finish and setscrew fastener.
- D. One-Piece, Deep-Pattern Type: Deep-drawn, box-shaped steel with polished, chrome-plated finish and spring-clip fasteners.
- E. One-Piece, Stamped-Steel Type: With polished, chrome-plated finish and spring-clip fasteners.
- F. Split-Plate, Stamped-Steel Type: With polished, chrome-plated finish; concealed and exposed-rivet hinge; and spring-clip fasteners.

2.3 FLOOR PLATES

- A. Split Floor Plates: Steel with concealed hinge.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install escutcheons for piping penetrations of walls, ceilings, and finished floors.
- B. Install escutcheons with ID to closely fit around pipe, tube, and insulation of piping and with OD that completely covers opening.
 - 1. Escutcheons for New Piping:
 - a. Piping with Fitting or Sleeve Protruding from Wall: One-piece, deep pattern.
 - b. Chrome-Plated Piping: One-piece steel with polished, chrome-plated finish.
 - c. Insulated Piping: One-piece steel with polished, chrome-plated finish.
 - d. Bare Piping at Wall and Floor Penetrations in Finished Spaces: One-piece steel with polished, chrome-plated finish.
 - e. Bare Piping at Ceiling Penetrations in Finished Spaces: One-piece steel with polished, chrome-plated finish.
 - f. Bare Piping in Unfinished Service Spaces: One-piece steel with polished, chrome-plated finish.
 - g. Bare Piping in Equipment Rooms: One-piece steel with polished, chrome-plated finish.
- C. Install floor plates for piping penetrations of equipment-room floors.

- D. Install floor plates with ID to closely fit around pipe, tube, and insulation of piping and with OD that completely covers opening.
 - 1. New Piping: One-piece, floor plate.
 - 2. Existing Piping: Split floor plate.

3.2 FIELD QUALITY CONTROL

- A. Using new materials, replace broken and damaged escutcheons and floor plates.

END OF SECTION 210518

SECTION 210523 - GENERAL-DUTY VALVES FOR WATER-BASED FIRE-SUPPRESSION PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Two-piece ball valves with indicators.
 - 2. Iron butterfly valves with indicators.
 - 3. Check valves.
 - 4. Iron OS&Y gate valves.
 - 5. Trim and drain valves.

1.3 DEFINITIONS

- A. NRS: Nonrising stem.
- B. OS&Y: Outside screw and yoke.
- C. SBR: Styrene-butadiene rubber.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of valve.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Prepare valves for shipping as follows:
 - 1. Protect internal parts against rust and corrosion.
 - 2. Protect threads, flange faces, and weld ends.
 - 3. Set valves open to minimize exposure of functional surfaces.
- B. Use the following precautions during storage:

1. Maintain valve end protection.
 2. Store valves indoors and maintain at higher-than-ambient dew point temperature. If outdoor storage is necessary, store valves off the ground in watertight enclosures.
- C. Use sling to handle large valves; rig sling to avoid damage to exposed parts. Do not use operating handles or stems as lifting or rigging points.
- D. Protect flanges and specialties from moisture and dirt.

PART 2 - PRODUCTS

2.1 SOURCE LIMITATIONS

- A. Obtain each type of valve from single manufacturer.

2.2 PERFORMANCE REQUIREMENTS

- A. UL Listed: Valves shall be listed in UL's "Online Certifications Directory" under the headings listed below and shall bear UL mark:
1. Fire Main Equipment: HAMV - Main Level
 - a. Indicator Posts, Gate Valve: HCBZ - Level 1
 - b. Ball Valves, System Control: HLUG - Level 3
 - c. Butterfly Valves: HLXS - Level 3
 - d. Check Valves: HMER - Level 3
 - e. Gate Valves: HMRZ - Level 3
 2. Sprinkler System & Water Spray System Devices: VDGT - Main Level
 - a. Valves, Trim and Drain: VQGU - Level 1
- B. FM Global Approved: Valves shall be listed in its "Approval Guide," under the headings listed below:
1. Automated Sprinkler Systems:
 - a. Indicator posts.
 - b. Valves.
 - 1) Gate valves.
 - 2) Check valves
 - 3) Miscellaneous valves.

- C. ASME Compliance:

1. ASME B1.20.1 for threads for threaded-end valves.
 2. ASME B16.1 for flanges on iron valves.
 3. ASME B31.9 for building services piping valves.
- D. AWWA Compliance: Comply with AWWA C606 for grooved-end connections.
- E. NFPA Compliance for valves:
1. Comply with NFPA 13, NFPA 14, NFPA 20, and NFPA 24.
- F. Valve Pressure Ratings: Not less than the minimum pressure rating indicated or higher, as required by system pressures.
- G. Valve Sizes: Same as upstream piping unless otherwise indicated.
- H. Valve Actuator Types:
1. Worm-gear actuator with handwheel for quarter-turn valves, except for trim and drain valves.
 2. Handwheel: For other than quarter-turn trim and drain valves.
 3. Handlever: For quarter-turn trim and drain valves NPS 2 (DN 50) and smaller.

2.3 TWO-PIECE BALL VALVES WITH INDICATORS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
1. Ames Fire & Waterworks; A Watts Water Technologies Company.
 2. NIBCO INC.
 3. Victaulic Company.
- B. Description:
1. UL 1091, except with ball instead of disc and FM Global approved for indicating valves (butterfly or ball type), Class Number 1112.
 2. Minimum Pressure Rating: 175 psig (1200 kPa).
 3. Body Design: Two piece.
 4. Body Material: Forged brass or bronze.
 5. Port Size: Full or standard.
 6. Seats: PTFE.
 7. Stem: Bronze or stainless steel.
 8. Ball: Chrome-plated brass.
 9. Actuator: Worm gear
 10. Supervisory Switch: Internal or external.
 11. End Connections for Valves NPS 1 (DN 25) through NPS 2 (DN 50): Threaded ends.
 12. End Connections for Valves NPS 2-1/2 (DN 65): Grooved ends.

2.4 IRON BUTTERFLY VALVES WITH INDICATORS

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. Anvil; an ASC Engineered Solution.
2. Globe Fire Sprinkler Corporation.
3. NIBCO INC.
4. Tyco Fire Products; brand of Johnson Controls International plc, Building Solutions North America.
5. Victaulic Company.
6. Zurn Industries, LLC.

B. Description:

1. Standard: UL 1091 and FM Global standard for indicating valves, (butterfly or ball type), Class Number 112.
2. Minimum Pressure Rating: 175 psig (1200 kPa).
3. Body Material: Cast or ductile iron with nylon, EPDM, epoxy, or polyamide coating.
4. Seat Material: EPDM.
5. Stem: Stainless steel.
6. Disc: Ductile iron, nickel plated.
7. Actuator: Worm gear.
8. Supervisory Switch: Internal or external.
9. Body Design: Lug or wafer connections.

2.5 CHECK VALVES

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. Anvil; an ASC Engineered Solution.
2. Globe Fire Sprinkler Corporation.
3. NIBCO INC.
4. Tyco Fire Products; brand of Johnson Controls International plc, Building Solutions North America.
5. Victaulic Company.
6. Viking Group Inc.
7. WATTS; A Watts Water Technologies Company.
8. Zurn Industries, LLC.

B. Description:

1. Standard: UL 312 and FM Global standard for swing check valves, Class Number 1210.
2. Minimum Pressure Rating: 175 psig (1200 kPa).
3. Type: Single swing check.

4. Body Material: Cast iron, ductile iron, or bronze.
5. Clapper: Bronze, ductile iron, or stainless steel with elastomeric seal.
6. Clapper Seat: Brass, bronze, or stainless steel.
7. Hinge Shaft: Bronze or stainless steel.
8. Hinge Spring: Stainless steel.
9. End Connections: Flanged, grooved, or threaded.

2.6 IRON OS&Y GATE VALVES

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. Hammond Valve.
2. Mueller Co. LLC; Mueller Water Products, Inc.
3. NIBCO INC.
4. Victaulic Company.
5. WATTS; A Watts Water Technologies Company.
6. Zurn Industries, LLC.

- B. Description:

1. Standard: UL 262 and FM Global standard for fire-service water control valves (OS&Y- and NRS-type gate valves).
2. Minimum Pressure Rating: 175 psig (1200 kPa).
3. Body and Bonnet Material: Cast or ductile iron.
4. Wedge: Cast or ductile iron, or bronze with elastomeric coating.
5. Wedge Seat: Cast or ductile iron, or bronze with elastomeric coating.
6. Stem: Brass or bronze.
7. Packing: Non-asbestos PTFE.
8. Supervisory Switch: External.
9. End Connections: Flanged.

2.7 TRIM AND DRAIN VALVES

- A. Ball Valves:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Apollo Valves; a part of Aalberts Integrated Piping Systems.
 - b. Jomar Valve.
 - c. Milwaukee Valve Company.
 - d. NIBCO INC.
 - e. Tyco Fire Products; brand of Johnson Controls International plc, Building Solutions North America.

- f. Victaulic Company.
- g. WATTS; A Watts Water Technologies Company.
- h. Zurn Industries, LLC.

2. Description:

- a. Pressure Rating: 175 psig (1200 kPa).
- b. Body Design: Two piece.
- c. Body Material: Forged brass or bronze.
- d. Port size: Full or standard.
- e. Seats: PTFE.
- f. Stem: Bronze or stainless steel.
- g. Ball: Chrome-plated brass.
- h. Actuator: Handlever.
- i. End Connections for Valves NPS 1 (DN 25) through NPS 2-1/2 (DN 65): Threaded ends.
- j. End Connections for Valves NPS 1-1/4 and NPS 2-1/2 (DN 32 and DN 65): Grooved ends.

B. Angle Valves:

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:

- a. NIBCO INC.
- b. United Brass Works, Inc.

2. Description:

- a. Pressure Rating: 175 psig (1200 kPa).
- b. Body Material: Brass or bronze.
- c. Ends: Threaded.
- d. Stem: Bronze.
- e. Disc: Bronze.
- f. Packing: Asbestos free.
- g. Handwheel: Malleable iron, bronze, or aluminum.

C. Globe Valves:

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:

- a. NIBCO INC.
- b. United Brass Works, Inc.

2. Description:

- a. Pressure Rating: 175 psig (1200 kPa).
- b. Body Material: Bronze with integral seat and screw-in bonnet.
- c. Ends: Threaded.
- d. Stem: Bronze.
- e. Disc Holder and Nut: Bronze.
- f. Disc Seat: Nitrile.
- g. Packing: Asbestos free.
- h. Handwheel: Malleable iron, bronze, or aluminum.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine valve interior for cleanliness, freedom from foreign matter, and corrosion. Remove special packing materials, such as blocks, used to prevent disc movement during shipping and handling.
- B. Operate valves in positions from fully open to fully closed. Examine guides and seats made accessible by such operations.
- C. Examine threads on valve and mating pipe for form and cleanliness.
- D. Examine mating flange faces for conditions that might cause leakage. Check bolting for proper size, length, and material. Verify that gasket is of proper size, that its material composition is suitable for service, and that it is free from defects and damage.
- E. Do not attempt to repair defective valves; replace with new valves.

3.2 INSTALLATION, GENERAL

- A. Comply with requirements in the following Sections for specific valve-installation requirements and applications:
 1. Section 211316 "Dry-Pipe Sprinkler Systems" for application of valves in dry-pipe, fire-suppression sprinkler systems.
- B. Install listed fire-protection shutoff valves supervised-open, located to control sources of water supply, except from fire-department connections. Install permanent identification signs, indicating portion of system controlled by each valve.
- C. Install double-check valve assembly in each fire-protection water-supply connection.

- D. Install valves having threaded connections with unions at each piece of equipment arranged to allow easy access, service, maintenance, and equipment removal without system shutdown. Provide separate support where necessary.
- E. Install valves in horizontal piping with stem at or above the pipe center.
- F. Install valves in position to allow full stem movement.
- G. Install valve tags. Comply with requirements in Section 210553 "Identification for Fire-Suppression Piping and Equipment" for valve tags and schedules and signs on surfaces concealing valves; and the NFPA standard applying to the piping system in which valves are installed. Install permanent identification signs indicating the portion of system controlled by each valve.

END OF SECTION 210523

SECTION 210529 - HANGERS AND SUPPORTS FOR FIRE-SUPPRESSION PIPING AND EQUIPMENT

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Metal pipe hangers and supports.
 - 2. Trapeze pipe hangers.
 - 3. Metal framing systems.
 - 4. Thermal hanger-shield inserts.
 - 5. Fastener systems.
 - 6. Equipment supports.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: Show fabrication and installation details and include calculations for the following:
 - 1. Trapeze pipe hangers.
 - 2. Metal framing systems.
 - 3. Equipment supports.

1.4 INFORMATIONAL SUBMITTALS

- A. Welding certificates.

1.5 QUALITY ASSURANCE

- A. Structural-Steel Welding Qualifications: Qualify procedures and personnel according to AWS D1.1/D1.1M.

- B. Pipe Welding Qualifications: Qualify procedures and operators according to 2015 ASME Boiler and Pressure Vessel Code, Section IX.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Structural Performance: Hangers and supports for fire-suppression piping and equipment shall withstand the effects of gravity loads and stresses within limits and under conditions indicated according to ASCE/SEI 7.
 - 1. Design supports for multiple pipes, including pipe stands, capable of supporting combined weight of supported systems, system contents, and test water.
 - 2. Design equipment supports capable of supporting combined operating weight of supported equipment and connected systems and components.
- B. NFPA Compliance: Comply with NFPA 13.
- C. UL Compliance: Comply with UL 203.

2.2 METAL PIPE HANGERS AND SUPPORTS

- A. Carbon-Steel Pipe Hangers and Supports:
 - 1. Description: Factory-fabricated components, NFPA approved, UL listed, or FM approved for fire-suppression piping support.
 - 2. Galvanized Metallic Coatings: Pregalvanized or hot-dip galvanized.
 - 3. Hanger Rods: Continuous-thread rod, nuts, and washer made of carbon steel.

2.3 TRAPEZE PIPE HANGERS

- A. Description: MSS SP-58, Type 59, shop- or field-fabricated pipe-support assembly, made from structural-carbon-steel shapes, with NFPA-approved, UL-listed, or FM-approved carbon-steel hanger rods, nuts, saddles, and U-bolts.

2.4 METAL FRAMING SYSTEMS

- A. MFMA Manufacturer Metal Framing Systems:
 - 1. Description: Shop- or field-fabricated pipe-support assembly, made of steel channels, accessories, fittings, and other components for supporting multiple parallel pipes.
 - 2. Standard: Comply with MFMA-4, factory-fabricated components for field assembly.
 - 3. Channels: Continuous slotted carbon-steel channel with inturned lips.
 - 4. Channel Width: Selected for applicable load criteria.

5. Channel Nuts: Formed or stamped nuts or other devices designed to fit into channel slot and, when tightened, prevent slipping along channel.
6. Hanger Rods: Continuous-thread rod, nuts, and washer made of carbon steel.
7. Paint Coating: Green epoxy, acrylic, or urethane.

B. Non-MFMA Manufacturer Metal Framing Systems:

1. Description: Shop- or field-fabricated pipe-support assembly, made of steel channels, accessories, fittings, and other components for supporting multiple parallel pipes.
2. Standard: Comply with MFMA-4, factory-fabricated components for field assembly.
3. Channels: Continuous slotted carbon-steel channel with inturned lips.
4. Channel Width: Select for applicable load criteria.
5. Channel Nuts: Formed or stamped nuts or other devices designed to fit into channel slot and, when tightened, prevent slipping along channel.
6. Hanger Rods: Continuous-thread rod, nuts, and washer made of carbon steel.
7. Paint Coating: Green epoxy, acrylic, or urethane.

2.5 THERMAL HANGER-SHIELD INSERTS

- A. Insulation-Insert Material: Water-repellent-treated, ASTM C533, Type I calcium silicate with 100-psi (688-kPa) minimum compressive strength.
- B. For Trapeze or Clamped Systems: Insert and shield shall cover entire circumference of pipe.
- C. For Clevis or Band Hangers: Insert and shield shall cover lower 180 degrees of pipe.
- D. Insert Length: Extend 2 inches (50 mm) beyond sheet metal shield for piping operating below ambient air temperature.

2.6 FASTENER SYSTEMS

- A. Powder-Actuated Fasteners: NFPA-approved, UL-listed, or FM-approved threaded-steel stud, for use in hardened portland cement concrete, with pull-out, tension, and shear capacities appropriate for supported loads and building materials where used.

2.7 EQUIPMENT SUPPORTS

- A. Description: NFPA-approved, UL-listed, or FM-approved, welded, shop- or field-fabricated equipment support, made from structural-carbon-steel shapes.

2.8 MATERIALS

- A. Aluminum: ASTM B221 (ASTM B221M).

- B. Carbon Steel: ASTM A1011/A1011M.
- C. Structural Steel: ASTM A36/A36M, carbon-steel plates, shapes, and bars; black and galvanized.
- D. Stainless Steel: ASTM A240/A240M.
- E. Grout: ASTM C1107/C1107M, factory-mixed and -packaged, dry, hydraulic-cement, nonshrink and nonmetallic grout, suitable for interior and exterior applications.
 - 1. Properties: Nonstaining, noncorrosive, and nongaseous.
 - 2. Design Mix: 5000-psi (34.5-MPa), 28-day compressive strength.

PART 3 - EXECUTION

3.1 APPLICATION

- A. Install firestopping materials and installation, for penetrations through fire-rated walls, ceilings, and assemblies.
- B. Strength of Support Assemblies: Where not indicated, select sizes of components, so strength will be adequate to carry present and future static loads within specified loading limits. Minimum static design load used for strength determination shall be weight of supported components plus 200 lb (90 kg).

3.2 INSTALLATION OF HANGERS AND SUPPORTS

- A. Metal Pipe-Hanger Installation: Comply with installation requirements of approvals and listings. Install hangers, supports, clamps, and attachments as required to properly support piping from building structure.
- B. Metal Trapeze Pipe-Hanger Installation: Comply with MSS SP-58. Arrange for grouping of parallel runs of horizontal piping, and support together on field-fabricated trapeze pipe hangers.
 - 1. Pipes of Various Sizes: Support together and space trapezes for smallest pipe size, or install intermediate supports for smaller-diameter pipes as specified for individual pipe hangers.
 - 2. Field fabricate from ASTM A36/A36M carbon-steel shapes selected for loads being supported. Weld steel according to AWS D1.1/D1.1M.
- C. Metal Framing System Installation: Arrange for grouping of parallel runs of piping, and support together on field-assembled metal strut systems.
- D. Thermal Hanger-Shield Installation: Install in pipe hanger or shield for insulated piping.
- E. Fastener System Installation:

1. Install powder-actuated fasteners for use in lightweight concrete or concrete slabs less than 4 inches (100 mm) thick in concrete, after concrete is placed and completely cured. Use operators that are licensed by powder-actuated tool manufacturer. Install fasteners according to powder-actuated tool manufacturer's operating manual. Install in accordance with approvals and listings.
 2. Install mechanical-expansion anchors in concrete, after concrete is placed and completely cured. Install fasteners according to manufacturer's written instructions. Install in accordance with approvals and listings.
- F. Install hangers and supports complete with necessary attachments, inserts, bolts, rods, nuts, washers, and other accessories.
- G. Equipment Support Installation: Fabricate from welded-structural-steel shapes.
- H. Install hangers and supports to allow controlled thermal and seismic movement of piping systems, to permit freedom of movement between pipe anchors, and to facilitate action of expansion joints, expansion loops, expansion bends, and similar units.
- I. Install lateral bracing with pipe hangers and supports to prevent swaying.
- J. Install building attachments within concrete slabs or attach to structural steel. Install additional attachments at concentrated loads, including valves, flanges, and strainers, NPS 2-1/2 (DN 65) and larger and at changes in direction of piping. Install concrete inserts before concrete is placed; fasten inserts to forms, and install reinforcing bars through openings at top of inserts.
- K. Load Distribution: Install hangers and supports, so that piping live and dead loads and stresses from movement will not be transmitted to connected equipment.
- L. Pipe Slopes: Install hangers and supports to provide indicated pipe slopes and to not exceed maximum pipe deflections allowed by ASME B31.9 for building services piping.
- M. Insulated Piping:
1. Attach clamps and spacers to piping.
 - a. Piping Operating Above Ambient Air Temperature: Clamp may project through insulation.
 - b. Piping Operating Below Ambient Air Temperature: Use thermal hanger-shield insert with clamp sized to match OD of insert.
 - c. Do not exceed pipe stress limits allowed by ASME B31.9 for building services piping.
 2. Install MSS SP-58, Type 39 protection saddles if insulation without vapor barrier is indicated. Fill interior voids with insulation that matches adjoining insulation.

- a. MSS SP-58, Type 39 Option: Thermal hanger-shield inserts may be used. Include steel weight-distribution plate for pipe NPS 4 (DN 100) and larger if pipe is installed on rollers.
3. Install MSS SP-58, Type 40 protective shields on cold piping with vapor barrier. Shields shall span an arc of 180 degrees.
 - a. MSS SP-58, Type 40 Option: Thermal hanger-shield inserts may be used. Include steel weight-distribution plate for pipe NPS 4 (DN 100) and larger if pipe is installed on rollers.
4. Shield Dimensions for Pipe: Not less than the following:
 - a. NPS 1/4 to NPS 3-1/2 (DN 8 to DN 90): 12 inches (305 mm) long and 0.048 inch (1.22 mm) thick.
 - b. NPS 4 (DN 100): 12 inches (305 mm) long and 0.06 inch (1.52 mm) thick.
 - c. NPS 5 and NPS 6 (DN 125 and DN 150): 18 inches (457 mm) long and 0.06 inch (1.52 mm) thick.
 - d. NPS 8 to NPS 14 (DN 200 to DN 350): 24 inches (610 mm) long and 0.075 inch (1.91 mm) thick.
 - e. NPS 16 to NPS 24 (DN 400 to DN 600): 24 inches (610 mm) long and 0.105 inch (2.67 mm) thick.
5. Pipes NPS 8 (DN 200) and Larger: Include wood or reinforced calcium-silicate-insulation inserts of length at least as long as protective shield.
6. Thermal Hanger Shields: Install with insulation of same thickness as piping insulation.

3.3 INSTALLATION OF EQUIPMENT SUPPORTS

- A. Fabricate structural-steel stands to suspend equipment from structure overhead or to support equipment above floor.
- B. Grouting: Place grout under supports for equipment, and make bearing surface smooth.
- C. Provide lateral bracing, to prevent swaying, for equipment supports.

3.4 METAL FABRICATIONS

- A. Cut, drill, and fit miscellaneous metal fabrications for trapeze pipe hangers and equipment supports.
- B. Fit exposed connections together to form hairline joints. Field weld connections that cannot be shop welded because of shipping size limitations.

- C. Field Welding: Comply with AWS D1.1/D1.1M procedures for shielded, metal arc welding; appearance and quality of welds; and methods used in correcting welding work; and with the following:
 - 1. Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
 - 2. Obtain fusion without undercut or overlap.
 - 3. Remove welding flux immediately.
 - 4. Finish welds at exposed connections, so no roughness shows after finishing and so contours of welded surfaces match adjacent contours.

3.5 ADJUSTING

- A. Hanger Adjustments: Adjust hangers to distribute loads equally on attachments and to achieve indicated slope of pipe.
- B. Trim excess length of continuous-thread hanger and support rods to 1-1/2 inches (40 mm).

3.6 PAINTING

- A. Touchup:
 - 1. Clean field welds and abraded, shop-painted areas. Paint exposed areas immediately after erecting hangers and supports. Use same materials as those used for shop painting. Comply with SSPC-PA 1 requirements for touching up field-painted surfaces.
 - a. Apply paint by brush or spray to provide a minimum dry film thickness of 2.0 mils (0.05 mm).
- B. Galvanized Surfaces: Clean welds, bolted connections, and abraded areas, and apply galvanizing-repair paint to comply with ASTM A780/A780M.

3.7 HANGER AND SUPPORT SCHEDULE

- A. Specific hanger and support requirements are in Sections specifying piping systems and equipment.
- B. Comply with NFPA requirements for pipe-hanger selections and applications that are not specified in piping system Sections.
- C. Use hangers and supports with galvanized metallic coatings for piping and equipment that will not have field-applied finishes.

- D. Use nonmetallic coatings on attachments for electrolytic protection where attachments are in direct contact with copper tubing.
- E. Use carbon-steel pipe hangers and supports and attachments for general service applications.
- F. Use thermal hanger-shield inserts for insulated piping and tubing.
- G. Horizontal-Piping Hangers and Supports: Comply with NFPA requirements. Unless otherwise indicated and except as specified in piping system Sections, install the following types:
 - 1. Adjustable, Steel Clevis Hangers (MSS Type 1): For suspension of noninsulated or insulated, stationary pipes NPS 1/2 to NPS 30 (DN 15 to DN 750).
 - 2. Steel Pipe Clamps (MSS Type 4): For suspension of NPS 1/2 to NPS 24 (DN 15 to DN 600) if little or no insulation is required.
 - 3. Adjustable, Swivel-Ring Band Hangers (MSS Type 10): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8 (DN 15 to DN 200).
 - 4. Split Pipe Ring with or without Turnbuckle Hangers (MSS Type 11): For suspension of noninsulated, stationary pipes NPS 3/8 to NPS 8 (DN 10 to DN 200).
 - 5. Extension Hinged or Two-Bolt Split Pipe Clamps (MSS Type 12): For suspension of noninsulated, stationary pipes NPS 3/8 to NPS 3 (DN 10 to DN 80).
 - 6. U-Bolts (MSS Type 24): For support of heavy pipes NPS 1/2 to NPS 30 (DN 15 to DN 750).
 - 7. Pipe Saddle Supports (MSS Type 36): For support of pipes NPS 4 to NPS 36 (DN 100 to DN 900), with steel-pipe base stanchion support and cast-iron floor flange or carbon-steel plate.
 - 8. Pipe Stanchion Saddles (MSS Type 37): For support of pipes NPS 4 to NPS 36 (DN 100 to DN 900), with steel-pipe base stanchion support and cast-iron floor flange or carbon-steel plate, and with U-bolt to retain pipe.
 - 9. Adjustable Pipe Saddle Supports (MSS Type 38): For stanchion-type support for pipes NPS 2-1/2 to NPS 36 (DN 65 to DN 900) if vertical adjustment is required, with steel-pipe base stanchion support and cast-iron floor flange.
- H. Vertical-Piping Clamps: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
 - 1. Extension Pipe or Riser Clamps (MSS Type 8): For support of pipe risers NPS 3/4 to NPS 24 (DN 24 to DN 600).
 - 2. Carbon- or Alloy-Steel Riser Clamps (MSS Type 42): For support of pipe risers NPS 3/4 to NPS 24 (DN 20 to DN 600) if longer ends are required for riser clamps.
- I. Hanger-Rod Attachments: Comply with NFPA requirements.
- J. Building Attachments: Comply with NFPA requirements. Unless otherwise indicated and except as specified in piping system Sections, install the following types:
 - 1. Steel or Malleable-Concrete Inserts (MSS Type 18): For upper attachment to suspend pipe hangers from concrete ceiling.

2. C-Clamps (MSS Type 23): For structural shapes.
 3. Side-Beam Brackets (MSS Type 34): For sides of steel or wooden beams.
- K. Saddles and Shields: Comply with NFPA requirements. Unless otherwise indicated and except as specified in piping system Sections, install the following types:
1. Steel-Pipe-Covering Protection Saddles (MSS Type 39): To fill interior voids with insulation that matches adjoining insulation.
 2. Protection Shields (MSS Type 40): Of length recommended in writing by manufacturer to prevent crushing insulation.
 3. Thermal Hanger-Shield Inserts: For supporting insulated pipe.
- L. Comply with NFPA requirements for trapeze pipe-hanger selections and applications that are not specified in piping system Sections.
- M. Comply with MFMA-103 for metal framing system selections and applications that are not specified in piping system Sections.
- N. Use powder-actuated fasteners instead of building attachments where required in concrete construction.

END OF SECTION 210529

SECTION 210533 - HEAT TRACING FOR FIRE-SUPPRESSION PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes heat tracing for fire-suppression piping with the following electric heating cables:
 - 1. Self-regulating, parallel resistance.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
 - 1. Include rated capacities, operating characteristics, and furnished specialties and accessories.
 - 2. Schedule heating capacity, length of cable, spacing, and electrical power requirement for each electric heating cable required.
- B. Shop Drawings: For electric heating cable.
 - 1. Include plans, elevations, sections, and attachment details.
 - 2. Include diagrams for power, signal, and control wiring.

1.4 INFORMATIONAL SUBMITTALS

- A. Field quality-control reports.
- B. Sample Warranty: For special warranty.

1.5 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For electric heating cables to include in operation and maintenance manuals.

1.6 WARRANTY

- A. Special Warranty: Manufacturer agrees to repair or replace electric heating cable that fails in materials or workmanship within specified warranty period.
 - 1. Warranty Period: Three years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 SELF-REGULATING, PARALLEL-RESISTANCE HEATING CABLES

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - 1. Chromalox, Inc.
 - 2. RAYCHEM; brand of nVent Electrical plc.
- B. Comply with IEEE 515.1.
- C. Heating Element: Pair of parallel No. 16 AWG, nickel-coated, stranded copper bus wires embedded in crosslinked conductive polymer core, which varies heat output in response to temperature along its length. Terminate with waterproof, factory-assembled, nonheating leads with connectors at one end, and seal the opposite end watertight. Cable shall be capable of crossing over itself once without overheating.
- D. Electrical Insulating Jacket: Flame-retardant polyolefin.
- E. Cable Cover: Stainless-steel braid and polyolefin outer jacket with ultraviolet inhibitor.
- F. Maximum Operating Temperature (Power On): 150 deg F.
- G. Maximum Exposure Temperature (Power Off): 185 deg F.
- H. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- I. Based on Raychem XL-Trace Edge 5XLE1 (120V/1 Phase) or approved equal.

2.2 CONTROLS

- A. Refer to electrical drawings for power connection.

2.3 ACCESSORIES

- A. Cable Installation Accessories: Fiberglass tape, heat-conductive putty, cable ties, silicone end seals and splice kits, and installation clips all furnished by manufacturer, or as recommended in writing by manufacturer.
- B. Warning Labels: Refer to Section 210553 "Identification for Fire - Suppression Piping and Equipment."
- C. Warning Tape: Continuously printed "Electrical Tracing"; vinyl, at least 3 mils thick, and with pressure-sensitive, permanent, waterproof, self-adhesive back.
 - 1. Width for Markers on Pipes with OD, Including Insulation, Less Than 6 Inches: 3/4 inch minimum.
 - 2. Width for Markers on Pipes with OD, Including Insulation, 6 Inches or Larger: 1-1/2 inches minimum.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine surfaces and substrates to receive electric heating cables for compliance with requirements for installation tolerances and other conditions affecting performance.
 - 1. Ensure surfaces and pipes in contact with electric heating cables are free of burrs and sharp protrusions.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Install electric heating cable where indicated and according to NFPA 70 and NFPA 13.
- B. Install electric heating cables after piping has been tested and before insulation is installed.
- C. Install electric heating cables according to IEEE 515.1.
- D. Install insulation over piping with electric cables according to Section 210700 "Fire-Suppression Systems Insulation."
- E. Install warning tape on piping insulation where piping is equipped with electric heating cables.
- F. Set field-adjustable switches and circuit-breaker trip ranges.

3.3 CONNECTIONS

- A. Ground equipment according to Section 260526 "Grounding and Bonding for Electrical Systems."
- B. Connect wiring according to Section 260519 "Low-Voltage Electrical Power Conductors and Cables."

3.4 FIELD QUALITY CONTROL

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
- B. Manufacturer's Field Service: Engage a factory-authorized service representative to test and inspect components, assemblies, and equipment installations, including connections.
- C. Perform the following tests and inspections with the assistance of a factory-authorized service representative:
 - 1. Perform tests after cable installation but before application of coverings such as insulation, wall or ceiling construction, or concrete.
 - 2. Test cables for electrical continuity and insulation integrity before energizing.
 - 3. Test cables to verify rating and power input. Energize and measure voltage and current simultaneously.
- D. Repeat tests for continuity, insulation resistance, and input power after applying thermal insulation on pipe-mounted cables.
- E. Cables will be considered defective if they do not pass tests and inspections.
- F. Prepare test and inspection reports.

3.5 PROTECTION

- A. Protect installed heating cables, including nonheating leads, from damage during construction.
- B. Remove and replace damaged heat-tracing cables.

END OF SECTION 210533

SECTION 210553 - IDENTIFICATION FOR FIRE-SUPPRESSION PIPING AND EQUIPMENT

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Equipment labels.
 - 2. Warning signs and labels.
 - 3. Pipe labels.
 - 4. Valve tags.
 - 5. Warning tags.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Samples: For color, letter style, and graphic representation required for each identification material and device.
- C. Equipment-Label Schedule: Include a listing of all equipment to be labeled and the proposed content for each label.
- D. Valve Schedules: Valve numbering scheme.

PART 2 - PRODUCTS

2.1 EQUIPMENT LABELS

- A. Metal Labels for Equipment:
 - 1. Material and Thickness: Aluminum, 0.032 inch (0.8 mm) thick, with predrilled holes for attachment hardware.
 - 2. Letter Color: White.
 - 3. Background Color: Red.

4. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch (64 by 19 mm).
 5. Minimum Letter Size: 1/4 inch (6.4 mm) for name of units if viewing distance is less than 24 inches (600 mm), 1/2 inch (13 mm) for viewing distances up to 72 inches (1830 mm), and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
 6. Fasteners: Stainless-steel rivets or self-tapping screws.
 7. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- B. Label Content: Include equipment's Drawing designation or unique equipment number, Drawing numbers where equipment is indicated (plans, details, and schedules), and the Specification Section number and title where equipment is specified.
- C. Equipment-Label Schedule: For each item of equipment to be labeled, on 8-1/2-by-11-inch (A4) bond paper. Tabulate equipment identification number and identify Drawing numbers where equipment is indicated (plans, details, and schedules) and the Specification Section number and title where equipment is specified. Equipment schedule shall be included in operation and maintenance data.

2.2 WARNING SIGNS AND LABELS

- A. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/16 inch (1.6 mm) thick, with predrilled holes for attachment hardware.
- B. Letter Color: Black.
- C. Background Color: Yellow.
- D. Maximum Temperature: Able to withstand temperatures up to 160 deg F (71 deg C).
- E. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch (64 by 19 mm).
- F. Minimum Letter Size: 1/4 inch (6.4 mm) for name of units if viewing distance is less than 24 inches (600 mm), 1/2 inch (13 mm) for viewing distances up to 72 inches (1830 mm), and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
- G. Fasteners: Stainless-steel rivets or self-tapping screws.
- H. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- I. Label Content: Include caution and warning information, plus emergency notification instructions.

2.3 PIPE LABELS

- A. General Requirements for Manufactured Pipe Labels: Preprinted, color-coded, with lettering indicating service and showing flow direction according to ASME A13.1.
- B. Self-adhesive Pipe Labels: Printed plastic with contact-type, permanent-adhesive backing.
- C. Pipe-Label Contents: Include identification of piping service using same designations or abbreviations as used on Drawings, pipe size, and an arrow indicating flow direction.
 - 1. Flow-Direction Arrows: Integral with piping-system service lettering to accommodate both directions or as separate unit on each pipe label to indicate flow direction.
 - 2. Lettering Size: Size letters according to ASME A13.1 for piping.
- D. Pipe-Label Colors:
 - 1. Background Color: Safety Red.
 - 2. Letter Color: White.

2.4 VALVE TAGS

- A. Description: Stamped or engraved with 1/4-inch (6.4-mm) letters for piping-system abbreviation and 1/2-inch (13-mm) numbers.
 - 1. Tag Material: aluminum, 0.032 inch (0.8 mm) thick, with predrilled holes for attachment hardware.
 - 2. Fasteners: Brass wire-link chain beaded chain or S-hook.
 - 3. Valve-Tag Color: Safety Red.
 - 4. Letter Color: White.
- B. Valve Schedules: For each piping system, on 8-1/2-by-11-inch (A4) bond paper. Tabulate valve number, piping system, system abbreviation (as shown on valve tag), location of valve (room or space), normal-operating position (open, closed, or modulating), and variations for identification. Mark valves for emergency shutoff and similar special uses.
 - 1. Valve-tag schedule shall be included in operation and maintenance data.

2.5 WARNING TAGS

- A. Description: Preprinted or partially preprinted, accident-prevention tags, of plasticized card stock with matte finish suitable for writing.
 - 1. Size: 3 by 5-1/4 inches (75 by 133 mm) minimum.
 - 2. Fasteners: Brass grommet and wire.

3. Nomenclature: Large-size primary caption such as "DANGER," "CAUTION," or "DO NOT OPERATE."
4. Color: Safety Yellow background with black lettering.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Clean piping and equipment surfaces of incompatible primers, paints, and encapsulants, as well as dirt, oil, grease, release agents, and other substances that could impair bond of identification devices.

3.2 GENERAL INSTALLATION REQUIREMENTS

- A. Coordinate installation of identifying devices with completion of covering and painting of surfaces where devices are to be installed.
- B. Coordinate installation of identifying devices with locations of access panels and doors.
- C. Install identifying devices before installing acoustical ceilings and similar concealment.

3.3 EQUIPMENT LABEL INSTALLATION

- A. Install or permanently fasten labels on each major item of mechanical equipment.
- B. Locate equipment labels where accessible and visible.

3.4 PIPE LABEL INSTALLATION

- A. Piping: Painting of piping is specified in Section 099114 "Exterior Painting" and 099123 "Interior Painting."
- B. Pipe-Label Locations: Locate pipe labels where piping is exposed or above accessible ceilings in finished spaces; machine rooms; accessible maintenance spaces such as shafts, tunnels, and plenums; and exterior exposed locations as follows:
 1. Near each valve and control device.
 2. Near each branch connection excluding short takeoffs. Where flow pattern is not obvious, mark each pipe at branch.
 3. Near penetrations and on both sides of through walls, floors, ceilings, and inaccessible enclosures.
 4. At access doors, manholes, and similar access points that permit a view of concealed piping.

5. Near major equipment items and other points of origination and termination.
6. Spaced at maximum intervals of 50 feet (15 m) along each run. Reduce intervals to 25 feet (7.6 m) in areas of congested piping and equipment.
7. On piping above removable acoustical ceilings. Omit intermediately spaced labels.

3.5 VALVE-TAG INSTALLATION

- A. Install tags on valves and control devices in fire-suppression piping systems. List tagged valves in a valve-tag schedule.
- B. Valve-Tag Application Schedule: Tag valves according to size, shape, and with captions similar to those indicated in "Valve-Tag Size and Shape" Subparagraph below:
 1. Valve-Tag Size and Shape:
 - a. Dry-Pipe Sprinkler System: 1-1/2 inches (38 mm), round.

3.6 WARNING-TAG INSTALLATION

- A. Write required message on, and attach warning tags to, equipment and other items where required.

END OF SECTION 210553

SECTION 210700 – FIRE-SUPPRESSION SYSTEMS INSULATION

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes mechanical insulation for water heater breeching, equipment and pipe, including the following:
 - 1. Insulation Materials:
 - a. Mineral-Fiber.
 - 2. Insulating cements.
 - 3. Adhesives.
 - 4. Mastics.
 - 5. Lagging adhesives.
 - 6. Sealants.
 - 7. Factory-applied jackets.
 - 8. Field-applied jackets.
 - 9. Tapes.
 - 10. Securements.
 - 11. Corner angles.

1.3 DEFINITIONS

- A. ASJ: All-service jacket.
- B. FSK: Foil, scrim, kraft paper.
- C. FSP: Foil, scrim, polyethylene.
- D. PVDC: Polyvinylidene chloride.
- E. SSL: Self-sealing lap.

1.4 SUBMITTALS

- A. Product Data: For each type of product indicated, identify thermal conductivity, thickness, and jackets (both factory and field applied, if any).
- B. Shop Drawings: Show details for the following:
 - 1. Application of protective shields, saddles, and inserts at hangers for each type of insulation and hanger.
 - 2. Insulation application at pipe expansion joints for each type of insulation.
 - 3. Insulation application at elbows, fittings, flanges, valves, and specialties for each type of insulation.
 - 4. Removable insulation at piping specialties, equipment connections, and access panels.
 - 5. Application of field-applied jackets.
 - 6. Field application for each equipment type.

1.5 QUALITY ASSURANCE

- A. Installer Qualifications: Skilled mechanics who have successfully completed an apprenticeship program or another craft training program certified by the Department of Labor, Bureau of Apprenticeship and Training.
- B. Fire-Test-Response Characteristics: Insulation and related materials shall have fire-test-response characteristics indicated, as determined by testing identical products per ASTM E 84, by a testing and inspecting agency acceptable to authorities having jurisdiction. Factory label insulation and jacket materials and adhesive, mastic, and cement material containers, with appropriate markings of applicable testing and inspecting agency.
 - 1. Insulation Installed Indoors: Flame-spread index of 25 or less, and smoke-developed index of 50 or less.
 - 2. Insulation Installed Outdoors: Flame-spread index of 75 or less, and smoke-developed index of 150 or less.
- C. National Commercial and Industrial Insulation Standards: Comply with installation requirements and standards.
- D. ASHRAE Standard 90.1-2004: Comply with insulation values required by the standard.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Packaging: Insulation material containers shall be marked by manufacturer with appropriate ASTM standard designation, type and grade, and maximum use temperature.

1.7 COORDINATION

- A. Coordinate size and location of supports, hangers, and insulation shields specified in Division 22 Section "Hangers and Supports for Plumbing Piping and Equipment."
- B. Coordinate clearance requirements with piping Installer for piping insulation application and equipment Installer for equipment insulation application. Before preparing piping Shop Drawings, establish and maintain clearance requirements for installation of insulation and field-applied jackets and finishes and for space required for maintenance.

1.8 SCHEDULING

- A. Schedule insulation application after pressure testing systems and, where required, after installing and testing heat tracing. Insulation application may begin on segments that have satisfactory test results.
- B. Complete installation and concealment of plastic materials as rapidly as possible in each area of construction.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:
 - 1. Products: Subject to compliance with requirements, provide one of the products specified.
 - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the manufacturers specified.

2.2 INSULATION MATERIALS

- A. Refer to Part 3 schedule articles for requirements about where insulating materials shall be applied.
- B. Products shall not contain asbestos, lead, mercury, or mercury compounds.
- C. Products that come in contact with stainless steel shall have a leachable chloride content of less than 50 ppm when tested according to ASTM C 871.
- D. Insulation materials for use on austenitic stainless steel shall be qualified as acceptable according to ASTM C 795.

- E. Foam insulation materials shall not use CFC or HCFC blowing agents in the manufacturing process.
- F. Mineral-Fiber, Preformed Pipe Insulation:
 - 1. Products:
 - a. Fibrex Insulations Inc.; Coreplus 1200.
 - b. Johns Manville; Micro-Lok.
 - c. Knauf Insulation; 1000 (Pipe Insulation).
 - d. Manson Insulation Inc.; Alley-K.
 - e. Owens Corning; Fiberglas Pipe Insulation.
 - 2. Type I, 850 deg F Materials: Mineral or glass fibers bonded with a thermosetting resin. Comply with ASTM C 547, Type I, Grade A, with factory-applied ASJ. Factory-applied jacket requirements are specified in Part 2 "Factory-Applied Jackets" Article.

2.3 INSULATING CEMENTS

- A. Mineral-Fiber Insulating Cement: Comply with ASTM C 195.
 - 1. Products:
 - a. Insulco, Division of MFS, Inc.; Triple I.
 - b. P. K. Insulation Mfg. Co., Inc.; Super-Stik.
- B. Expanded or Exfoliated Vermiculite Insulating Cement: Comply with ASTM C 196.
 - 1. Products:
 - a. P. K. Insulation Mfg. Co., Inc.; Thermal-V-Kote.
- C. Mineral-Fiber, Hydraulic-Setting Insulating and Finishing Cement: Comply with ASTM C 449/C 449M.
 - 1. Products:
 - a. Insulco, Division of MFS, Inc.; SmoothKote.
 - b. P. K. Insulation Mfg. Co., Inc.; PK No. 127, and Quik-Cote.
 - c. Rock Wool Manufacturing Company; Delta One Shot.

2.4 ADHESIVES

- A. Materials shall be compatible with insulation materials, jackets, and substrates and for bonding insulation to itself and to surfaces to be insulated, unless otherwise indicated.

- B. Mineral-Fiber Adhesive: Comply with MIL-A-3316C, Class 2, Grade A.
 - 1. Products:
 - a. Childers Products, Division of ITW; CP-82.
 - b. Foster Products Corporation, H. B. Fuller Company; 85-20.
 - c. ITW TACC, Division of Illinois Tool Works; S-90/80.
 - d. Marathon Industries, Inc.; 225.
 - e. Mon-Eco Industries, Inc.; 22-25.

- C. ASJ Adhesive, and FSK and PVDC Jacket Adhesive: Comply with MIL-A-3316C, Class 2, Grade A for bonding insulation jacket lap seams and joints.
 - 1. Products:
 - a. Childers Products, Division of ITW; CP-82.
 - b. Foster Products Corporation, H. B. Fuller Company; 85-20.
 - c. ITW TACC, Division of Illinois Tool Works; S-90/80.
 - d. Marathon Industries, Inc.; 225.
 - e. Mon-Eco Industries, Inc.; 22-25.

2.5 MASTICS

- A. Materials shall be compatible with insulation materials, jackets, and substrates; comply with MIL-C-19565C, Type II.

- B. Vapor-Barrier Mastic: Water based; suitable for indoor and outdoor use on below ambient services.
 - 1. Products:
 - a. Childers Products, Division of ITW; CP-35.
 - b. Foster Products Corporation, H. B. Fuller Company; 30-90.
 - c. ITW TACC, Division of Illinois Tool Works; CB-50.
 - d. Marathon Industries, Inc.; 590.
 - e. Mon-Eco Industries, Inc.; 55-40.
 - f. Vimasco Corporation; 749.

 - 2. Water-Vapor Permeance: ASTM E 96, Procedure B, 0.013 perm at 43-mil dry film thickness.
 - 3. Service Temperature Range: Minus 20 to plus 180 deg F.
 - 4. Solids Content: ASTM D 1644, 59 percent by volume and 71 percent by weight.
 - 5. Color: White.

- C. Vapor-Barrier Mastic: Solvent based; suitable for indoor use on below ambient services.

1. Products:
 - a. Childers Products, Division of ITW; CP-30.
 - b. Foster Products Corporation, H. B. Fuller Company; 30-35.
 - c. ITW TACC, Division of Illinois Tool Works; CB-25.
 - d. Marathon Industries, Inc.; 501.
 - e. Mon-Eco Industries, Inc.; 55-10.
 2. Water-Vapor Permeance: ASTM F 1249, 0.05 perm at 35-mil dry film thickness.
 3. Service Temperature Range: 0 to 180 deg F.
 4. Solids Content: ASTM D 1644, 44 percent by volume and 62 percent by weight.
 5. Color: White.
- D. Vapor-Barrier Mastic: Solvent based; suitable for outdoor use on below ambient services.
1. Products:
 - a. Childers Products, Division of ITW; Encacel.
 - b. Foster Products Corporation, H. B. Fuller Company; 60-95/60-96.
 - c. Marathon Industries, Inc.; 570.
 - d. Mon-Eco Industries, Inc.; 55-70.
 2. Water-Vapor Permeance: ASTM F 1249, 0.05 perm at 30-mil dry film thickness.
 3. Service Temperature Range: Minus 50 to plus 220 deg F.
 4. Solids Content: ASTM D 1644, 33 percent by volume and 46 percent by weight.
 5. Color: White.
- E. Breather Mastic: Water based; suitable for indoor and outdoor use on above ambient services.
1. Products:
 - a. Childers Products, Division of ITW; CP-10.
 - b. Foster Products Corporation, H. B. Fuller Company; 35-00.
 - c. ITW TACC, Division of Illinois Tool Works; CB-05/15.
 - d. Marathon Industries, Inc.; 550.
 - e. Mon-Eco Industries, Inc.; 55-50.
 - f. Vimasco Corporation; WC-1/WC-5.
 2. Water-Vapor Permeance: ASTM F 1249, 3 perms at 0.0625-inch dry film thickness.
 3. Service Temperature Range: Minus 20 to plus 200 deg F.
 4. Solids Content: 63 percent by volume and 73 percent by weight.
 5. Color: White.

2.6 LAGGING ADHESIVES

- A. Description: Comply with MIL-A-3316C Class I, Grade A and shall be compatible with insulation materials, jackets, and substrates.
1. Products:
 - a. Childers Products, Division of ITW; CP-52.
 - b. Foster Products Corporation, H. B. Fuller Company; 81-42.
 - c. Marathon Industries, Inc.; 130.
 - d. Mon-Eco Industries, Inc.; 11-30.
 - e. Vimasco Corporation; 136.
 2. Fire-resistant, water-based lagging adhesive and coating for use indoors to adhere fire-resistant lagging cloths over duct, equipment, and pipe insulation.
 3. Service Temperature Range: Minus 50 to plus 180 deg F.
 4. Color: White.

2.7 SEALANTS

- A. FSK and Metal Jacket Flashing Sealants:
1. Products:
 - a. Childers Products, Division of ITW; CP-76-8.
 - b. Foster Products Corporation, H. B. Fuller Company; 95-44.
 - c. Marathon Industries, Inc.; 405.
 - d. Mon-Eco Industries, Inc.; 44-05.
 - e. Vimasco Corporation; 750.
 2. Materials shall be compatible with insulation materials, jackets, and substrates.
 3. Fire- and water-resistant, flexible, elastomeric sealant.
 4. Service Temperature Range: Minus 40 to plus 250 deg F.
 5. Color: Aluminum.
- B. ASJ Flashing Sealants, and Vinyl, PVDC, and PVC Jacket Flashing Sealants:
1. Products:
 - a. Childers Products, Division of ITW; CP-76.
 - b. Materials shall be compatible with insulation materials, jackets, and substrates.
 - c. Fire- and water-resistant, flexible, elastomeric sealant.
 - d. Service Temperature Range: Minus 40 to plus 250 deg F.
 - e. Color: White.

2.8 FACTORY-APPLIED JACKETS

- A. Insulation system schedules indicate factory-applied jackets on various applications. When factory-applied jackets are indicated, comply with the following:
1. ASJ: White, kraft-paper, fiberglass-reinforced scrim with aluminum-foil backing; complying with ASTM C 1136, Type I.
 2. ASJ-SSL: ASJ with self-sealing, pressure-sensitive, acrylic-based adhesive covered by a removable protective strip; complying with ASTM C 1136, Type I.

2.9 FIELD-APPLIED JACKETS

- A. Field-applied jackets shall comply with ASTM C 921, Type I, unless otherwise indicated.
- B. Metal Jacket:
1. Products:
 - a. Childers Products, Division of ITW; Metal Jacketing Systems.
 - b. PABCO Metals Corporation; Surefit.
 - c. RPR Products, Inc.; Insul-Mate.
 - d. Insert manufacturer's name; product name or designation.
 2. Aluminum Jacket: Comply with ASTM B 209, Alloy 3003, 3005, 3105 or 5005, Temper H-14.
 - a. Sheet and roll stock ready for shop or field sizing Factory cut and rolled to size.
 - b. Finish and thickness are indicated in field-applied jacket schedules.
 - c. Moisture Barrier for Indoor Applications: 3-mil- thick, heat-bonded polyethylene and kraft paper.
 - d. Moisture Barrier for Outdoor Applications: 3-mil-thick, heat-bonded polyethylene and kraft paper.
 - e. Factory-Fabricated Fitting Covers:
 - 1) Same material, finish, and thickness as jacket.
 - 2) Preformed 2-piece or gore, 45- and 90-degree, short- and long-radius elbows.
 - 3) Tee covers.
 - 4) Flange and union covers.
 - 5) End caps.
 - 6) Beveled collars.
 - 7) Valve covers.
 - 8) Field fabricate fitting covers only if factory-fabricated fitting covers are not available.

2.10 TAPES

- A. ASJ Tape: White vapor-retarder tape matching factory-applied jacket with acrylic adhesive, complying with ASTM C 1136 and UL listed.
1. Products:
 - a. Avery Dennison Corporation, Specialty Tapes Division; Fasson 0835.
 - b. Compac Corp.; 104 and 105.
 - c. Ideal Tape Co., Inc., an American Biltrite Company; 428 AWF ASJ.
 - d. Venture Tape; 1540 CW Plus, 1542 CW Plus, and 1542 CW Plus/SQ.
 2. Width: 3 inches.
 3. Thickness: 11.5 mils.
 4. Adhesion: 90 ounces force/inch in width.
 5. Elongation: 2 percent.
 6. Tensile Strength: 40 lbf/ inch in width.
 7. ASJ Tape Disks and Squares: Precut disks or squares of ASJ tape.

2.11 SECUREMENTS

- A. Bands:
1. Products:
 - a. Childers Products; Bands.
 - b. PABCO Metals Corporation; Bands.
 - c. RPR Products, Inc.; Bands.
 2. Stainless Steel: ASTM A 167 or ASTM A 240/A 240M, Type 304 or Type 316; 0.015 inch thick, 3/4 inch wide with wing or closed seal.
 3. Aluminum: ASTM B 209, Alloy 3003, 3005, 3105, or 5005; Temper H-14, 0.020 inch thick, 3/4 inch wide with wing or closed seal.
 4. Springs: Twin spring set constructed of stainless steel with ends flat and slotted to accept metal bands. Spring size determined by manufacturer for application.
- B. Insulation Pins and Hangers:
1. Capacitor-Discharge-Weld Pins: Copper- or zinc-coated steel pin, fully annealed for capacitor-discharge welding, 0.106-inch or 0.135-inch diameter shank, length to suit depth of insulation indicated.
 - a. Products:
 - 1) AGM Industries, Inc.; CWP-1.
 - 2) GEMCO; CD.

- 3) Midwest Fasteners, Inc.; CD.
 - 4) Nelson Stud Welding; TPA, TPC, and TPS.
2. Cupped-Head, Capacitor-Discharge-Weld Pins: Copper- or zinc-coated steel pin, fully annealed for capacitor-discharge welding, 0.106-inch- or 0.135-inch diameter shank, length to suit depth of insulation indicated with integral 1-1/2-inch galvanized carbon-steel washer.
- a. Products:
 - 1) AGM Industries, Inc.; CWP-1.
 - 2) GEMCO; Cupped Head Weld Pin.
 - 3) Midwest Fasteners, Inc.; Cupped Head.
 - 4) Nelson Stud Welding; CHP.
3. Metal, Adhesively Attached, Perforated-Base Insulation Hangers: Baseplate welded to projecting spindle that is capable of holding insulation, of thickness indicated, securely in position indicated when self-locking washer is in place. Comply with the following requirements:
- a. Products:
 - 1) AGM Industries, Inc.; Tactoo Insul-Hangers, Series T.
 - 2) GEMCO; Perforated Base.
 - 3) Midwest Fasteners, Inc.; Spindle.
 - b. Baseplate: Perforated, galvanized carbon-steel sheet, 0.030 inch thick by 2 inches square.
 - c. Spindle: Copper- or zinc-coated, low carbon steel, Aluminum, or Stainless steel, fully annealed, 0.106-inch-diameter shank, length to suit depth of insulation indicated.
 - d. Adhesive: Recommended by hanger manufacturer. Product with demonstrated capability to bond insulation hanger securely to substrates indicated without damaging insulation, hangers, and substrates.
4. Nonmetal, Adhesively Attached, Perforated-Base Insulation Hangers: Baseplate fastened to projecting spindle that is capable of holding insulation, of thickness indicated, securely in position indicated when self-locking washer is in place. Comply with the following requirements:
- a. Products:
 - 1) GEMCO; Nylon Hangers.
 - 2) Midwest Fasteners, Inc.; Nylon Insulation Hangers.
 - b. Baseplate: Perforated, nylon sheet, 0.030 inch thick by 1½-inches in diameter.

- c. Spindle: Nylon, 0.106-inch-diameter shank, length to suit depth of insulation indicated, up to 2½-inches.
 - d. Adhesive: Recommended by hanger manufacturer. Product with demonstrated capability to bond insulation hanger securely to substrates indicated without damaging insulation, hangers, and substrates.
 5. Self-Sticking-Base Insulation Hangers: Baseplate welded to projecting spindle that is capable of holding insulation, of thickness indicated, securely in position indicated when self-locking washer is in place. Comply with the following requirements:
 - a. Products:
 - 1) AGM Industries, Inc.; Tactoo Insul-Hangers, Series TSA.
 - 2) GEMCO; Press and Peel.
 - 3) Midwest Fasteners, Inc.; Self Stick.
 - 4) Baseplate: Galvanized carbon-steel sheet, 0.030-inch thick by 2-inches square.
 - b. Spindle: Copper- or zinc-coated, low carbon steel, Aluminum, or Stainless steel, fully annealed, 0.106-inch diameter shank, length to suit depth of insulation indicated.
 - c. Adhesive-backed base with a peel-off protective cover.
 6. Insulation-Retaining Washers: Self-locking washers formed from 0.016-inch thick, galvanized-steel, aluminum, or stainless-steel sheet, with beveled edge sized as required to hold insulation securely in place but not less than 1½-inches in diameter.
 - a. Products:
 - 1) AGM Industries, Inc.; RC-150.
 - 2) GEMCO; R-150.
 - 3) Midwest Fasteners, Inc.; WA-150.
 - 4) Nelson Stud Welding; Speed Clips.
 - b. Protect ends with capped self-locking washers incorporating a spring steel insert to ensure permanent retention of cap in exposed locations.
 7. Nonmetal Insulation-Retaining Washers: Self-locking washers formed from 0.016-inch thick nylon sheet, with beveled edge sized as required to hold insulation securely in place but not less than 1½-inches in diameter.
 - a. Manufacturers:
 - 1) GEMCO.
 - 2) Midwest Fasteners, Inc.
- C. Staples: Outward-clinching insulation staples, nominal ¾-inch wide, stainless steel or Monel.

- D. Wire: 0.080-inch nickel-copper alloy, 0.062-inch soft-annealed, stainless steel, or 0.062-inch soft-annealed, galvanized steel.
 - 1. Manufacturers:
 - a. ACS Industries, Inc.
 - b. C & F Wire.
 - c. Childers Products.
 - d. PABCO Metals Corporation.
 - e. RPR Products, Inc.

2.12 CORNER ANGLES

- A. Aluminum Corner Angles: 0.040 inch thick, minimum 1 by 1 inch, aluminum according to ASTM B 209 (ASTM B 209M), Alloy 3003, 3005, 3105 or 5005; Temper H-14.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates and conditions for compliance with requirements for installation and other conditions affecting performance of insulation application.
 - 1. Verify that systems and equipment to be insulated have been tested and are free of defects.
 - 2. Verify that surfaces to be insulated are clean and dry.
 - 3. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Surface Preparation: Clean and dry surfaces to receive insulation. Remove materials that will adversely affect insulation application.
- B. Surface Preparation: Clean and prepare surfaces to be insulated. Before insulating, apply a corrosion coating to insulated surfaces as follows:
 - 1. Stainless Steel: Coat 300 series stainless steel with an epoxy primer 5 mils thick and an epoxy finish 5 mils thick if operating in a temperature range between 140 and 300 deg F. Consult coating manufacturer for appropriate coating materials and application methods for operating temperature range.
 - 2. Carbon Steel: Coat carbon steel operating at a service temperature between 32 and 300 deg F with an epoxy coating. Consult coating manufacturer for appropriate coating materials and application methods for operating temperature range.

- C. Mix insulating cements with clean potable water; if insulating cements are to be in contact with stainless-steel surfaces, use demineralized water.

3.3 COMMON INSTALLATION REQUIREMENTS

- A. Install insulation products in strict accordance with manufacturer's installation instructions and the National Commercial and Industrial Insulation Standards.
- B. Install insulation materials, accessories, and finishes with smooth, straight, and even surfaces; free of voids throughout the length of equipment, ducts and fittings, and piping including fittings, valves, and specialties.
- C. Install insulation materials, forms, vapor barriers or retarders, jackets, and thicknesses required for each item of equipment, duct system, and pipe system as specified in insulation system schedules.
- D. Install accessories compatible with insulation materials and suitable for the service. Install accessories that do not corrode, soften, or otherwise attack insulation or jacket in either wet or dry state.
- E. Install insulation with longitudinal seams at top and bottom of horizontal runs.
- F. Install multiple layers of insulation with longitudinal and end seams staggered.
- G. Do not weld brackets, clips, or other attachment devices to piping, fittings, and specialties.
- H. Keep insulation materials dry during application and finishing.
- I. Install insulation with tight longitudinal seams and end joints. Bond seams and joints with adhesive recommended by insulation material manufacturer.
- J. Install insulation with least number of joints practical.
- K. Where vapor barrier is indicated, seal joints, seams, and penetrations in insulation at hangers, supports, anchors, and other projections with vapor-barrier mastic.
 - 1. Install insulation continuously through hangers and around anchor attachments.
 - 2. For insulation application where vapor barriers are indicated, extend insulation on anchor legs from point of attachment to supported item to point of attachment to structure. Taper and seal ends at attachment to structure with vapor-barrier mastic.
 - 3. Install insert materials and install insulation to tightly join the insert. Seal insulation to insulation inserts with adhesive or sealing compound recommended by insulation material manufacturer.
 - 4. Cover inserts with jacket material matching adjacent pipe insulation. Install shields over jacket, arranged to protect jacket from tear or puncture by hanger, support, and shield.

- L. Apply adhesives, mastics, and sealants at manufacturer's recommended coverage rate and wet and dry film thicknesses.
- M. Install insulation with factory-applied jackets as follows:
 - 1. Draw jacket tight and smooth.
 - 2. Cover circumferential joints with 3-inch-wide strips, of same material as insulation jacket. Secure strips with adhesive and outward clinching staples along both edges of strip, spaced 4 inches o.c.
 - 3. Overlap jacket longitudinal seams at least 1½-inches. Install insulation with longitudinal seams at bottom of pipe. Clean and dry surface to receive self-sealing lap. Staple laps with outward clinching staples along edge at 2 inches o.c.
 - a. For below ambient services, apply vapor-barrier mastic over staples.
 - 4. Cover joints and seams with tape as recommended by insulation material manufacturer to maintain vapor seal.
 - 5. Where vapor barriers are indicated, apply vapor-barrier mastic on seams and joints and at ends adjacent to duct and pipe flanges and fittings.
- N. Cut insulation in a manner to avoid compressing insulation more than 75 percent of its nominal thickness.
- O. Finish installation with systems at operating conditions. Repair joint separations and cracking due to thermal movement.
- P. Repair damaged insulation facings by applying same facing material over damaged areas. Extend patches at least 4 inches beyond damaged areas. Adhere, staple, and seal patches similar to butt joints.
- Q. For above ambient services, do not install insulation to the following:
 - 1. Vibration-control devices.
 - 2. Testing agency labels and stamps.
 - 3. Nameplates and data plates.
 - 4. Manholes.
 - 5. Handholes.
 - 6. Cleanouts.

3.4 GENERAL PIPE INSULATION INSTALLATION

- A. Requirements in this Article generally apply to all insulation materials except where more specific requirements are specified in various pipe insulation material installation articles.
- B. Insulation Installation on Fittings, Valves, Strainers, Flanges, and Unions:

1. Install insulation over fittings, valves, strainers, flanges, unions, and other specialties with continuous thermal and vapor-retarder integrity, unless otherwise indicated.
 2. Insulate pipe elbows using preformed fitting insulation or mitered fittings made from same material and density as adjacent pipe insulation. Each piece shall be butted tightly against adjoining piece and bonded with adhesive. Fill joints, seams, voids, and irregular surfaces with insulating cement finished to a smooth, hard, and uniform contour that is uniform with adjoining pipe insulation.
 3. Insulate tee fittings with preformed fitting insulation or sectional pipe insulation of same material and thickness as used for adjacent pipe. Cut sectional pipe insulation to fit. Butt each section closely to the next and hold in place with tie wire. Bond pieces with adhesive.
 4. Insulate valves using preformed fitting insulation or sectional pipe insulation of same material, density, and thickness as used for adjacent pipe. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker. For valves, insulate up to and including the bonnets, valve stuffing-box studs, bolts, and nuts. Fill joints, seams, and irregular surfaces with insulating cement.
 5. Insulate strainers using preformed fitting insulation or sectional pipe insulation of same material, density, and thickness as used for adjacent pipe. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker. Fill joints, seams, and irregular surfaces with insulating cement. Insulate strainers so strainer basket flange or plug can be easily removed and replaced without damaging the insulation and jacket. Provide a removable reusable insulation cover. For below ambient services, provide a design that maintains vapor barrier.
 6. Insulate flanges and unions using a section of oversized preformed pipe insulation. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker.
 7. Cover segmented insulated surfaces with a layer of finishing cement and coat with a mastic. Install vapor-barrier mastic for below ambient services and a breather mastic for above ambient services. Reinforce the mastic with fabric-reinforcing mesh. Trowel the mastic to a smooth and well-shaped contour.
 8. For services not specified to receive a field-applied jacket except for flexible elastomeric and polyolefin, install fitted PVC cover over elbows, tees, strainers, valves, flanges, and unions. Terminate ends with PVC end caps. Tape PVC covers to adjoining insulation facing using PVC tape.
 9. Stencil or label the outside insulation jacket of each union with the word "UNION." Match size and color of pipe labels.
- C. Insulate instrument connections for thermometers, pressure gages, pressure temperature taps, test connections, flow meters, sensors, switches, and transmitters on insulated pipes, vessels, and equipment. Shape insulation at these connections by tapering it to and around the connection with insulating cement and finish with finishing cement, mastic, and flashing sealant.
- D. Install removable insulation covers at locations indicated. Installation shall conform to the following:

1. Make removable flange and union insulation from sectional pipe insulation of same thickness as that on adjoining pipe. Install same insulation jacket as adjoining pipe insulation.
2. When flange and union covers are made from sectional pipe insulation, extend insulation from flanges or union long at least two times the insulation thickness over adjacent pipe insulation on each side of flange or union. Secure flange cover in place with stainless-steel or aluminum bands. Select band material compatible with insulation and jacket.
3. Construct removable valve insulation covers in same manner as for flanges except divide the two-part section on the vertical center line of valve body.
4. When covers are made from block insulation, make two halves, each consisting of mitered blocks wired to stainless-steel fabric. Secure this wire frame, with its attached insulation, to flanges with tie wire. Extend insulation at least 2 inches over adjacent pipe insulation on each side of valve. Fill space between flange or union cover and pipe insulation with insulating cement. Finish cover assembly with insulating cement applied in two coats. After first coat is dry, apply and trowel second coat to a smooth finish.
5. Unless a PVC jacket is indicated in field-applied jacket schedules, finish exposed surfaces with a metal jacket.

3.5 MINERAL-FIBER INSULATION INSTALLATION

A. Insulation Installation on Straight Pipes and Tubes:

1. Secure each layer of preformed pipe insulation to pipe with wire or bands and tighten bands without deforming insulation materials.
2. Where vapor barriers are indicated, seal longitudinal seams, end joints, and protrusions with vapor-barrier mastic and joint sealant.
3. For insulation with factory-applied jackets on above ambient surfaces, secure laps with outward clinched staples at 6 inches o.c.
4. For insulation with factory-applied jackets on below ambient surfaces, do not staple longitudinal tabs but secure tabs with additional adhesive as recommended by insulation material manufacturer and seal with vapor-barrier mastic and flashing sealant.

B. Insulation Installation on Pipe Flanges:

1. Install preformed pipe insulation to outer diameter of pipe flange.
2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with mineral-fiber blanket insulation.
4. Install jacket material with manufacturer's recommended adhesive, overlap seams at least 1 inch, and seal joints with flashing sealant.

C. Insulation Installation on Pipe Fittings and Elbows:

1. Install preformed sections of same material as straight segments of pipe insulation when available.

2. When preformed insulation elbows and fittings are not available, install mitered sections of pipe insulation, to a thickness equal to adjoining pipe insulation. Secure insulation materials with wire or bands.

D. Insulation Installation on Valves and Pipe Specialties:

1. Install preformed sections of same material as straight segments of pipe insulation when available.
2. When preformed sections are not available, install mitered sections of pipe insulation to valve body.
3. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
4. Install insulation to flanges as specified for flange insulation application.

3.6 FIELD-APPLIED JACKET INSTALLATION

- A. Where metal jackets are indicated, install with 2-inch overlap at longitudinal seams and end joints. Overlap longitudinal seams arranged to shed water. Seal end joints with weatherproof sealant recommended by insulation manufacturer. Secure jacket with stainless-steel bands 12 inches o.c. and at end joints.

3.7 PIPING INSULATION SCHEDULE, GENERAL

- A. Acceptable preformed pipe and tubular insulation materials and thicknesses are identified for each piping system and pipe size range. If more than one material is listed for a piping system, selection from materials listed is Contractor's option.
- B. Items Not Insulated: Unless otherwise indicated, do not install insulation on the following:
 1. Dry Pipe Fire Suppression main and branch piping.

3.8 PARKING GARAGE PIPING INSULATION SCHEDULE

- A. Dry Pipe Fire Suppression Drain Piping from mains down to lowest valve:
 1. All Sizes: Insulation shall be any of the following:
 - a. Pre-formed Fiber with ASJ Jacket: 1 inch thick.

3.9 PARKING GARAGE, FIELD-APPLIED JACKET SCHEDULE

- A. Install jacket over insulation material. For insulation with factory-applied jacket, install the field-applied jacket over the factory-applied jacket.

- B. If more than one material is listed, selection from materials listed is Contractor's option.
- C. Dry Pipe Fire Suppression Drain Piping from mains down to lowest valve:
 - 1. Aluminum, Stucco Embossed: 0.020 inch thick.

END OF SECTION 210700

SECTION 211119 – FIRE DEPARTMENT CONNECTIONS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Flush-type fire-department connections.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
 - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for each fire-department connection.

PART 2 - PRODUCTS

2.1 EXPOSED-TYPE FIRE-DEPARTMENT CONNECTION

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:
 - 1. Croker; a Division of Morris Group International.
 - 2. Elkhart Brass Mfg. Co., Inc.
 - 3. Fire Protection Products Inc (FPPI); a brand of Anvil International and Smith-Cooper International.
 - 4. GMR International Equipment Corporation.
 - 5. Guardian Fire Equipment, Inc.
 - 6. Venus Fire Protection Ltd.
 - 7. Wilson & Cousins Inc.
- B. Standard: UL 405.
- C. Type: Flush, for wall mounting.

- D. Pressure Rating: 175 psig minimum.
- E. Body Material: Corrosion-resistant metal.
- F. Inlets: Brass with threads according to NFPA 1963 and matching local fire-department sizes and threads. Include extension pipe nipples, brass lugged swivel connections, and check devices or clappers.
- G. Caps: Brass, lugged type, with gasket and chain.
- H. Escutcheon Plate: Rectangular, brass, wall type.
- I. Outlet: With pipe threads.
- J. Body Style: Horizontal.
- K. Number of Inlets: Two.
- L. Outlet Location: Back.
- M. Escutcheon Plate Marking: Similar to "AUTO SPKR & STANDPIPE."
- N. Finish: Rough brass or bronze.
- O. Outlet Size: NPS 4.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of fire-department connections.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Install wall-type fire-department connections.
- B. Install automatic (ball-drip) drain valve at each check valve for fire-department connection.
- C. Reuse existing exterior wall penetration.

END OF SECTION 211119

SECTION 211316 - DRY-PIPE SPRINKLER SYSTEMS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:

1. Pipes, fittings, and specialties.
2. Specialty valves.
3. Sprinkler specialty pipe fittings.
4. Sprinklers.
5. Alarm devices.
6. Manual control stations.
7. Control panels.
8. Pressure gauges.

- B. Related Requirements:

1. Section 211119 "Fire Department Connections" for exposed-, flush-, and yard-type fire department connections.
2. Section 210523 "Fire Protection Piping" for ball, butterfly, check, gate, post-indicator, and trim and drain valves.

1.3 DEFINITIONS

- A. Standard-Pressure Sprinkler Piping: Dry-pipe sprinkler system piping designed to operate at working pressure of 175-psig (1200-kPa) maximum.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.

1. Include rated capacities, operating characteristics, electrical characteristics, and furnished specialties and accessories.

- B. Shop Drawings: For dry-pipe sprinkler systems.

1. Include plans, elevations, sections, and attachment details.
 2. Include diagrams for power, signal, and control wiring.
- C. Delegated-Design Submittal: For dry-pipe sprinkler systems indicated to comply with performance requirements and design criteria, including analysis data signed and sealed by the qualified professional engineer responsible for their preparation.

1.5 INFORMATIONAL SUBMITTALS

- A. Coordination Drawings: Sprinkler systems, drawn to scale, on which the following items are shown and coordinated with each other, using input from installers of the items involved:
1. Domestic water piping.
 2. Compressed air piping.
 3. HVAC hydronic piping.
 4. Items penetrating finished ceiling including the following:
 - a. Lighting fixtures.
 5. Structural components and other existing utilities in the building.
- B. Qualification Data: For qualified Installer.
- C. Design Data:
1. Approved Sprinkler Piping Drawings: Working plans, prepared according to NFPA 13, that have been approved by authorities having jurisdiction, including hydraulic calculations if applicable.
- D. Fire-hydrant flow test report.
- E. Field Test Reports: Indicate and interpret test results for compliance with performance requirements and as described in NFPA 13. Include "Contractor's Material and Test Certificate for Aboveground Piping."
- F. Field quality-control reports.

1.6 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For dry-pipe sprinkler systems and specialties to include in emergency, operation, and maintenance manuals.

1.7 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.

1. Sprinkler Cabinets: Finished, wall-mounted, steel cabinet with hinged cover, and with space for minimum of six spare sprinklers plus sprinkler wrench. Include number of sprinklers required by NFPA 13 and sprinkler wrench. Include separate cabinet with sprinklers and wrench for each type of sprinkler used on Project.

1.8 QUALITY ASSURANCE

- A. Installer Qualifications:

1. Installer's responsibilities include designing, fabricating, and installing sprinkler systems and providing professional engineering services needed to assume engineering responsibility. Base calculations on results of fire-hydrant flow test.

1.9 FIELD CONDITIONS

- A. Interruption of Existing Sprinkler Service: Do not interrupt sprinkler service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary sprinkler service according to requirements indicated:

1. Notify Owner no fewer than seven days in advance of proposed interruption of sprinkler service.
2. Do not proceed with interruption of sprinkler service without Owner's written permission.

PART 2 - PRODUCTS

2.1 SYSTEM DESCRIPTIONS

- A. Dry-Pipe Sprinkler System: Automatic sprinklers are attached to piping containing compressed air. Opening of sprinklers releases compressed air and permits water pressure to open dry-pipe valve. Water then flows into piping and discharges from opened sprinklers.

2.2 PERFORMANCE REQUIREMENTS

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Sprinkler system equipment, specialties, accessories, installation, and testing shall comply with NFPA 13.

- C. Standard-Pressure Piping System Component: Listed for 175-psig (1200-kPa) minimum working pressure.
- D. Sprinkler system design shall be approved by authorities having jurisdiction.
 - 1. Margin of Safety for Available Water Flow and Pressure: 10 percent, including losses through water-service piping, valves, and backflow preventers.
 - 2. Sprinkler Occupancy Hazard Classifications:
 - a. Automobile Parking Areas: Ordinary Hazard, Group 2.
 - b. Building Service Areas: Ordinary Hazard, Group 1.
 - 3. Minimum Density for Automatic-Sprinkler Piping Design:
 - a. Ordinary-Hazard, Group 1 Occupancy: 0.15 gpm over 1,950-sq. ft. area.
 - b. Ordinary-Hazard, Group 2 Occupancy: 0.20 gpm over 1,950-sq. ft. area.
 - c. Special Occupancy Hazard: As determined by authorities having jurisdiction.
 - 4. Maximum protection area per sprinkler according to UL listing.
 - 5. Total Combined Hose-Stream Demand Requirement: According to NFPA 13 unless otherwise indicated:
 - a. Ordinary-Hazard Occupancies: 250 gpm (15.75 L/s) for 60 to 90 minutes.

2.3 STEEL PIPE AND FITTINGS

- A. Standard-Weight (Schedule 40), Steel Pipe: ASTM A53/A53M, Type E, Grade B. Pipe ends may be factory or field formed to match joining method.
- B. Black-Steel Pipe Nipples: ASTM A733, made of ASTM A53/A53M, standard-weight, seamless steel pipe with threaded ends.
- C. Uncoated-Steel Couplings: ASTM A865/A865M, threaded.
- D. Uncoated, Gray-Iron Threaded Fittings: ASME B16.4, Class 125, standard pattern.
- E. Malleable- or Ductile-Iron Unions: UL 860.
- F. Cast-Iron Flanges: ASME B16.1, Class 125.
- G. Plain-End-Pipe Fittings: UL 213, ductile-iron body with retainer lugs that require one-quarter turn or screwed retainer pin to secure pipe in fitting.
 - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:

- a. Anvil International/Smith-Cooper International; Tailwind Capital, LLC.

H. Grooved-Joint, Steel-Pipe Appurtenances:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Victaulic Company.
2. Pressure Rating: 175-psig (1200-kPa) minimum.
3. Galvanized, Grooved-End Fittings for Steel Piping: ASTM A47/A47M, malleable-iron casting or ASTM A536, ductile-iron casting, with dimensions matching steel pipe.
4. Grooved-End-Pipe Couplings for Steel Piping: AWWA C606 and UL 213 rigid pattern, unless otherwise indicated, for steel-pipe dimensions. Include ferrous housing sections, EPDM-rubber gasket, and bolts and nuts.

2.4 SPECIALTY VALVES

- A. Listed in UL's "Fire Protection Equipment Directory" or FM Global's "Approval Guide."
- B. Pressure Rating:
 1. Standard-Pressure Piping Specialty Valves: 175-psig (1200-kPa) minimum.
- C. Body Material: Cast or ductile iron.
- D. Size: Same as connected piping.
- E. End Connections: Flanged or grooved.
- F. Dry-Pipe Valves:
 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Globe Fire Sprinkler Corporation.
 - b. Tyco Fire Products; brand of Johnson Controls International plc, Building Solutions North America.
 - c. Victaulic Company.
 - d. Viking Corporation.
 2. Standard: UL 260.
 3. Design: Differential-pressure type.
 4. Include UL 1486, quick-opening devices, trim sets for air supply, drain, priming level, alarm connections, ball drip valves, pressure gauges, priming chamber attachment, and fill-line attachment.
 5. Air-Pressure Maintenance Device:

- a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1) Globe Fire Sprinkler Corporation.
 - 2) Tyco Fire Products; brand of Johnson Controls International plc, Building Solutions North America.
 - 3) Victaulic Company.
 - 4) Viking Corporation.
- b. Standard: UL 260.
- c. Type: Automatic device to maintain minimum air pressure in piping.
- d. Include shutoff valves to permit servicing without shutting down sprinkler piping, bypass valve for quick filling, pressure regulator or switch to maintain pressure, strainer, pressure ratings with 14- to 60-psig (95- to 410-kPa) adjustable range, and 175-psig (1200-kPa) outlet pressure.

G. Automatic (Ball Drip) Drain Valves:

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:
 - a. Reliable Automatic Sprinkler Co., Inc. (The).
 - b. Tyco Fire Products; brand of Johnson Controls International plc, Building Solutions North America.
2. Standard: UL 1726.
3. Pressure Rating: 175-psig (1200-kPa) minimum.
4. Type: Automatic draining, ball check.
5. Size: NPS 3/4 (DN 20).
6. End Connections: Threaded.

2.5 AIR COMPRESSORS

- A. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:
 1. Gast Manufacturing Inc.
 2. General Air Products, Inc,
 3. Viking Corporation.
- B. Standard: UL's "Fire Protection Equipment Directory" listing or "Approval Guide," published by FM Global, listing.
- C. Motor Horsepower: 1.5 HP

- D. Power: 208-V ac, 60 Hz, single phase.
- E. Refer to schedule on drawings.

2.6 AIR DRYERS

- A. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:
 - 1. Gast Manufacturing Inc.
 - 2. General Air Products, Inc,
 - 3. Viking Corporation.
- B. Standard: UL's "Fire Protection Equipment Directory" listing or "Approval Guide," published by FM Global, listing.
- C. Power: 120-V ac, 60 Hz, single phase.
- D. Refer to schedule on drawings.

2.7 SPRINKLER PIPING SPECIALTIES

- A. General Requirements for Dry-Pipe System Fittings: UL listed for dry-pipe service.
- B. Branch Outlet Fittings:
 - 1. Standard: UL 213.
 - 2. Pressure Rating: 175-psig (1200-kPa) minimum.
 - 3. Body Material: Ductile-iron housing with EPDM seals and bolts and nuts.
 - 4. Type: Mechanical-tee and -cross fittings.
 - 5. Configurations: Snap-on and strapless, ductile-iron housing with branch outlets.
 - 6. Size: Of dimension to fit onto sprinkler main and with outlet connections as required to match connected branch piping.
 - 7. Branch Outlets: Grooved, plain-end pipe, or threaded.
- C. Flow Detection and Test Assemblies:
 - 1. Standard: UL's "Fire Protection Equipment Directory" or FM Global's "Approval Guide."
 - 2. Pressure Rating: 175-psig (1200-kPa) minimum.
 - 3. Body Material: Cast- or ductile-iron housing with orifice, sight glass, and integral test valve.
 - 4. Size: Same as connected piping.
 - 5. Inlet and Outlet: Threaded.
- D. Branch Line Testers:
 - 1. Standard: UL 199.
 - 2. Pressure Rating: 175-psig (1200-kPa) minimum.

3. Body Material: Brass.
4. Size: Same as connected piping.
5. Inlet: Threaded.
6. Drain Outlet: Threaded and capped.
7. Branch Outlet: Threaded, for sprinkler.

E. Sprinkler Inspector's Test Fittings:

1. Standard: UL's "Fire Protection Equipment Directory" or FM Global's "Approval Guide."
2. Pressure Rating: 175-psig (1200-kPa) minimum.
3. Body Material: Cast- or ductile-iron housing with sight glass.
4. Size: Same as connected piping.
5. Inlet and Outlet: Threaded.

F. Adjustable Drop Nipples:

1. Standard: UL 1474.
2. Pressure Rating: 250-psig (1725-kPa) minimum.
3. Body Material: Steel pipe with EPDM O-ring seals.
4. Size: Same as connected piping.
5. Length: Adjustable.
6. Inlet and Outlet: Threaded.

2.8 SPRINKLERS

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. Globe Fire Sprinkler Corporation.
2. Tyco Fire Products; brand of Johnson Controls International plc, Building Solutions North America.
3. Victaulic Company.
4. Viking Corporation.

B. Listed in UL's "Fire Protection Equipment Directory" or FM Global's "Approval Guide."

C. Pressure Rating for Residential Sprinklers: 175-psig (1200-kPa) maximum.

D. Pressure Rating for Automatic Sprinklers: 175-psig (1200-kPa) minimum.

E. Automatic Sprinklers with Heat-Responsive Element:

1. Nonresidential Applications: UL 199.
2. Characteristics: Nominal 1/2-inch (12.7-mm) orifice with Discharge Coefficient K of 5.6, and for "Ordinary" temperature classification rating unless otherwise indicated or required by application.

F. Sprinkler Finishes: bronze.

- G. Sprinkler Escutcheons: Materials, types, and finishes for the following sprinkler mounting applications. Escutcheons for concealed, flush, and recessed-type sprinklers are specified with sprinklers.
 - 1. Ceiling Mounting: Chrome-plated steel, two piece, with 1-inch (25-mm) vertical adjustment.
 - 2. Sidewall Mounting: Chrome-plated steel, one piece, flat.
- H. Sprinkler Guards:
 - 1. Standard: UL 199.
 - 2. Type: Wire cage with fastening device for attaching to sprinkler.

2.9 ALARM DEVICES

- A. Alarm-device types shall match piping and equipment connections.
- B. Water-Motor-Operated Alarm:
 - 1. Standard: UL 753.
 - 2. Type: Mechanically operated, with Pelton wheel.
 - 3. Alarm Gong: Cast aluminum with red-enamel factory finish.
 - 4. Size: 10-inch (250-mm) diameter.
 - 5. Components: Shaft length, bearings, and sleeve to suit wall construction.
 - 6. Inlet: NPS 3/4 (DN 20).
 - 7. Outlet: NPS 1 (DN 25) drain connection.
- C. Pressure Switches - Water-Flow Alarm Detection:
 - 1. Standard: UL 346.
 - 2. Type: Electrically supervised, pressure-activated water-flow switch.
 - 3. Components: Two single-pole, double-throw switches.
 - 4. Design Operation: Rising pressure to 6 psi (40 kPa), plus or minus 2 psi (13.8 kPa) signals water flow.
 - 5. Adjustability: Each switch is to be independently adjustable.
 - 6. Wire Separation: Pressure switch to provide separation of wiring to each switch connection to allow for low and high volume connections to comply with NFPA 70 Article 760 requirements.
- D. Pressure Switches - Low/High Air Pressure Supervisory:
 - 1. Standard: UL 346.
 - 2. Type: Electrically supervised pressure supervisory switch.
 - 3. Components: Two single-pole, double-throw switches.
 - 4. Design Operation: Detects increase and/or decrease from normal supervisory air pressure.
 - 5. Adjustability: Each switch is to be independently adjustable.
 - 6. Wire Separation: Pressure switch shall provide for separation of wiring to each switch connection to allow for low and high voltage connections to comply with NFPA 70 Article 760 requirements.

- E. Valve Supervisory Switches:
1. General Requirements for Valve Supervisory Switches:
 - a. Standard: UL 346.
 - b. Type: Electrically supervised.
 - c. Design: Signals that controlled valve is in other than fully open position.
 - d. Wire Terminal Designations: Indicates normal switch position when switch is properly installed on the valve and valve is fully open.
 2. Requirements for OS&Y Valve Supervisory Switches:
 - a. Components: One or two single-pole, double-throw switches.
 - b. NEMA Rating: NEMA 4 and NEMA 6P enclosures suitable for mounting in any position indoors or outdoors.
 - c. Visual Switch Indication: Indicates device is properly installed and OS&Y valve is fully open.
 - d. Mounting Hardware: Mounting bracket to grip valve yoke and prevent movement of switch assembly on OS&Y valve.
 - e. Trip Rod Length: Adjustable.
 3. Requirements for PIV and Butterfly Valve Supervisory Switches:
 - a. Components: Two single-pole, double-throw switches.
 - b. NEMA Rating: NEMA 4 and NEMA 6P enclosures suitable for mounting in any position indoors or outdoors.
 - c. Mounting Hardware: Removable nipple.
 - d. Trip Rod Length: Adjustable.
 4. Requirements for Ball Valve Supervisory Switch:
 - a. Components: One single-pole, double-throw switch.
 - b. NEMA Rating: NEMA 4 enclosure suitable for mounting in any position indoors or outdoors.
 - c. Mounting Hardware: Suitable for mounting directly to pipe, ball valves or backflow preventers sized from up to NPS 2 (DN 50).

2.10 CONTROL PANELS

- A. Description: Single-area, two-area, or single-area cross-zoned type control panel as indicated, including NEMA ICS 6, Type 1 enclosure, detector, alarm, and solenoid-valve circuitry for operation of deluge valves.
1. Listed in UL's "Fire Protection Equipment Directory" or FM Global's "Approval Guide" when used with thermal detectors and Class A detector circuit wiring.
 2. Electrical characteristics are 120-V ac, 60 Hz, with 24-V dc rechargeable batteries.

3. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application
- B. Manual Control Stations: Electric operation, metal enclosure, labeled "MANUAL CONTROL STATION," with operating instructions and cover held closed by breakable strut to prevent accidental opening.
- C. Panels Components:
 1. Power supply.
 2. Battery charger.
 3. Standby batteries.
 4. Field-wiring terminal strip.
 5. Electrically supervised solenoid valves and polarized fire-alarm bell.
 6. Lamp test facility.
 7. Single-pole, double-throw auxiliary alarm contacts.
 8. Rectifier.

2.11 PRESSURE GAUGES

- A. Standard: UL 393.
- B. Dial Size: 3-1/2- to 4-1/2-inch (90- to 115-mm) diameter.
- C. Pressure Gauge Range: 0- to 250-psig (0- to 1725-kPa) minimum.
- D. Label: Include "WATER" or "AIR/WATER" label on dial face.
- E. Air System Piping Gauge: Include retard feature and "AIR" or "AIR/WATER" label on dial face.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Perform fire-hydrant flow test according to NFPA 13 and NFPA 291. Use results for system design calculations required in "Quality Assurance" Article.
- B. Report test results promptly and in writing.

3.2 SERVICE-ENTRANCE PIPING

- A. Connect sprinkler piping to existing water-service piping for the building.

3.3 PIPING INSTALLATION

- A. Locations and Arrangements: Drawing plans, schematics, and diagrams indicate general location and arrangement of piping. Install piping as indicated on approved working plans.
 - 1. Deviations from approved working plans for piping require written approval from authorities having jurisdiction. File written approval with Architect before deviating from approved working plans.
 - 2. Coordinate layout and installation of sprinklers with other construction that penetrates ceilings, including light fixtures, HVAC equipment, and partition assemblies.
- B. Piping Standard: Comply with NFPA 13 requirements for installation of sprinkler piping.
- C. Use listed fittings to make changes in direction, branch takeoffs from mains, and reductions in pipe sizes.
- D. Install unions adjacent to each valve in pipes NPS 2 (DN 50) and smaller.
- E. Install flanges, flange adapters, or couplings for grooved-end piping on valves, apparatus, and equipment having NPS 2-1/2 (DN 65) and larger end connections.
- F. Install "Inspector's Test Connections" in sprinkler system piping, complete with shutoff valve, and sized and located according to NFPA 13.
- G. Install sprinkler piping with drains for complete system drainage.
- H. Install sprinkler control valves, test assemblies, and drain risers adjacent to standpipes when sprinkler piping is connected to standpipes.
- I. Install automatic (ball drip) drain valves to drain piping between fire department connections and check valves. Drain to floor drain or to outside building.
- J. Connect existing compressed-air supply to dry-pipe sprinkler piping.
- K. Install alarm devices in piping systems.
- L. Install pressure gauges on riser or feed main, at each sprinkler test connection, and at top of each standpipe. Include pressure gauges with connection not less than NPS 1/4 (DN 8) and with soft-metal seated globe valve, arranged for draining pipe between gauge and valve. Install gauges to permit removal, and install where they are not subject to freezing.
- M. Drain dry-pipe sprinkler piping.
- N. Pressurize and check dry-pipe sprinkler system piping and air-pressure maintenance devices.
- O. Install sleeves for piping penetrations of walls, ceilings, and floors. Comply with requirements for sleeves specified in Section 210517 "Sleeves and Sleeve Seals for Fire-Suppression Piping."

- P. Install sleeve seals for piping penetrations of concrete walls and slabs. Comply with requirements for sleeve seals specified in Section 210517 "Sleeves and Sleeve Seals for Fire-Suppression Piping."
- Q. Install escutcheons for piping penetrations of walls, ceilings, and floors. Comply with requirements for escutcheons specified in Section 210518 "Escutcheons for Fire-Suppression Piping."

3.4 JOINT CONSTRUCTION

- A. Install couplings, flanges, flanged fittings, unions, nipples, and transition and special fittings that have finish and pressure ratings same as or higher than system's pressure rating for aboveground applications unless otherwise indicated.
- B. Install unions adjacent to each valve in pipes NPS 2 (DN 50) and smaller.
- C. Install flanges, flange adapters, or couplings for grooved-end piping on valves, apparatus, and equipment having NPS 2-1/2 (DN 65) and larger end connections.
- D. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
- E. Remove scale, slag, dirt, and debris from inside and outside of pipes, tubes, and fittings before assembly.
- F. Flanged Joints: Select appropriate gasket material in size, type, and thickness suitable for water service. Join flanges with gasket and bolts according to ASME B31.9.
- G. Threaded Joints: Thread pipe with tapered pipe threads according to ASME B1.20.1. Cut threads full and clean using sharp dies. Ream threaded pipe ends to remove burrs and restore full ID. Join pipe fittings and valves as follows:
 - 1. Apply appropriate tape or thread compound to external pipe threads.
 - 2. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged.
- H. Steel-Piping, Cut-Grooved Joints: Cut square-edge groove in end of pipe according to AWWA C606. Assemble coupling with housing, gasket, lubricant, and bolts. Join steel pipe and grooved-end fittings according to AWWA C606 for steel-pipe joints.
- I. Dissimilar-Material Piping Joints: Make joints using adapters compatible with materials of both piping systems.

3.5 VALVE AND SPECIALTIES INSTALLATION

- A. Install listed fire-protection valves, trim and drain valves, specialty valves and trim, controls, and specialties according to NFPA 13 and authorities having jurisdiction.
- B. Install listed fire-protection shutoff valves supervised open, located to control sources of water supply except from fire-department connections. Install permanent identification signs indicating portion of system controlled by each valve.
- C. Specialty Valves:
 - 1. Install valves in vertical position for proper direction of flow, in main supply to system.
 - 2. Install dry-pipe valves with trim sets for air supply, drain, priming level, alarm connections, ball drip valves, pressure gauges, priming chamber attachment, and fill-line attachment.
 - a. Install air compressor and compressed-air-supply piping.
 - b. Install air-pressure maintenance device with shutoff valves to permit servicing without shutting down sprinkler system; bypass valve for quick system filling; pressure regulator or switch to maintain system pressure; strainer; pressure ratings with 14- to 60-psig (95- to 410-kPa) adjustable range; and 175-psig (1200-kPa) maximum inlet pressure.
 - c. Install compressed-air-supply piping from building's compressed-air piping system.

3.6 SPRINKLER INSTALLATION

- A. Install sprinklers in suspended ceilings in center of narrow dimension of acoustical ceiling panels.
- B. Install sprinklers with water supply from heated space. Do not install pendent or sidewall sprinklers in areas subject to freezing.
- C. Flexible sprinkler hoses are not allowed.
- D. Saddle Tee fittings are not allowed.

3.7 IDENTIFICATION

- A. Install labeling and pipe markers on equipment and piping according to requirements in NFPA 13.
- B. Identify system components, wiring, cabling, and terminals. Comply with requirements for identification specified in Section 260553 "Identification for Electrical Systems."

3.8 FIELD QUALITY CONTROL

- A. Perform the following tests and inspections with the assistance of a factory-authorized service representative:
 - 1. Leak Test: After installation, charge systems and test for leaks. Repair leaks and retest until no leaks exist.
 - 2. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
 - 3. Flush, test, and inspect sprinkler systems according to NFPA 13, "Systems Acceptance" Chapter.
 - 4. Energize circuits to electrical equipment and devices.
 - 5. Start and run air compressors.
 - 6. Coordinate with fire-alarm tests. Operate as required.
 - 7. Coordinate with fire-pump tests. Operate as required.
 - 8. Verify that equipment hose threads are same as local fire department equipment.
- B. Sprinkler piping system will be considered defective if it does not pass tests and inspections.
- C. Prepare test and inspection reports.

3.9 CLEANING

- A. Clean dirt and debris from sprinklers.
- B. Only sprinklers with their original factory finish are acceptable. Remove and replace any sprinklers that are painted or have any other finish than their original factory finish.

3.10 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain specialty valves.

3.11 PIPING SCHEDULE

- A. Piping between Fire Department Connections and Check Valves: Standard-weight (Schedule 40) black steel pipe with grooved ends, grooved-end fittings, grooved-end-pipe couplings, and grooved joints.
- B. Sprinkler specialty fittings may be used, downstream of control valves, instead of specified fittings.
- C. Standard-pressure, dry-pipe sprinkler system, NPS 2 (DN 50) and smaller, shall be one of the following:

1. Standard-weight (Schedule 40), black steel pipe with threaded ends; gray-iron threaded fittings; and threaded joints.
 2. Standard-weight (Schedule 40), black steel pipe with cut-grooved ends; grooved-end fittings for steel piping; grooved-end-pipe couplings for steel piping; and grooved joints.
- D. Standard-pressure, dry-pipe sprinkler system, NPS 2-1/2 to NPS 4 (DN 65 to DN 100), shall be the following:
1. Standard-weight (Schedule 40), black steel pipe with cut-grooved ends; grooved-end fittings for steel piping; grooved-end-pipe couplings for steel piping; and grooved joints.
- E. Standard-pressure, dry-pipe sprinkler system, NPS 5 and NPS 6 (DN 125 and DN 150), shall be the following:
1. Standard-weight (Schedule 40), black steel pipe with cut-grooved ends; grooved-end fittings for steel piping; grooved-end-pipe couplings for steel piping; and grooved joints.

3.12 SPRINKLER SCHEDULE

- A. Use sprinkler types in subparagraphs below for the following applications:
1. Rooms without Ceilings: Upright sprinklers.
 2. Garage space with low Ceiling as indicated on prints: Concealed sprinklers.
 3. Wall Mounting: Dry sidewall sprinklers.
- B. Provide sprinkler types in subparagraphs below with finishes indicated.
1. Concealed Sprinklers: Rough brass, with factory-painted cover plate (owner to select color from standard color chart).
 2. Flush Sprinklers: Bright chrome, with painted white escutcheon.
 3. Recessed Sprinklers: Bright chrome, with bright chrome escutcheon.
 4. Upright and Sidewall Sprinklers: Chrome plated in finished spaces exposed to view; rough bronze in unfinished spaces not exposed to view.

END OF SECTION 211316

SECTION 260010 - BASIC ELECTRICAL REQUIREMENTS

PART 1 - GENERAL

1.1 DESCRIPTION OF WORK

- A. Work includes all electrical items and systems shown on the contract drawings and specified herein.
- B. Unless specifically dimensioned, the work shown on the drawings is diagrammatic, and is intended only to show general arrangement.
- C. Include in the work all accessories and devices necessary for the intended operation of any system, whether or not specifically shown or specified.

1.2 STANDARDS OF QUALITY

- A. The specifications establish the standard of quality required, either by description of by references to brand name, name of manufacturers or manufacturer's model number.
- B. Where one product only is specifically identified by name of manufacturer's model number, the Contractor shall base his bid on the use of the name product. Where multiple names are used, the Contractor shall base his bid on the use of any of those products named.
- C. The Contractor may submit with his bid, the names of products which are proposed as substitutions for products named in specifications. Each proposed substitution shall be accompanied by a written sum of money to be added or deducted from his bid. The Owner reserves the sole right to accept or reject said substitutions with or without cause.
- D. When equipment and/or materials are proposed to be purchased from a manufacturer other than those specified, the Contractor shall provide complete data adequate for the Engineer's evaluation of the proposed substitution.
- E. When the equipment other than that specified is used, the Contractor shall be responsible for any extra cost of required revisions such as structural steel, concrete, electrical, piping, etc. Such additional costs shall be identified at the time such substitutions are proposed.

1.3 SUMMARY

- A. This Section includes general administrative and procedural requirements for electrical installations.
 - 1. Submittals

2. Maintenance Manuals
3. Rough-ins
4. Electrical Installations

1.4 SUBMITTALS

- A. The Contractor shall review, approve and submit shop drawings, with promptness so as to cause no delay in his work or in that of others. No submissions will be accepted by the Engineer without the signed review and approval of the Contractor.
- B. The Contractor shall check and verify pertinent field measurements, quantities of equipment and materials required.
- C. Submittals shall be identified by reference to the drawings, sections of specifications, or equipment symbols to which they relate.
- D. Shop drawings, when required, shall include:
 1. Verification of information given in Contract Documents such as performance, dimensions, weight, materials, construction, types, models, manufacturer, etc.
 2. Equipment layouts drawn to scale as may be required.
 3. Wiring diagrams and schematics for equipment.
 4. Any special construction conditions.
 5. Other information/data as may be requested.
- E. All submittals shall identify the specific details of the product or assembly. All optional features being proposed shall be so noted, or the submittal will be rejected.
- F. Review is only for general conformance with the design concept of the project and general compliance with the information given in the contract documents. Any action shown is subject to the requirements of the plans and specification. Contractor is responsible for dimensions which shall be confirmed and correlated at the job site; fabrication processes and techniques of construction; coordination of his work with that of all other trades; and the satisfactory performance of his work.
- G. For items being resubmitted, clearly identify changes made from the initial submittal requested by the Engineer. The Engineer will review only those changes requested and identified by the Contractor.

1.5 MAINTENANCE MANUALS

- A. Prepare maintenance manuals including the following information for equipment items:

1. Description of function, normal operating characteristics and limitations, performance curves, engineering data and tests, and complete nomenclature and commercial numbers of replacement parts.
2. Manufacturer's printed operating procedures to include start-up, break-in, and routine and normal operating instructions; regulation, control, stopping, shutdown, and emergency instructions; and summer and winter operating instructions.
3. Maintenance procedures for routine preventative maintenance and troubleshooting; disassembly, repair, and reassembly; aligning and adjusting instructions.
4. Servicing instructions and lubrication charts and schedules.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Deliver products to the project properly identified with names, model numbers, types, grades, compliance labels, and other information needed for identification.

1.7 PERMITS, FEES, AND CERTIFICATES OF APPROVAL

- A. Contractor shall acquire all permits and certificates.
- B. Contractor shall provide all labor and instruments required for tests and cleaning of systems.
- C. Whenever tests are required, three (3) copies of the test reports shall be submitted to the Engineer.
- D. Tests may be observed by the Engineer or his representative. Notify the Engineer a minimum of three weeks in advance of the test dates.

1.8 COMPLIANCE WITH CODES, STANDARDS AND REGULATIONS

- A. In the absence of specific instruction in the technical specifications, equipment and installation shall conform to the following applicable codes, standards and regulations, latest editions:
 1. American Society for Testing Materials (ASTM).
 2. American National Standard Institute (ANSI).
 3. Underwriter's Laboratories, Inc. (UL).
 4. American Welding Society Code (AWSC).
 5. Local Building, Electrical, and Fire Codes.
 6. National Electrical Code (NEC).
 7. Service Rules and Regulations of Local Electrical Utility Company.
 8. National Electrical Manufacturer's Association (NEMA).
 9. U.S. Department of Health & Human Services "HRS-M-HF" 84-1.
 10. Occupational Safety and Health Act (OSHA).
 11. National Fire Protection Association (NFPA).
 12. Americans with Disabilities Act (ADA).

PART 2 - PRODUCTS - Not Used.

PART 3 - EXECUTION

3.1 ROUGH-IN

- A. Verify final locations for rough-ins with field measurements and with requirements of the actual equipment to be connected.

3.2 ELECTRICAL INSTALLATIONS

- A. General: Sequence, coordinate, and integrate the various elements of electrical systems, materials, and equipment. Comply with the following requirements:
 - 1. Coordinate electrical systems, equipment, and materials installation with other building components.
 - 2. Verify all dimensions by field measurements.
 - 3. Arrange for chases, slots, and openings in other building components during progress of construction, to allow for electrical installations.
 - 4. Coordinate the installation of required supporting devices and sleeves to be set in poured-in-place concrete and other structural components, as they are constructed.
 - 5. Sequence, coordinate, and integrate installations of electrical materials and equipment for efficient flow of the work. Give particular attention to large equipment requiring positioning prior to closing in the building.
 - 6. Where mounting heights are not detailed or dimensioned, install systems, materials, and equipment to provide the maximum headroom possible.
 - 7. Install systems, materials, and equipment to conform with approved submittal data, including coordination drawings, to greatest extent possible. Conform to arrangements indicated by the Contract Documents, recognizing that portions of the Work are shown only in diagrammatic form. Where coordination requirements conflict with individual system requirements, refer conflict to the Engineer.
 - 8. Install systems, materials, and equipment level and plumb, parallel and perpendicular to other building systems and components, where installed exposed in finished spaces.
 - 9. Install electrical equipment to facilitate servicing, maintenance, and repair or replacement of equipment components. As much as practical, connect equipment for ease of disconnecting, with minimum of interference with other installations.
 - 10. Install access panel or doors where units are concealed behind finished surfaces.
 - 11. Install systems, material, and equipment giving right-of-way priority to systems required to be installed at a specified slope.
 - 12. Coordinate all electrical requirements with other trades and their shop drawings prior to installing conduit, wire, switches and breakers. Notify engineer of any discrepancies between document and actual supplied equipment.

3.3 CUTTING AND PATCHING

A. General: Performing cutting and patching in accordance with the following requirements:

1. Perform cutting, fitting, and patching of electrical equipment and materials required to:
 - a. Uncover work to provide for installation of ill-timed work.
 - b. Remove and replace defective work.
 - c. Remove and replace work not conforming to requirements of the contract documents.
 - d. Upon written instruction from the Engineer, uncover and restore work to provide for Engineer observation of concealed work.

END OF SECTION 260010

SECTION 260500 - COMMON WORK RESULTS FOR ELECTRICAL

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Electrical equipment coordination and installation.
2. Common electrical installation requirements.

1.2 COORDINATION

A. Coordinate arrangement, mounting, and support of electrical equipment:

1. To allow maximum possible headroom unless specific mounting heights that reduce headroom are indicated.
2. To provide for ease of disconnecting the equipment with minimum interference to other installations.
3. To allow right of way for piping and conduit installed at required slope.
4. So, connecting raceways, cables, wireways, cable trays, and busways will be clear of obstructions and of the working and access space of other equipment.

B. Coordinate installation of required supporting devices and set sleeves in cast-in-place concrete, masonry walls, and other structural components as they are constructed.

C. Coordinate location of access panels and doors for electrical items that are behind finished surfaces or otherwise concealed.

PART 2 - PRODUCTS – Not Used.

PART 3 - EXECUTION

3.1 COMMON REQUIREMENTS FOR ELECTRICAL INSTALLATION

A. Comply with NECA 1.

B. Measure indicated mounting heights to bottom of unit for suspended items and to center of unit for wall-mounting items.

- C. Headroom Maintenance: If mounting heights or other location criteria are not indicated, arrange and install components and equipment to provide maximum possible headroom consistent with these requirements.
- D. Equipment: Install to facilitate service, maintenance, and repair or replacement of components of both electrical equipment and other nearby installations. Connect in such a way as to facilitate future disconnecting with minimum interference with other items in the vicinity.
- E. Right of Way: Give to piping systems installed at a required slope.

END OF SECTION 260500

SECTION 260519 - LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Building wires and cables rated 600 V and less.
2. Connectors, splices, and terminations rated 600 V and less.

PART 2 - PRODUCTS

2.1 CONDUCTORS AND CABLES

- A. Copper Conductors: Comply with NEMA WC 70/ICEA S-95-658.
- B. Conductor Insulation: Comply with NEMA WC 70/ICEA S-95-658 for Type THHN-2-THWN-2.

2.2 CONNECTORS AND SPLICES

- A. Description: Factory-fabricated connectors and splices of size, ampacity rating, material, type, and class for application and service indicated.

2.3 SYSTEM DESCRIPTION

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Comply with NFPA 70.

PART 3 - EXECUTION

3.1 CONDUCTOR MATERIAL APPLICATIONS

- A. Branch Circuits: Copper. Stranded for No. 12 AWG and larger, except VFC cable, which shall be extra flexible stranded.

3.2 CONDUCTOR INSULATION AND MULTICONDUCTOR CABLE APPLICATIONS AND WIRING METHODS

- A. Exposed Branch Circuits, Including in Crawlspace: Type THHN-2-THWN-2, single conductors in raceway.
- B. Branch Circuits Concealed in Ceilings, Walls, and Partitions: Type THHN-2-THWN-2, single conductors in raceway.

3.3 INSTALLATION OF CONDUCTORS AND CABLES

- A. Conceal cables in finished walls, ceilings, and floors unless otherwise indicated.
- B. Complete raceway installation between conductor and cable termination points according to Section 260533 "Raceways and Boxes for Electrical Systems" prior to pulling conductors and cables.
- C. Use manufacturer-approved pulling compound or lubricant where necessary; compound used must not deteriorate conductor or insulation. Do not exceed manufacturer's recommended maximum pulling tensions and sidewall pressure values.
- D. Use pulling means, including fish tape, cable, rope, and basket-weave wire/cable grips, that will not damage cables or raceway.
- E. Install exposed cables parallel and perpendicular to surfaces of exposed structural members, and follow surface contours where possible.
- F. Support cables according to Section 260529 "Hangers and Supports for Electrical Systems."

3.4 CONNECTIONS

- A. Tighten electrical connectors and terminals according to manufacturer's published torque-tightening values. If manufacturer's torque values are not indicated, use those specified in UL 486A-486B.
- B. Make splices, terminations, and taps that are compatible with conductor material and that possess equivalent or better mechanical strength and insulation ratings than unspliced conductors.
 - 1. Use oxide inhibitor in each splice, termination, and tap for aluminum conductors.
- C. Wiring at Outlets: Install conductor at each outlet, with at least 6 inches of slack.

3.5 IDENTIFICATION

- A. Identify and color-code conductors and cables according to Section 260553 "Identification for Electrical Systems."
- B. Identify each spare conductor at each end with identity number and location of other end of conductor, and identify as spare conductor.

3.6 SLEEVE AND SLEEVE-SEAL INSTALLATION FOR ELECTRICAL PENETRATIONS

- A. Install sleeves and sleeve seals at penetrations of exterior floor and wall assemblies. Comply with requirements in Section 260544 "Sleeves and Sleeve Seals for Electrical Raceways and Cabling."

3.7 FIRESTOPPING

- A. Apply firestopping to electrical penetrations of fire-rated floor and wall assemblies to restore original fire-resistance rating of assembly.

3.8 FIELD QUALITY CONTROL

- A. Perform the following tests and inspections:
 - 1. After installing conductors and cables and before electrical circuitry has been energized, test for compliance with requirements.
 - 2. Perform each visual and mechanical inspection and electrical test stated in NETA Acceptance Testing Specification. Certify compliance with test parameters.
- B. Test and Inspection Reports: Prepare a written report to record the following:
 - 1. Procedures used.
 - 2. Results that comply with requirements.
 - 3. Results that do not comply with requirements and corrective action taken to achieve compliance with requirements.
- C. Cables will be considered defective if they do not pass tests and inspections.

END OF SECTION 260519

SECTION 260526 - GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes grounding and bonding systems and equipment.

1.2 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Comply with UL 467 for grounding and bonding materials and equipment.

PART 2 - PRODUCTS

2.1 SYSTEM DESCRIPTION

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Comply with UL 467 for grounding and bonding materials and equipment.

2.2 CONDUCTORS

- A. Insulated Conductors: Copper wire or cable insulated for 600 V unless otherwise required by applicable Code or authorities having jurisdiction.
- B. Bare Copper Conductors:
 - 1. Solid Conductors: ASTM B 3.
 - 2. Stranded Conductors: ASTM B 8.
 - 3. Tinned Conductors: ASTM B 33.
 - 4. Bonding Cable: 28 kcmil, 14 strands of No. 17 AWG conductor, 1/4 inch in diameter.
 - 5. Bonding Conductor: No. 4 or No. 6 AWG, stranded conductor.
 - 6. Bonding Jumper: Copper tape, braided conductors terminated with copper ferrules; 1-5/8 inches wide and 1/16 inch thick.
 - 7. Tinned Bonding Jumper: Tinned-copper tape, braided conductors terminated with copper ferrules; 1-5/8 inches wide and 1/16 inch thick.

2.3 CONNECTORS

- A. Listed and labeled by an NRTL acceptable to authorities having jurisdiction for applications in which used and for specific types, sizes, and combinations of conductors and other items connected.
- B. Bolted Connectors for Conductors and Pipes: Copper or copper alloy.
- C. Welded Connectors: Exothermic-welding kits of types recommended by kit manufacturer for materials being joined and installation conditions.

PART 3 - EXECUTION

3.1 APPLICATIONS

- A. Conductors: Install stranded conductors for No. 8 AWG and larger unless otherwise indicated.
- B. Conductor Terminations and Connections:
 - 1. Pipe and Equipment Grounding Conductor Terminations: Bolted connectors.

3.2 EQUIPMENT GROUNDING

- A. Install insulated equipment grounding conductors with the following items, in addition to those required by NFPA 70:
 - 1. Feeders and branch circuits.
 - 2. Lighting circuits.
 - 3. Receptacle circuits.
 - 4. Single-phase motor and appliance branch circuits.
 - 5. Flexible raceway runs.

3.3 INSTALLATION

- A. Grounding Conductors: Route along shortest and straightest paths possible unless otherwise indicated or required by Code. Avoid obstructing access or placing conductors where they may be subjected to strain, impact, or damage.
- B. Bonding Straps and Jumpers: Install in locations accessible for inspection and maintenance except where routed through short lengths of conduit.
 - 1. Bonding to Structure: Bond straps directly to basic structure, taking care not to penetrate any adjacent parts.
 - 2. Bonding to Equipment Mounted on Vibration Isolation Hangers and Supports: Install bonding so vibration is not transmitted to rigidly mounted equipment.

3.4 FIELD QUALITY CONTROL

- A. Tests and Inspections:
 - 1. After installing grounding system but before permanent electrical circuits have been energized, test for compliance with requirements.
 - 2. Inspect physical and mechanical condition. Verify tightness of accessible, bolted, electrical connections with a calibrated torque wrench according to manufacturer's written instructions.
- B. Grounding system will be considered defective if it does not pass tests and inspections.
- C. Prepare test and inspection reports.
- D. Report measured ground resistances that exceed the following values:
 - 1. Power and Lighting Equipment or System with Capacity of 500 kVA and Less: 10 ohms.
- E. Excessive Ground Resistance: If resistance to ground exceeds specified values, notify Architect promptly and include recommendations to reduce ground resistance.

END OF SECTION 260526

SECTION 260529 - HANGERS AND SUPPORTS FOR ELECTRICAL SYSTEMS

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following:
 - 1. Hangers and supports for electrical equipment and systems.

1.2 PERFORMANCE REQUIREMENTS

- A. Design equipment supports capable of supporting combined operating weight of supported equipment and connected systems and components.
- B. Rated Strength: Adequate in tension, shear, and pullout force to resist maximum loads calculated or imposed for this Project, with a minimum structural safety factor of five times the applied force.

1.3 QUALITY ASSURANCE

- A. Welding: Qualify procedures and personnel according to AWS D1.1/D1.1M, "Structural Welding Code - Steel."
- B. Comply with NFPA 70.

PART 2 - PRODUCTS

2.1 SUPPORT, ANCHORAGE, AND ATTACHMENT COMPONENTS

- A. Steel Slotted Support Systems: Comply with MFMA-4, factory-fabricated components for field assembly.
 - 1. Metallic Coatings: Hot-dip galvanized after fabrication and applied according to MFMA-4.
 - 2. Nonmetallic Coatings: Manufacturer's standard PVC, polyurethane, or polyester coating applied according to MFMA-4.
 - 3. Painted Coatings: Manufacturer's standard painted coating applied according to MFMA-4.
 - 4. Channel Dimensions: Selected for applicable load criteria.

- B. Nonmetallic Slotted Support Systems: Structural-grade, factory-formed, glass-fiber-resin channels and angles with 9/16-inch- diameter holes at a maximum of 8 inches o.c., in at least 1 surface.
 - 1. Fittings and Accessories: Products of channel and angle manufacturer and designed for use with those items.
 - 2. Fitting and Accessory Materials: Same as channels and angles, except metal items may be stainless steel.
 - 3. Rated Strength: Selected to suit applicable load criteria.
- C. Raceway and Cable Supports: As described in NECA 1 and NECA 101.
- D. Conduit and Cable Support Devices: Steel hangers, clamps, and associated fittings, designed for types and sizes of raceway or cable to be supported.
- E. Structural Steel for Fabricated Supports and Restraints: ASTM A 36/A 36M, steel plates, shapes, and bars; black and galvanized.
- F. Mounting, Anchoring, and Attachment Components: Items for fastening electrical items or their supports to building surfaces include the following:
 - 1. Powder-Actuated Fasteners: Threaded-steel stud, for use in hardened portland cement concrete, steel, or wood, with tension, shear, and pullout capacities appropriate for supported loads and building materials where used.
 - 2. Mechanical-Expansion Anchors: Insert-wedge-type, zinc-coated steel, for use in hardened portland cement concrete with tension, shear, and pullout capacities appropriate for supported loads and building materials in which used.
 - 3. Concrete Inserts: Steel or malleable-iron, slotted support system units similar to MSS Type 18; complying with MFMA-4 or MSS SP-58.
 - 4. Clamps for Attachment to Steel Structural Elements: MSS SP-58, type suitable for attached structural element.
 - 5. Through Bolts: Structural type, hex head, and high strength. Comply with ASTM A 325.
 - 6. Toggle Bolts: All-steel springhead type.
 - 7. Hanger Rods: Threaded steel.

2.2 FABRICATED METAL EQUIPMENT SUPPORT ASSEMBLIES

- A. Description: Welded or bolted, structural-steel shapes, shop or field fabricated to fit dimensions of supported equipment.

PART 3 - EXECUTION

3.1 APPLICATION

- A. Comply with NECA 1 and NECA 101 for application of hangers and supports for electrical equipment and systems except if requirements in this Section are stricter.
- B. Maximum Support Spacing and Minimum Hanger Rod Size for Raceway: Space supports for EMT, IMC, and RMC as required by NFPA 70. Minimum rod size shall be 1/4 inch in diameter.
- C. Spring-steel clamps designed for supporting single conduits without bolts may be used for 1-1/2-inch and smaller raceways serving branch circuits and communication systems above suspended ceilings and for fastening raceways to trapeze supports.

3.2 SUPPORT INSTALLATION

- A. Comply with NECA 1 and NECA 101 for installation requirements except as specified in this Article.
- B. Raceway Support Methods: In addition to methods described in NECA 1, EMT may be supported by openings through structure members, as permitted in NFPA 70.
- C. Strength of Support Assemblies: Where not indicated, select sizes of components so strength will be adequate to carry present and future static loads within specified loading limits. Minimum static load used for strength determination shall be weight of supported components plus 200 lb.
- D. Mounting and Anchorage of Surface-Mounted Equipment and Components: Anchor and fasten electrical items and their supports to building structural elements by the following methods unless otherwise indicated by code:
 - 1. To Wood: Fasten with lag screws or through bolts.
 - 2. To New Concrete: Bolt to concrete inserts.
 - 3. To Masonry: Approved toggle-type bolts on hollow masonry units and expansion anchor fasteners on solid masonry units.
 - 4. To Existing Concrete: Expansion anchor fasteners.
 - 5. Instead of expansion anchors, powder-actuated driven threaded studs provided with lock washers and nuts may be used in existing standard-weight concrete 4 inches thick or greater. Do not use for anchorage to lightweight-aggregate concrete or for slabs less than 4 inches thick.
 - 6. To Steel: Beam clamps (MSS Type 19, 21, 23, 25, or 27) complying with MSS SP-69.
 - 7. To Light Steel: Sheet metal screws.

- 8. Items Mounted on Hollow Walls and Nonstructural Building Surfaces: Mount cabinets, panelboards, disconnect switches, control enclosures, pull and junction boxes, transformers, and other devices on slotted-channel racks attached to substrate.
- E. Drill holes for expansion anchors in concrete at locations and to depths that avoid reinforcing bars.

3.3 INSTALLATION OF FABRICATED METAL SUPPORTS

- A. Comply with installation requirements in Section 055000 "Metal Fabrications" for site-fabricated metal supports.
- B. Cut, fit, and place miscellaneous metal supports accurately in location, alignment, and elevation to support and anchor electrical materials and equipment.
- C. Field Welding: Comply with AWS D1.1/D1.1M.

END OF SECTION 260529

SECTION 260533 - RACEWAYS AND BOXES FOR ELECTRICAL SYSTEMS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Metal conduits, tubing, and fittings.
2. Boxes, enclosures, and cabinets.

PART 2 - PRODUCTS

2.1 METAL CONDUITS, TUBING, AND FITTINGS

- A. Listing and Labeling: Metal conduits, tubing, and fittings shall be listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. EMT: Comply with ANSI C80.3 and UL 797.
- C. FMC: Comply with UL 1; zinc-coated steel or aluminum.
- D. Fittings for Metal Conduit: Comply with NEMA FB 1 and UL 514B.
 1. Fittings for EMT:
 - a. Material: Steel.
 - b. Type: Setscrew.

2.2 BOXES, ENCLOSURES, AND CABINETS

- A. General Requirements for Boxes, Enclosures, and Cabinets: Boxes, enclosures, and cabinets installed in wet locations shall be listed for use in wet locations.
- B. Sheet Metal Outlet and Device Boxes: Comply with NEMA OS 1 and UL 514A.
- C. Small Sheet Metal Pull and Junction Boxes: NEMA OS 1.
- D. Box extensions used to accommodate new building finishes shall be of same material as recessed box.
- E. Device Box Dimensions: 4 inches square by 2-1/8 inches deep.
- F. Gangable boxes are prohibited.

3.1 RACEWAY APPLICATION

- A. Indoors: Apply raceway products as specified below unless otherwise indicated:
 - 1. Exposed, Not Subject to Physical Damage: EMT.
 - 2. Concealed in Ceilings and Interior Walls and Partitions: EMT.
 - 3. Connection to Vibrating Equipment (Including Transformers and Hydraulic, Pneumatic, Electric Solenoid, or Motor-Driven Equipment): FMC, except use LFMC in damp or wet locations.
 - 4. Boxes and Enclosures: NEMA 250, Type 1, except use NEMA 250, Type 4 stainless steel in institutional and commercial kitchens and damp or wet locations.
- B. Minimum Raceway Size: 3/4-inch trade size.
- C. Raceway Fittings: Compatible with raceways and suitable for use and location.
 - 1. EMT: Use setscrew, fittings. Comply with NEMA FB 2.10.
 - 2. Flexible Conduit: Use only fittings listed for use with flexible conduit. Comply with NEMA FB 2.20.
- D. Install nonferrous conduit or tubing for circuits operating above 60 Hz. Where aluminum raceways are installed for such circuits and pass through concrete, install in nonmetallic sleeve.
- E. Do not install aluminum conduits, boxes, or fittings in contact with concrete or earth.
- F. Install surface raceways only where indicated on Drawings.
- G. Do not install nonmetallic conduit where ambient temperature exceeds 120 deg F.

3.2 INSTALLATION

- A. Comply with NECA 1 and NECA 101 for installation requirements except where requirements on Drawings or in this article are stricter. Comply with NECA 102 for aluminum conduits. Comply with NFPA 70 limitations for types of raceways allowed in specific occupancies and number of floors.
- B. Keep raceways at least 6 inches away from parallel runs of flues and steam or hot-water pipes. Install horizontal raceway runs above water and steam piping.
- C. Complete raceway installation before starting conductor installation.
- D. Comply with requirements in Section 260529 "Hangers and Supports for Electrical Systems" for hangers and supports.

- E. Install no more than the equivalent of three 90-degree bends in any conduit run except for control wiring conduits, for which fewer bends are allowed. Support within 12 inches of changes in direction.
- F. Conceal conduit and EMT within finished walls, ceilings, and floors unless otherwise indicated. Install conduits parallel or perpendicular to building lines.
- G. Support conduit within 12 inches of enclosures to which attached.
- H. Stub-ups to Above Recessed Ceilings:
 - 1. Use EMT, IMC, or RMC for raceways.
 - 2. Use a conduit bushing or insulated fitting to terminate stub-ups not terminated in hubs or in an enclosure.
- I. Terminate threaded conduits into threaded hubs or with locknuts on inside and outside of boxes or cabinets. Install bushings on conduits up to 1-1/4-inch trade size and insulated throat metal bushings on 1-1/2-inch trade size and larger conduits terminated with locknuts. Install insulated throat metal grounding bushings on service conduits.
- J. Install raceways square to the enclosure and terminate at enclosures with locknuts. Install locknuts hand tight plus 1/4 turn more.
- K. Do not rely on locknuts to penetrate nonconductive coatings on enclosures. Remove coatings in the locknut area prior to assembling conduit to enclosure to assure a continuous ground path.
- L. Cut conduit perpendicular to the length. For conduits 2-inch trade size and larger, use roll cutter or a guide to make cut straight and perpendicular to the length.
- M. Install pull wires in empty raceways. Use polypropylene or monofilament plastic line with not less than 200-lb tensile strength. Leave at least 12 inches of slack at each end of pull wire. Cap underground raceways designated as spare above grade alongside raceways in use.
- N. Install raceway sealing fittings at accessible locations according to NFPA 70 and fill them with listed sealing compound. For concealed raceways, install each fitting in a flush steel box with a blank cover plate having a finish similar to that of adjacent plates or surfaces. Install raceway sealing fittings according to NFPA 70.
- O. Flexible Conduit Connections: Comply with NEMA RV 3. Use a maximum of 72 inches of flexible conduit for recessed equipment subject to vibration, noise transmission, or movement; and for transformers and motors.
 - 1. Use LFMC in damp or wet locations subject to severe physical damage.
 - 2. Use LFMC or LFNC in damp or wet locations not subject to severe physical damage.

- P. Mount boxes at heights indicated on Drawings. If mounting heights of boxes are not individually indicated, give priority to ADA requirements. Install boxes with height measured to bottom of box unless otherwise indicated.
- Q. Horizontally separate boxes mounted on opposite sides of walls so they are not in the same vertical channel.
- R. Locate boxes so that cover or plate will not span different building finishes.
- S. Support boxes of three gangs or more from more than one side by spanning two framing members or mounting on brackets specifically designed for the purpose.
- T. Fasten junction and pull boxes to or support from building structure. Do not support boxes by conduits.

3.3 SLEEVE AND SLEEVE-SEAL INSTALLATION FOR ELECTRICAL PENETRATIONS

- A. Install sleeves and sleeve seals at penetrations of exterior floor and wall assemblies. Comply with requirements in Section 260544 "Sleeves and Sleeve Seals for Electrical Raceways and Cabling."

3.4 FIRESTOPPING

- A. Install firestopping at penetrations of fire-rated floor and wall assemblies.

END OF SECTION 260533

SECTION 260544 - SLEEVES AND SLEEVE SEALS FOR ELECTRICAL RACEWAYS AND CABLING

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Sleeves for raceway and cable penetration of non-fire-rated construction walls and floors.
2. Sleeve-seal systems.
3. Sleeve-seal fittings.
4. Grout.
5. Silicone sealants.

B. Related Requirements:

1. Section 078400 "Penetration Firestopping" for penetration firestopping installed in fire-resistance-rated walls, horizontal assemblies, and smoke barriers, with and without penetrating items.

PART 2 - PRODUCTS

2.1 SLEEVES

A. Wall Sleeves:

1. Steel Pipe Sleeves: ASTM A 53/A 53M, Type E, Grade B, Schedule 40, zinc coated, plain ends.

- ##### B. Sleeves for Conduits Penetrating Non-Fire-Rated Gypsum Board Assemblies: Galvanized-steel sheet; 0.0239-inch minimum thickness; round tube closed with welded longitudinal joint, with tabs for screw-fastening the sleeve to the board.

2.2 SLEEVE-SEAL FITTINGS

- ##### A. Description: Manufactured plastic, sleeve-type, waterstop assembly made for embedding in concrete slab or wall. Unit shall have plastic or rubber waterstop collar with center opening to match piping OD.

2.3 GROUT

- ##### A. Description: Nonshrink; recommended for interior and exterior sealing openings in non-fire-rated walls or floors.

- B. Standard: ASTM C 1107/C 1107M, Grade B, post-hardening and volume-adjusting, dry, hydraulic-cement grout.
- C. Design Mix: 5000-psi, 28-day compressive strength.
- D. Packaging: Premixed and factory packaged.

2.4 SILICONE SEALANTS

- A. Silicone Sealants: Single-component, silicone-based, neutral-curing elastomeric sealants of grade indicated below.
 - 1. Grade: Pourable (self-leveling) formulation for openings in floors and other horizontal surfaces that are not fire rated.
 - 2. Sealant shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- B. Silicone Foams: Multicomponent, silicone-based liquid elastomers that, when mixed, expand and cure in place to produce a flexible, nonshrinking foam.

PART 3 - EXECUTION

3.1 SLEEVE INSTALLATION FOR NON-FIRE-RATED ELECTRICAL PENETRATIONS

- A. Comply with NECA 1.
- B. Comply with NEMA VE 2 for cable tray and cable penetrations.
- C. Sleeves for Conduits Penetrating Above-Grade Non-Fire-Rated Concrete and Masonry-Unit Floors and Walls:
 - 1. Interior Penetrations of Non-Fire-Rated Walls and Floors:
 - a. Seal annular space between sleeve and raceway or cable, using joint sealant appropriate for size, depth, and location of joint.
 - b. Seal space outside of sleeves with mortar or grout. Pack sealing material solidly between sleeve and wall so no voids remain. Tool exposed surfaces smooth; protect material while curing.
 - 2. Use pipe sleeves unless penetration arrangement requires rectangular sleeved opening.
 - 3. Size pipe sleeves to provide 1/4-inch annular clear space between sleeve and raceway or cable unless sleeve seal is to be installed.

4. Install sleeves for wall penetrations unless core-drilled holes or formed openings are used. Install sleeves during erection of walls. Cut sleeves to length for mounting flush with both surfaces of walls. Deburr after cutting.
5. Install sleeves for floor penetrations. Extend sleeves installed in floors 2 inches above finished floor level. Install sleeves during erection of floors.

D. Sleeves for Conduits Penetrating Non-Fire-Rated Gypsum Board Assemblies:

1. Use circular metal sleeves unless penetration arrangement requires rectangular sleeved opening.
2. Seal space outside of sleeves with approved joint compound for gypsum board assemblies.

3.2 SLEEVE-SEAL-SYSTEM INSTALLATION

- A. Install type and number of sealing elements recommended by manufacturer for raceway or cable material and size. Position raceway or cable in center of sleeve. Assemble mechanical sleeve seals and install in annular space between raceway or cable and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make watertight seal.

3.3 SLEEVE-SEAL-FITTING INSTALLATION

- A. Install sleeve-seal fittings in new walls and slabs as they are constructed.
- B. Assemble fitting components of length to be flush with both surfaces of concrete slabs and walls. Position waterstop flange to be centered in concrete slab or wall.
- C. Secure nailing flanges to concrete forms.
- D. Using grout, seal the space around outside of sleeve-seal fittings.

END OF SECTION 260544

SECTION 260553 - IDENTIFICATION FOR ELECTRICAL SYSTEMS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Identification for raceways.
2. Identification of power and control cables.
3. Identification for conductors.
4. Equipment identification labels.

1.2 QUALITY ASSURANCE

- A. Comply with ANSI A13.1 and IEEE C2.
- B. Comply with NFPA 70.
- C. Comply with 29 CFR 1910.144 and 29 CFR 1910.145.
- D. Comply with ANSI Z535.4 for safety signs and labels.
- E. Adhesive-attached labeling materials, including label stocks, laminating adhesives, and inks used by label printers, shall comply with UL 969.

1.3 COORDINATION

- A. Coordinate identification names, abbreviations, colors, and other features with requirements in other Sections requiring identification applications, Drawings, Shop Drawings, manufacturer's wiring diagrams, and the Operation and Maintenance Manual; and with those required by codes, standards, and 29 CFR 1910.145. Use consistent designations throughout Project.
- B. Coordinate installation of identifying devices with completion of covering and painting of surfaces where devices are to be applied.
- C. Coordinate installation of identifying devices with location of access panels and doors.
- D. Install identifying devices before installing acoustical ceilings and similar concealment.

PART 2 - PRODUCTS

2.1 POWER AND CONTROL RACEWAY IDENTIFICATION MATERIALS

- A. Comply with ANSI A13.1 for minimum size of letters for legend and for minimum length of color field for each raceway size.
- B. Colors for Raceways Carrying Circuits at 600 V or Less:
 - 1. Black letters on an orange field.
 - 2. Legend: Indicate voltage and system or service type.
- C. Vinyl Labels for Raceways Carrying Circuits at 600 V or Less: Preprinted, flexible label laminated with a clear, weather- and chemical-resistant coating and matching wraparound clear adhesive tape for securing ends of legend label.
- D. Snap-Around, Color-Coding Bands for Raceways Carrying Circuits at 600 V or Less: Slit, pretensioned, flexible, solid-colored acrylic sleeve, 2 inches long, with diameter sized to suit diameter of raceway or cable it identifies and to stay in place by gripping action.

2.2 POWER AND CONTROL CABLE IDENTIFICATION MATERIALS

- A. Comply with ANSI A13.1 for minimum size of letters for legend and for minimum length of color field for each cable size.
- B. Write-On Tags: Polyester tag, 0.015 inch thick, with corrosion-resistant grommet and cable tie for attachment to conductor or cable.
 - 1. Marker for Tags: Permanent, waterproof, black ink marker recommended by tag manufacturer.
 - 2. Marker for Tags: Machine-printed, permanent, waterproof, black ink marker recommended by printer manufacturer.
- C. Snap-Around, Color-Coding Bands: Slit, pretensioned, flexible, solid-colored acrylic sleeve, 2 inches long, with diameter sized to suit diameter of cable it identifies and to stay in place by gripping action.

2.3 CONDUCTOR IDENTIFICATION MATERIALS

- A. Color-Coding Conductor Tape: Colored, self-adhesive vinyl tape not less than 3 mils thick by 1 to 2 inches wide.

- B. Self-Adhesive, Self-Laminating Polyester Labels: Preprinted, 3-mil- thick flexible label with acrylic pressure-sensitive adhesive that provides a clear, weather- and chemical-resistant, self-laminating, protective shield over the legend. Labels sized to fit the conductor diameter such that the clear shield overlaps the entire printed legend.
- C. Snap-Around, Color-Coding Bands: Slit, pretensioned, flexible, solid-colored acrylic sleeve with diameter sized to suit diameter of conductor it identifies and to stay in place by gripping action.
- D. Marker Tapes: Vinyl or vinyl-cloth, self-adhesive wraparound type, with circuit identification legend machine printed by thermal transfer or equivalent process.
- E. Write-On Tags: Polyester tag, 0.015 inch thick, with corrosion-resistant grommet and cable tie for attachment to conductor or cable.
 - 1. Marker for Tags: Permanent, waterproof, black ink marker recommended by tag manufacturer.
 - 2. Labels for Tags: Self-adhesive label, machine-printed with permanent, waterproof, black ink recommended by printer manufacturer, sized for attachment to tag.

2.4 EQUIPMENT IDENTIFICATION LABELS

- A. Self-Adhesive, Engraved, Laminated Acrylic or Melamine Label: Adhesive backed, with white letters on a dark-gray background. Minimum letter height shall be 3/8 inch.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Verify identity of each item before installing identification products.
- B. Location: Install identification materials and devices at locations for most convenient viewing without interference with operation and maintenance of equipment.
- C. Apply identification devices to surfaces that require finish after completing finish work.
- D. Self-Adhesive Identification Products: Clean surfaces before application, using materials and methods recommended by manufacturer of identification device.
- E. Attach plastic raceway and cable labels that are not self-adhesive type with clear vinyl tape with adhesive appropriate to the location and substrate.

- F. System Identification Color-Coding Bands for Raceways and Cables: Each color-coding band shall completely encircle cable or conduit. Place adjacent bands of two-color markings in contact, side by side. Locate bands at changes in direction, at penetrations of walls and floors, at 50-foot maximum intervals in straight runs, and at 25-foot maximum intervals in congested areas.
- G. Aluminum Wraparound Marker Labels and Metal Tags: Secure tight to surface of conductor or cable at a location with high visibility and accessibility.
- H. Cable Ties: For attaching tags. Use general-purpose type, except as listed below:
 - 1. In Spaces Handling Environmental Air: Plenum rated.

3.2 IDENTIFICATION SCHEDULE

- A. Accessible Raceways and Metal-Clad Cables, 600 V or Less, for Service, Feeder, and Branch Circuits More Than 30 A, and 120 V to ground: Identify with self-adhesive vinyl label. Install labels at 30-foot maximum intervals.
- B. Accessible Raceways and Cables within Buildings: Identify the covers of each junction and pull box of the following systems with self-adhesive vinyl labels with the wiring system legend and system voltage. System legends shall be as follows:
 - 1. Emergency Power.
 - 2. Power.
- C. Power-Circuit Conductor Identification, 600 V or Less: For conductors in vaults, pull and junction boxes, manholes, and handholes, use color-coding conductor tape to identify the phase.
 - 1. Color-Coding for Phase and Voltage Level Identification, 600 V or Less: Use colors listed below for ungrounded branch-circuit conductors.
 - a. Color shall be factory applied or field applied for sizes larger than No. 8 AWG, if authorities having jurisdiction permit.
 - b. Colors for 208/120-V Circuits:
 - 1) Phase A: Black.
 - 2) Phase B: Red.
 - 3) Phase C: Blue.
 - c. Colors for 480/277-V Circuits:

- 1) Phase A: Brown.
 - 2) Phase B: Orange.
 - 3) Phase C: Yellow.
- d. Colors for 240/120-V Three Phase Circuits:
- 1) Phase A: Black.
 - 2) Phase B (Hi leg): Orange.
 - 3) Phase C: Blue.
- e. Colors for 240/120-V Single Phase Circuits:
- 1) Phase A: Black.
 - 2) Phase C: Red.
- f. Field-Applied, Color-Coding Conductor Tape: Apply in half-lapped turns for a minimum distance of 6 inches from terminal points and in boxes where splices or taps are made. Apply last two turns of tape with no tension to prevent possible unwinding. Locate bands to avoid obscuring factory cable markings.
- D. Conductors to Be Extended in the Future: Attach write-on tags to conductors and list source.
- E. Auxiliary Electrical Systems Conductor Identification: Identify field-installed alarm, control, and signal connections.
1. Identify conductors, cables, and terminals in enclosures and at junctions, terminals, and pull points. Identify by system and circuit designation.
 2. Use system of marker tape designations that is uniform and consistent with system used by manufacturer for factory-installed connections.
 3. Coordinate identification with Project Drawings, manufacturer's wiring diagrams, and the Operation and Maintenance Manual.
- F. Equipment Identification Labels: On each unit of equipment, install unique designation label that is consistent with wiring diagrams, schedules, and the Operation and Maintenance Manual. Apply labels to disconnect switches and protection equipment, central or master units, control panels, control stations, terminal cabinets, and racks of each system. Systems include power, lighting, control, communication, signal, monitoring, and alarm systems unless equipment is provided with its own identification.
1. Labeling Instructions:

- a. Indoor Equipment: Self-adhesive, engraved, laminated acrylic or melamine label. Unless otherwise indicated, provide a single line of text with 1/2-inch- high letters on 1-1/2-inch- high label; where two lines of text are required, use labels 2 inches high.
 - b. Elevated Components: Increase sizes of labels and letters to those appropriate for viewing from the floor.
 - c. Unless provided with self-adhesive means of attachment, fasten labels with appropriate mechanical fasteners that do not change the NEMA or NRTL rating of the enclosure.
2. Equipment to Be Labeled:
- a. Enclosures and electrical cabinets.
 - b. Access doors and panels for concealed electrical items.
 - c. Enclosed switches.

END OF SECTION 260553

SECTION 262726 - WIRING DEVICES

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Receptacles, receptacles with integral GFCI, and associated device plates.
2. Snap switches and wall-box dimmers.
3. Floor service outlets, poke-through assemblies, service poles, and multioutlet assemblies.

1.2 DEFINITIONS

- A. EMI: Electromagnetic interference.
- B. Pigtail: Short lead used to connect a device to a branch-circuit conductor.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: List of legends and description of materials and process used for premarking wall plates.

1.4 INFORMATIONAL SUBMITTALS

- A. Field quality-control reports.

1.5 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For wiring devices to include in all manufacturers' packing-label warnings and instruction manuals that include labeling conditions.

1.6 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
 1. Poke-Through, Fire-Rated Closure Plugs: One for every five floor service outlets installed, but no fewer than two.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Manufacturers' Names: Shortened versions (shown in parentheses) of the following manufacturers' names are used in other Part 2 articles:
1. Cooper Wiring Devices; Division of Cooper Industries, Inc. (Cooper).
 2. Hubbell Incorporated; Wiring Device-Kellems (Hubbell).
 3. Leviton Mfg. Company Inc. (Leviton).
 4. Pass & Seymour/Legrand (Pass & Seymour).
- B. Source Limitations: Obtain each type of wiring device and associated wall plate from single source from single manufacturer.

2.2 GENERAL WIRING-DEVICE REQUIREMENTS

- A. Wiring Devices, Components, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Comply with NFPA 70.
- C. Devices that are manufactured for use with modular plug-in connectors may be substituted under the following conditions:
1. Connectors shall comply with UL 2459 and shall be made with stranding building wire.
 2. Devices shall comply with the requirements in this Section.

2.3 STRAIGHT-BLADE RECEPTACLES

- A. Convenience Receptacles, 125 V, 20 A: Comply with NEMA WD 1, NEMA WD 6 Configuration 5-20R, UL 498, and FS W-C-596.
1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Cooper; 5351 (single), CR5362 (duplex).
 - b. Hubbell; HBL5351 (single), HBL5352 (duplex).
 - c. Leviton; 5891 (single), 5352 (duplex).
 - d. Pass & Seymour; 5361 (single), 5362 (duplex).

2.4 TOGGLE SWITCHES

- A. Comply with NEMA WD 1, UL 20, and FS W-S-896.
- B. Switches, 120/277 V, 20 A:

1. Products: Subject to compliance with requirements, provide one of the following:

1) Single Pole:

- a) Cooper; AH1221.
- b) Hubbell; HBL1221.
- c) Leviton; 1221-2.
- d) Pass & Seymour; CSB20AC1.

2) Three Way:

- a) Cooper; AH1223.
- b) Hubbell; HBL1223.
- c) Leviton; 1223-2.
- d) Pass & Seymour; CSB20AC3.

3) Four Way:

- a) Cooper; AH1224.
- b) Hubbell; HBL1224.
- c) Leviton; 1224-2.
- d) Pass & Seymour; CSB20AC4.

2.5 WALL PLATES

A. Single and combination types shall match corresponding wiring devices.

- 1. Plate-Securing Screws: Metal with head color to match plate finish.
- 2. Material for Finished Spaces: 0.035-inch- thick, satin-finished, Type 302 stainless steel.

2.6 POKE-THROUGH ASSEMBLIES

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- 1. Hubbell Incorporated; Wiring Device-Kellems.
- 2. Pass & Seymour/Legrand.
- 3. Square D/Schneider Electric.
- 4. Thomas & Betts Corporation.
- 5. Wiremold/Legrand.

B. Description:

1. Factory-fabricated assembly of below-floor junction box with multichanneled, through-floor raceway/firestop unit and detachable matching floor service-outlet assembly.
2. Comply with UL 514 scrub water exclusion requirements.
3. Service-Outlet Assembly: As noted on drawings.
4. Size: Selected to fit nominal 3-inch or 4-inch cored holes in floor and matched to floor thickness. Refer to drawings for poke-thru specified.
5. Fire Rating: Unit is listed and labeled for fire rating of floor-ceiling assembly.
6. Closure Plug: Arranged to close unused 3-inch or 4-inch cored openings and reestablish fire rating of floor.
7. Wiring Raceways and Compartments: For a minimum of four No. 12 AWG conductors and a minimum of four, four-pair Cat 6 cables.

2.7 FINISHES

- A. Device Color: Stainless steel, black covers.
 1. Wiring Devices Connected to Normal Power System: As selected by Architect unless otherwise indicated or required by NFPA 70 or device listing.
- B. Wall Plate Color: Stainless steel, black covers.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Comply with NECA 1, including mounting heights listed in that standard, unless otherwise indicated.
- B. Coordination with Other Trades:
 1. Protect installed devices and their boxes. Do not place wall finish materials over device boxes and do not cut holes for boxes with routers that are guided by riding against outside of boxes.
 2. Keep outlet boxes free of plaster, drywall joint compound, mortar, cement, concrete, dust, paint, and other material that may contaminate the raceway system, conductors, and cables.
 3. Install wiring devices after all wall preparation, including painting, is complete.
- C. Conductors:

1. Do not strip insulation from conductors until right before they are spliced or terminated on devices.
2. Strip insulation evenly around the conductor using tools designed for the purpose. Avoid scoring or nicking of solid wire or cutting strands from stranded wire.
3. The length of free conductors at outlets for devices shall meet provisions of NFPA 70, Article 300, without pigtails.
4. Existing Conductors:
 - a. Cut back and pigtail, or replace all damaged conductors.
 - b. Straighten conductors that remain and remove corrosion and foreign matter.
 - c. Pigtailling existing conductors is permitted, provided the outlet box is large enough.

D. Device Installation:

1. Replace devices that have been in temporary use during construction and that were installed before building finishing operations were complete.
2. Keep each wiring device in its package or otherwise protected until it is time to connect conductors.
3. Do not remove surface protection, such as plastic film and smudge covers, until the last possible moment.
4. Connect devices to branch circuits using pigtails that are not less than 6 inches in length.
5. When there is a choice, use side wiring with binding-head screw terminals. Wrap solid conductor tightly clockwise, two-thirds to three-fourths of the way around terminal screw.
6. Use a torque screwdriver when a torque is recommended or required by manufacturer.
7. When conductors larger than No. 12 AWG are installed on 15- or 20-A circuits, splice No. 12 AWG pigtails for device connections.
8. Tighten unused terminal screws on the device.
9. When mounting into metal boxes, remove the fiber or plastic washers used to hold device-mounting screws in yokes, allowing metal-to-metal contact.

E. Receptacle Orientation:

1. Install ground pin of vertically mounted receptacles down, and on horizontally mounted receptacles to the right.

F. Device Plates: Do not use oversized or extra-deep plates. Repair wall finishes and remount outlet boxes when standard device plates do not fit flush or do not cover rough wall opening.

G. Arrangement of Devices: Unless otherwise indicated, mount flush, with long dimension vertical and with grounding terminal of receptacles on top. Group adjacent switches under single, multigang wall plates.

H. Adjust locations of floor service outlets and service poles to suit arrangement of partitions and furnishings.

3.2 IDENTIFICATION

- A. Comply with Section 260553 "Identification for Electrical Systems."
- B. Identify each receptacle with panelboard identification and circuit number. Use hot, stamped, or engraved machine printing with black-filled lettering on face of plate, and durable wire markers or tags inside outlet boxes.

3.3 FIELD QUALITY CONTROL

- A. Tests for Convenience Receptacles:
 - 1. Line Voltage: Acceptable range is 105 to 132 V.
 - 2. Percent Voltage Drop under 15-A Load: A value of 6 percent or higher is unacceptable.
 - 3. Ground Impedance: Values of up to 2 ohms are acceptable.
 - 4. GFCI Trip: Test for tripping values specified in UL 1436 and UL 943.
 - 5. Using the test plug, verify that the device and its outlet box are securely mounted.
 - 6. Tests shall be diagnostic, indicating damaged conductors, high resistance at the circuit breaker, poor connections, inadequate fault current path, defective devices, or similar problems. Correct circuit conditions, remove malfunctioning units and replace with new ones, and retest as specified above.
- B. Wiring device will be considered defective if it does not pass tests and inspections.
- C. Prepare test and inspection reports.

END OF SECTION 262726

SECTION 262816 - ENCLOSED SWITCHES AND CIRCUIT BREAKERS

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following individually mounted, enclosed switches and circuit breakers:
1. Fusible switches.
 2. Nonfusible switches.
 3. Molded-case circuit breakers (MCCBs).
 4. Enclosures.

1.2 SUBMITTALS

- A. Product Data: For each type of enclosed switch, circuit breaker, accessory, and component indicated. Include dimensioned elevations, sections, weights, and manufacturers' technical data on features, performance, electrical characteristics, ratings, and finishes.
1. Enclosure types and details for types other than NEMA 250, Type 1.
 2. Current and voltage ratings.
 3. Short-circuit current rating.
 4. UL listing for series rating of installed devices.
 5. Features, characteristics, ratings, and factory settings of individual overcurrent protective devices and auxiliary components.
- B. Shop Drawings: Diagram power, signal, and control wiring.
- C. Field quality-control test reports including the following:
1. Test procedures used.
 2. Test results that comply with requirements.
 3. Results of failed tests and corrective action taken to achieve test results that comply with requirements.
- D. Manufacturer's field service report.
- E. Operation and Maintenance Data: For enclosed switches and circuit breakers to include in emergency, operation, and maintenance manuals. Include the following:
1. Manufacturer's written instructions for testing and adjusting enclosed switches and circuit breakers.

2. Time-current curves, including selectable ranges for each type of circuit breaker.

1.3 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- B. Comply with NFPA 70.

1.4 COORDINATION

- A. Coordinate layout and installation of switches, circuit breakers, and components with other construction, including conduit, piping, equipment, and adjacent surfaces. Maintain required workspace clearances and required clearances for equipment access doors and panels.

PART 2 - PRODUCTS

2.1 FUSIBLE AND NONFUSIBLE SWITCHES

- A. Available Manufacturers:
 1. Eaton Corporation; Cutler-Hammer Products.
 2. General Electric Co.; Electrical Distribution & Control Division.
 3. Siemens Energy & Automation, Inc.
 4. Square D/Group Schneider.
- B. Fusible Switch, 1200 A and Smaller: NEMA KS 1, Type HD, with clips or bolt pads to accommodate specified fuses, lockable handle with capability to accept two padlocks, and interlocked with cover in closed position.
- C. Nonfusible Switch, 1200 A and Smaller: NEMA KS 1, Type HD, lockable handle with capability to accept two padlocks, and interlocked with cover in closed position.
- D. Accessories:
 1. Equipment Ground Kit: Internally mounted and labeled for copper and aluminum ground conductors.
 2. Neutral Kit: Internally mounted; insulated, capable of being grounded, and bonded; and labeled for copper and aluminum neutral conductors.
 3. Auxiliary Contact Kit: Auxiliary set of contacts arranged to open before switch blades open.

2.2 MOLDED-CASE CIRCUIT BREAKERS

- A. Circuit breakers shall be constructed using glass-reinforced insulating material. Current carrying components shall be completely isolated from the handle and the accessory mounting area.
- B. Circuit breakers shall have a toggle operating mechanism with common tripping of all poles, which provides quick-make, quick-break contact action. The circuit-breaker handle shall be over center, be trip free, and reside in a tripped position between on and off to provide local trip indication. Circuit-breaker escutcheon shall be clearly marked on and off in addition to providing international I/O markings. Equip circuit breaker with a push-to-trip button, located on the face of the circuit breaker to mechanically operate the circuit-breaker tripping mechanism for maintenance and testing purposes.
- C. The maximum ampere rating and UL, IEC, or other certification standards with applicable voltage systems and corresponding interrupting ratings shall be clearly marked on face of circuit breaker. Circuit breakers shall be 100 percent rated.
- D. MCCBs shall be equipped with a device for locking in the isolated position.
- E. Lugs shall be suitable for 194 deg F rated wire, sized according to the 167 deg F temperature rating in NFPA 70.
- F. Standard: Comply with UL 489 with interrupting capacity to comply with available fault currents.
- G. Thermal-Magnetic Circuit Breakers: Inverse time-current thermal element for low-level overloads and instantaneous magnetic trip element for short circuits. Adjustable magnetic trip setting for circuit-breaker frame sizes 250 A and larger.
- H. Adjustable, Instantaneous-Trip Circuit Breakers: Magnetic trip element with front-mounted, field-adjustable trip setting.
- I. Electronic Trip Circuit Breakers: Field-replaceable rating plug, rms sensing, with the following field-adjustable settings:
 - 1. Instantaneous trip.
 - 2. Long- and short-time pickup levels.
 - 3. Long- and short-time time adjustments.
 - 4. Ground-fault pickup level, time delay, and I-squared t response.
- J. Current-Limiting Circuit Breakers: Frame sizes 400 A and smaller, and let-through ratings less than NEMA FU 1, RK-5.
- K. Integrally Fused Circuit Breakers: Thermal-magnetic trip element with integral limiter-style fuse listed for use with circuit breaker and trip activation on fuse opening or on opening of fuse compartment door.

- L. Ground-Fault Circuit-Interrupter (GFCI) Circuit Breakers: Single- and two-pole configurations with Class A ground-fault protection (6-mA trip).
- M. Ground-Fault Equipment-Protection (GFEP) Circuit Breakers: With Class B ground-fault protection (30-mA trip).
- N. Features and Accessories:
 - 1. Standard frame sizes, trip ratings, and number of poles.
 - 2. Lugs: Compression type, suitable for number, size, trip ratings, and conductor material.
 - 3. Application Listing: Appropriate for application; Type SWD for switching fluorescent lighting loads; Type HID for feeding fluorescent and high-intensity discharge lighting circuits.
 - 4. Ground-Fault Protection: Comply with UL 1053; integrally mounted, self-powered type with mechanical ground-fault indicator; relay with adjustable pickup and time-delay settings, push-to-test feature, internal memory, and shunt trip unit; and three-phase, zero-sequence current transformer/sensor.
 - 5. Communication Capability: Universal-mounted communication module with functions and features compatible with power monitoring and control system, specified in Section 260913 "Electrical Power Monitoring and Control."
 - 6. Shunt Trip: Trip coil energized from separate circuit, with coil-clearing contact.
 - 7. Undervoltage Trip: Set to operate at 35 to 75 percent of rated voltage without intentional time delay.
 - 8. Key Interlock Kit: Externally mounted to prohibit circuit-breaker operation; key shall be removable only when circuit breaker is in off position.
 - 9. Electrical Operator: Provide remote control for on, off, and reset operations.
 - 10. Accessory Control Power Voltage: Integrally mounted, self-powered.

2.3 ENCLOSURES

- A. NEMA AB 1 and NEMA KS 1 to meet environmental conditions of installed location.
 - 1. Outdoor Locations: NEMA 250, Type 3R.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine elements and surfaces to receive enclosed switches and circuit breakers for compliance with installation tolerances and other conditions affecting performance.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 CONCRETE BASES

- A. Coordinate size and location of concrete bases. Verify structural requirements with structural engineer.
- B. Concrete base is specified in Division 26 Section "Hangers and Supports for Electrical Systems," and concrete materials and installation requirements are specified in Division 03.

3.3 INSTALLATION

- A. Comply with applicable portions of NECA 1, NEMA PB 1.1, and NEMA PB 2.1 for installation of enclosed switches and circuit breakers.
- B. Mount individual wall-mounting switches and circuit breakers with tops at uniform height, unless otherwise indicated. Anchor floor-mounting switches to concrete base.
- C. Temporary Lifting Provisions: Remove temporary lifting eyes, channels, and brackets and temporary blocking of moving parts from enclosures and components.

3.4 IDENTIFICATION

- A. Identify field-installed conductors, interconnecting wiring, and components; provide warning signs as specified in Division 26 Section "Identification for Electrical Systems."
- B. Enclosure Nameplates: Label each enclosure with engraved metal or laminated-plastic nameplate as specified in Division 26 Section "Identification for Electrical Systems."

3.5 FIELD QUALITY CONTROL

- A. Prepare for acceptance testing as follows:
 - 1. Inspect mechanical and electrical connections.
 - 2. Verify switch and relay type and labeling verification.
 - 3. Verify rating of installed fuses.

4. Inspect proper installation of type, size, quantity, and arrangement of mounting or anchorage devices complying with manufacturer's certification.

B. Perform the following field tests and inspections and prepare test reports:

1. Perform each electrical test and visual and mechanical inspection stated in NETA ATS, Section 7.5 for switches and Section 7.6 for molded-case circuit breakers. Certify compliance with test parameters.
2. Correct malfunctioning units on-site, where possible, and retest to demonstrate compliance; otherwise, replace with new units and retest.

3.6 CLEANING

- A. On completion of installation, vacuum dirt and debris from interiors; do not use compressed air to assist in cleaning.
- B. Inspect exposed surfaces and repair damaged finishes.

END OF SECTION 262816