

ADDENDUM 03

DATE: March 10, 2026

PROJECT: MSP Headquarters
Upgrade Elevators, Michigan State Police Headquarters
State Secondary Complex

DTMB File: 171/24099.TYC

H+B PROJECT: 24316

This Addendum is issued for the purpose of modifying and/or clarifying the original drawings and specifications and shall take precedence over them.

All work included herein shall be in accordance with the original drawings and specifications except as specifically noted herein. All incidental items required to provide the following modifications shall be included even though not specifically described.

This Addendum is being sent to all bidders receiving plans and specifications. Receipt of this Addendum shall be noted on Proposal Form in appropriate locations.

DRAWINGS

1. Drawing Sheet A-104 (reissued)
 - a. Added metal platform and stair to exit out of mechanical room space.
 - 1) Fabricate metal stair and platform as indicated on drawings. Platform to have bolted connections as much as possible to be movable to access existing HVAC piping.
 - b. Added hollow metal door and frame.
 - 1) Hollow metal frame to be Metallic coated steel sheet (16 gage minimum) welded frame to be field painted.
 - 2) Hollow metal door to be flush Metallic-coated steel sheet minimum thickness of 0.042 inch with full flush edge construction. Door to be field painted.
 - 3) Core to be manufacturers standard.
 - 4) Frame anchors to be post install anchors.
 - 5) Door Hardware: 1-1/2 pair of hinges, closer w/ integral door stop (90 degree open), storeroom lock and aluminum threshold. All new door hardware to match existing building hardware manufacturer for similar doors and be keyed to the owner's keying system.
 - c. Insulated metal panel to be 2.5" thick, r20, concealed fastener panel, with manufacturer's standard finish, color to match existing louver color, similar to Falk HFW 40 insulated wall panel or approved equal. Provide all necessary flashings, trims and sealant to provide a complete weather tight installation.

END OF ADDENDUM

JDM:ame

Attachment: Sheet A-104

Cc: All Plan Holders (via Sigma)

